



MILLINGTON, TN

LITTLE ROCK, AR

Job Information

Job #: 94559

Date: August 8, 2018

Priority: —

Authorized OT: No

Authorized by:

Customer Information

Name: Delta Plastics

Motor#:

Name Plate Information

Manufacturer:	Toshiba	Enclosure :	Open Drop Proof (ODP)	Horsepower/kW:	60
Serial#:	13080046630	Model#:	06045DSR41A-P	Service Factor:	1.15
Frame:	364T	Rated RPM:	1775	Rated Voltage:	230/460
Phase:	3	Rated Amps:	138/69	Cycles:	60

Special design: No

Mechanical Inspection

Inspect bolt holes and fasteners. Validate correct fasteners.

Shaft Condition: Good

Bearings Retainer: Yes

Type of grounding device:

Bearing DE Size: 6314 Z/C3

Shaft runout(TIR-Inbound): .001

Bearing ODE Size: 6312 Z/C3

Retainer condition: Good

WEST TENNESSEE
7030 Ryburn Drive
Millington, TN 38053
Phone 901-873-5300
Fax 901-873-5301

CENTRAL ARKANSAS
6812 Lindsey Rd.
Little Rock, AR 72206
Phone 501-375-9178
Fax 501-375-4254



MILLINGTON, TN

LITTLE ROCK, AR

Mechanical Inspection (Continued)

Seals DE condition :	None	Brg. Seats DE:	Good
Seals DE type:	N/A	If DE undersized, amt.:	
Seals DE size:		Brg. Seats ODE:	Good
Seals DE (inbound) condition :		If ODE undersized, amt.:	.004
Seals ODE condition :	None	Shaft damage:	OK
Seals ODE type:	N/A	Bushings/sleeves DE:	Ok
Seals ODE size:		Bushings/sleeves ODE:	Ok
Seals ODE (inbound) condition :			
Endbell fits/damage:	Bad	Foot/Flange condition:	Ok
Endbell DE size:	5.9064	Foot flatness:	Pass
Endbell DE insulated?:	No	Does Air Gap Meet Customer or EASA spec(<10% variation)?	
Endbell ODE size:	5.1195		
Endbell ODE insulated?:	No		

Conclusion

Service Tech name: Terrence Holland

Service Tech signature: