



MILLINGTON, TN

LITTLE ROCK, AR

## Job Information

Job #: 94600

Date: August 14, 2018

Priority: —

Authorized OT: No

Authorized by:

## Customer Information

Name: Stuttgart flour

Motor#:

## Name Plate Information

Manufacturer:	ABB	Enclosure :	Open Drop Proof (ODP)	Horsepower/kW:	400
Serial#:	WAA013598	Model#:	447THDN17055M W	Service Factor:	
Frame:		Rated RPM:	1785	Rated Voltage:	460
Phase:	3	Rated Amps:	152	Cycles:	60

Special design: No

## Mechanical Inspection

Inspect bolt holes and fasteners. Validate correct fasteners.

Shaft Condition: Good

Bearings Retainer: Yes

Type of grounding device:

Bearing DE Size: 6318 2z

Shaft runout(TIR-Inbound): .001

Bearing ODE Size: 6314 2Z

Retainer condition: Good

**WEST TENNESSEE**  
7030 Ryburn Drive  
Millington, TN 38053  
Phone 901-873-5300  
Fax 901-873-5301

**CENTRAL ARKANSAS**  
6812 Lindsey Rd.  
Little Rock, AR 72206  
Phone 501-375-9178  
Fax 501-375-4254



MILLINGTON, TN

LITTLE ROCK, AR

## Mechanical Inspection (Continued)

Seals DE condition :	Worn	Brg. Seats DE:	Good
Seals DE type:	Slinger	If DE undersized, amt.:	Over sized
Seals DE size:		Brg. Seats ODE:	Good
Seals DE (inbound) condition :		If ODE undersized, amt.:	
Seals ODE condition :	Worn	Shaft damage:	OK
Seals ODE type:	Slinger	Bushings/sleeves DE:	Ok
Seals ODE size:		Bushings/sleeves ODE:	Ok
Seals ODE (inbound) condition :			
Endbell fits/damage:	Good	Foot/Flange condition:	Ok
Endbell DE size:	7.4800	Foot flatness:	Pass
Endbell DE insulated?:	—	Does Air Gap Meet Customer or EASA spec(<10% variation)?	
Endbell ODE size:	Bad lip worn		
Endbell ODE insulated?:	—		

## Conclusion

Service Tech name: Terrence Holland

Service Tech signature: