

Job Information

Job #: 94624 Date: August 20, 2018

Priority: — Authorized OT: No Authorized by:

Customer Information

Name: Motor#:

Name Plate Information

Manufacturer: Siemens Enclosure: Totally Enclosed Horsepower/kW: 60

Fan Cooled

Serial#: J04T0140EU3 Model#: 1LA03644FP21 Service Factor: 1.15

Frame: 354T Rated RPM: 1775 Rated Voltage: 230/460

Phase: 3 Rated Amps: 142/70.8 Cycles: 60

Special design: No

Mechanical Inspection

Inspect bolt holes and fasteners. Validate correct fasteners.

Shaft Condition: Good Bearings Retainer: No

Type of grounding device: Bearing DE Size: 6314/2Z

Shaft runout(TIR-Inbound): .001 Bearing ODE Size: 6210/2Z

Retainer condition: —



Mechanical Inspection (Continued)

Seals DE condition: Brittle Brg. Seats DE: Good

Seals DE type: Slinger If DE undersized, amt.:

Seals DE size: Brg. Seats ODE: Good

Seals DE (inbound) condition: If ODE undersized, amt.:

Seals ODE condition: Shaft damage: OK None

Seals ODE type: Slinger

Bushings/sleeves DE: Ok Seals ODE size:

Bushings/sleeves ODE: Ok Seals ODE (inbound) condition:

> Endbell fits/damage: Bad Foot/Flange condition: Ok

Endbell DE size: 5.9070 Foot flatness: **Pass**

Endbell DE insulated?:

Does Air Gap Meet Customer or EASA spec(<10% Endbell ODE size: 3.5447

variation)?

Endbell ODE insulated?: No

Conclusion

Service Tech name: Terrence Holland

Service Tech signature: