



MILLINGTON, TN

LITTLE ROCK, AR

Job Information

Job #: 94691

Date: September 14, 2018

Priority: —

Authorized OT: No

Authorized by:

Customer Information

Name: Molex

Motor#:

Name Plate Information

Manufacturer:	Siemens	Enclosure :	Open Drop Proof (ODP)	Horsepower/kW:	450
Serial#:	A07TESP1111	Model#:		Service Factor:	
Frame:	449TDZ	Rated RPM:	3570	Rated Voltage:	460
Phase:	3	Rated Amps:	489	Cycles:	60

Special design: No

Mechanical Inspection

Inspect bolt holes and fasteners. Validate correct fasteners.

Shaft Condition: Other

Bearings Retainer: No

Type of grounding device:

Bearing DE Size: 6216 ZZ

Shaft runout(TIR-Inbound):

Bearing ODE Size: 6313 ZZ

Retainer condition: —

WEST TENNESSEE
7030 Ryburn Drive
Millington, TN 38053
Phone 901-873-5300
Fax 901-873-5301

CENTRAL ARKANSAS
6812 Lindsey Rd.
Little Rock, AR 72206
Phone 501-375-9178
Fax 501-375-4254



MILLINGTON, TN

LITTLE ROCK, AR

Mechanical Inspection (Continued)

Seals DE condition :	None	Brg. Seats DE:	Good
Seals DE type:	N/A	If DE undersized, amt.:	
Seals DE size:		Brg. Seats ODE:	Good
Seals DE (inbound) condition :		If ODE undersized, amt.:	
Seals ODE condition :	None	Shaft damage:	Salvageable
Seals ODE type:	N/A	Bushings/sleeves DE:	Ok
Seals ODE size:		Bushings/sleeves ODE:	Ok
Seals ODE (inbound) condition :			
Endbell fits/damage:	Good	Foot/Flange condition:	Ok
Endbell DE size:	5.5123	Foot flatness:	Pass
Endbell DE insulated?:	No	Does Air Gap Meet Customer or EASA spec(<10% variation)?	
Endbell ODE size:	5.5127		
Endbell ODE insulated?:	No		

Conclusion

Service Tech name: Lynn McDonald

Service Tech signature:

WEST TENNESSEE
7030 Ryburn Drive
Millington, TN 38053
Phone 901-873-5300
Fax 901-873-5301

CENTRAL ARKANSAS
6812 Lindsey Rd.
Little Rock, AR 72206
Phone 501-375-9178
Fax 501-375-4254