

Job Information

Job #:	94765				Date:	October 3, 2018
Priority:	_	Authorized OT:	No	Authorized by:		

Customer Information

Name:	Future Fuel	Motor#	

Name Plate Information

Manufacturer:	US	Enclosure :	Explosion-proof enclosures (EXPL/	Horsepower/kW:	3
Serial#:		Model#:		Service Factor:	
Frame:	182TD	Rated RPM:	3515	Rated Voltage:	230/460
Phase:	3	Rated Amps:	7.8/3.9	Cycles:	60

Special design: No

Mechanical Inspection

Inspect bolt holes and fasteners. Validate correct fasteners.

Shaft Condition:	Good	Bearings Retainer:	Yes
Type of grounding device:	NA	Bearing DE Size:	6307ZZ
Shaft runout(TIR-Inbound):		Bearing ODE Size:	6205ZZ

Retainer condition:

WEST TENNESSEE 7030 Ryburn Drive Millington, TN 38053 Phone 901-873-5300 Fax 901-873-5301 CENTRAL ARKANSAS 6812 Lindsey Rd. Little Rock, AR 72206 Phone 501-375-9178 Fax 501-375-4254





Mechanical Inspection (Continued)

Seals DE condition :	None	Brg. Seats DE:	Good
Seals DE type:	Slinger	If DE undersized, amt.:	
Seals DE size:		Brg. Seats ODE:	Good
Seals DE (inbound) condition :		If ODE undersized, amt.:	
Seals ODE condition :	None	Shaft damage:	ОК
Seals ODE type:	N/A		
Seals ODE size:		Bushings/sleeves DE:	Ok
Seals ODE (inbound) condition :		Bushings/sleeves ODE:	Ok
Endbell fits/damage:	Good	Foot/Flange condition:	Ok
Endbell DE size:	3.1503	Foot flatness:	Pass
Endbell DE insulated?:	No	Doos Air Gan Moot Cu	stomer or EASA spec(<10%
Endbell ODE size:	2.0479	variation)?	
Endbell ODE insulated?:	No	_	

Conclusion

Service Tech name:

Robert Wiley

Service Tech signature:

stow iley

WEST TENNESSEE 7030 Ryburn Drive Millington, TN 38053 Phone 901-873-5300 Fax 901-873-5301 CENTRAL ARKANSAS 6812 Lindsey Rd. Little Rock, AR 72206 Phone 501-375-9178 Fax 501-375-4254