



MILLINGTON, TN

LITTLE ROCK, AR

Job Information

Job #: 94827

Date: October 29,
2018

Priority: —

Authorized OT: No

Authorized by:

Customer Information

Name: Cameron Valve

Motor#:

Name Plate Information

Manufacturer: WEG

Enclosure : Open Drop Proof
(ODP)

Horsepower/kW: 3

Serial#:

Model#: 00336ES3EF56

Service Factor: 1.15

Frame: F56HC

Rated RPM: 3450

Rated Voltage: 230/460

Phase: 3

Rated Amps: 7.6/3.8

Cycles: 60

Special design: No

Mechanical Inspection

Inspect bolt holes and fasteners. Validate correct fasteners.

Shaft Condition: Good

Bearings Retainer: Yes

Type of grounding device: None

Bearing DE Size: 6204 Z

Shaft runout(TIR-Inbound): .001

Bearing ODE Size: 6203 Z

Retainer condition: —

WEST TENNESSEE
7030 Ryburn Drive
Millington, TN 38053
Phone 901-873-5300
Fax 901-873-5301

CENTRAL ARKANSAS
6812 Lindsey Rd.
Little Rock, AR 72206
Phone 501-375-9178
Fax 501-375-4254



MILLINGTON, TN

LITTLE ROCK, AR

Mechanical Inspection (Continued)

Seals DE condition :	Other	Brg. Seats DE:	Good
Seals DE type:	Slinger	If DE undersized, amt.:	
Seals DE size:		Brg. Seats ODE:	Good
Seals DE (inbound) condition :		If ODE undersized, amt.:	
Seals ODE condition :	Other	Shaft damage:	OK
Seals ODE type:	Slinger	Bushings/sleeves DE:	Ok
Seals ODE size:		Bushings/sleeves ODE:	Ok
Seals ODE (inbound) condition :			
Endbell fits/damage:	Good	Foot/Flange condition:	Ok
Endbell DE size:	1.8510	Foot flatness:	Pass
Endbell DE insulated?:	No	Does Air Gap Meet Customer or EASA spec(<10% variation)?	
Endbell ODE size:	1.5799		
Endbell ODE insulated?:	No		

Conclusion

Service Tech name: Terrence Holland

Service Tech signature: