



MILLINGTON, TN

LITTLE ROCK, AR

Job Information

Job #: 135457

Date: October 15, 2018

Priority: —

Authorized OT: No

Authorized by:

Customer Information

Name: KTG

Motor#:

Name Plate Information

Manufacturer:	GE	Enclosure :	Totally Enclosed Fan Cooled	Horsepower/kW:	50
Serial#:	SEG223015	Model#:	5KS365SS308D1	Service Factor:	1.15
Frame:	365T	Rated RPM:	1195	Rated Voltage:	460
Phase:	3	Rated Amps:	58.2	Cycles:	60

Special design: No

Mechanical Inspection

Inspect bolt holes and fasteners. Validate correct fasteners.

Shaft Condition: Good

Bearings Retainer: Yes

Type of grounding device:

Bearing DE Size: 6314

Shaft runout(TIR-Inbound): .001

Bearing ODE Size: 6314

Retainer condition: Good

WEST TENNESSEE
7030 Ryburn Drive
Millington, TN 38053
Phone 901-873-5300
Fax 901-873-5301

CENTRAL ARKANSAS
6812 Lindsey Rd.
Little Rock, AR 72206
Phone 501-375-9178
Fax 501-375-4254



MILLINGTON, TN

LITTLE ROCK, AR

Mechanical Inspection (Continued)

DE shaft extension : 1.3745

Shaft damage: OK

DE shaft extension keyway: .625

Shaft Brg. Journal DE: Good

ODE shaft extension : N/A

If DE undersized, amt.:

ODE shaft extension keyway: N/A

Shaft air Seal DE size: 2.5

Shaft Brg. Journal ODE: Good

Shaft air Seal ODE size: 2.5

If ODE undersized, amt.:

DE Endbell fits/damage: Good

ODE Endbell fits/damage: Good

Endbell DE size: 5.9055

Endbell ODE size: 5.9055

Endbell DE air seal size: 2.505

Endbell ODE air seal size: 2.505

Endbell DE insulated?: No

Endbell ODE insulated?: No

Does Air Gap Meet Customer or EASA spec(<10% variation)?

Foot flatness: Pass

Yes

Conclusion

Service Tech name: BILLY MAYS

Service Tech signature:

WEST TENNESSEE
7030 Ryburn Drive
Millington, TN 38053
Phone 901-873-5300
Fax 901-873-5301

CENTRAL ARKANSAS
6812 Lindsey Rd.
Little Rock, AR 72206
Phone 501-375-9178
Fax 501-375-4254