



MILLINGTON, TN

LITTLE ROCK, AR

Job Information

Job #: 138470

Date: November 6,
2018

Priority: —

Authorized OT: No

Authorized by:

Customer Information

Name: USG INTERIORS

Motor#:

Name Plate Information

Manufacturer:	SIEMENS	Enclosure :	Totally Enclosed Fan Cooled	Horsepower/kW:	30
Serial#:	C03T0619TE1B	Model#:	1LA03244SE41	Service Factor:	N/A
Frame:	324T	Rated RPM:	1770	Rated Voltage:	460
Phase:	3	Rated Amps:	47	Cycles:	60

Special design: No

Mechanical Inspection

Inspect bolt holes and fasteners. Validate correct fasteners.

Shaft Condition: Good

Bearings Retainer: Yes

Type of grounding device:

Bearing DE Size: 6312

Shaft runout(TIR-Inbound): .001

Bearing ODE Size: 6312

Retainer condition: Good

WEST TENNESSEE
7030 Ryburn Drive
Millington, TN 38053
Phone 901-873-5300
Fax 901-873-5301

CENTRAL ARKANSAS
6812 Lindsey Rd.
Little Rock, AR 72206
Phone 501-375-9178
Fax 501-375-4254



MILLINGTON, TN

LITTLE ROCK, AR

Mechanical Inspection (Continued)

DE shaft extension :	2.124	Shaft damage:	OK
DE shaft extension keyway:	.5	Shaft Brg. Journal DE:	Good
ODE shaft extension :	1.935	If DE undersized, amt.:	
ODE shaft extension keyway:	.5		
Shaft air Seal DE size:	2.363	Shaft Brg. Journal ODE:	Good
Shaft air Seal ODE size:	2.363	If ODE undersized, amt.:	
DE Endbell fits/damage:	Bad	ODE Endbell fits/damage:	Bad
Endbell DE size:	5.123	Endbell ODE size:	5.124
Endbell DE air seal size:	2.400	Endbell ODE air seal size:	2.380
Endbell DE insulated?:	No	Endbell ODE insulated?:	No
		Does Air Gap Meet Customer or EASA spec(<10% variation)?	
Foot flatness:	Pass	Yes	

Conclusion

Service Tech name: BILLY MAYS

Service Tech signature:

WEST TENNESSEE
7030 Ryburn Drive
Millington, TN 38053
Phone 901-873-5300
Fax 901-873-5301

CENTRAL ARKANSAS
6812 Lindsey Rd.
Little Rock, AR 72206
Phone 501-375-9178
Fax 501-375-4254