



MILLINGTON, TN

LITTLE ROCK, AR

Job Information

Job #: 139116

Date: February 20, 2019

Priority: —

Authorized OT: No

Authorized by:

Customer Information

Name: USG INTERIORS

Motor#: 000730

Name Plate Information

Manufacturer:	GE	Enclosure :	Totally Enclosed Fan Cooled	Horsepower/kW:	100
Serial#:	XJ6436021	Model#:	5KS405SS208D11	Service Factor:	N/A
Frame:	405T	Rated RPM:	1790	Rated Voltage:	460
Phase:	3	Rated Amps:	113	Cycles:	60

Special design: No

Mechanical Inspection

Inspect bolt holes and fasteners. Validate correct fasteners.

Shaft Condition: Other

Bearings Retainer: Yes

Type of grounding device:

Bearing DE Size: 6316

Shaft runout(TIR-Inbound): .001

Bearing ODE Size: 6316

Retainer condition: Good

WEST TENNESSEE
7030 Ryburn Drive
Millington, TN 38053
Phone 901-873-5300
Fax 901-873-5301

CENTRAL ARKANSAS
6812 Lindsey Rd.
Little Rock, AR 72206
Phone 501-375-9178
Fax 501-375-4254



MILLINGTON, TN

LITTLE ROCK, AR

Mechanical Inspection (Continued)

DE shaft extension :	2.873	Shaft damage:	OK
DE shaft extension keyway:	.75	Shaft Brg. Journal DE:	Good
ODE shaft extension :	2.5025	If DE undersized, amt.:	
ODE shaft extension keyway:	.312	Shaft Brg. Journal ODE:	Good
Shaft air Seal ODE size:	2.998	If ODE undersized, amt.:	
Shaft air Seal DE size:	2.998		
DE Endbell fits/damage:	Bad	ODE Endbell fits/damage:	Good
Endbell DE size:	6.695	Endbell ODE size:	6.693
Endbell DE air seal size:	3.045	Endbell ODE air seal size:	3.045
Endbell DE insulated?:	No	Endbell ODE insulated?:	No
Foot flatness:	Pass	Does Air Gap Meet Customer or EASA spec(<10% variation)?	—

Conclusion

Service Tech name: BILLY MAYS

Service Tech signature:

WEST TENNESSEE
7030 Ryburn Drive
Millington, TN 38053
Phone 901-873-5300
Fax 901-873-5301

CENTRAL ARKANSAS
6812 Lindsey Rd.
Little Rock, AR 72206
Phone 501-375-9178
Fax 501-375-4254