

Job Information

Job #: 140148 Date: July 20, 2019

Priority: 1A Rush/OT Authorized OT: No Authorized by: Terry Goddard

Customer Information

Name: National HVAC Motor#: B06 9982A R-A2

Name Plate Information

Manufacturer: Bell & Gossett Enclosure: Open Drop Proof Horsepower/kW: N/A

(ODP)

Serial#: 398675 Model#: VTP-CT Service Factor: N/A

Frame: 14HMO Rated RPM: 255 Capacity Rated Voltage:

Phase: 6-3-98 MFD Rated Amps: Head- 135 Cycles: Stages- 2

Special design: No

Mechanical Inspection

Inspect bolt holes and fasteners. Validate correct fasteners.

Shaft Condition: Worn Bearings Retainer: No

Type of grounding device: N/A Bearing DE Size: N/A

Shaft runout(TIR-Inbound): N/A Bearing ODE Size: N/A

Retainer condition: Good





Worn Shaft

Old Seals

G



Packing Seal

New bolts installed in seal housing.



Mechanical Inspection (Continued)

DE shaft extension : N/A Shaft damage: Salvageable

DE shaft extension keyway: N/A Shaft Brg. Journal DE: Good

ODE shaft extension: N/A If DE undersized, amt.: N/A

ODE shaft extension keyway: N/A Shaft air Seal ODE size: N/A

Shaft air Seal ODE size: N/A Shaft Brg. Journal ODE: Good

Shaft air Seal ODE size: N/A If ODE undersized, amt.: N/A

Shaft air Seal DE size: N/A ODE Endbell fits/damage: Good

Shaft air Seal ODE size: N/A

DE Endbell fits/damage: Good

Endbell DE size: N/A Customer Name: Terry Goddard

Customer Signature:

Conclusion

Service Tech name: Erich Sodam/Billy Mays

Service Tech signature:

Bully

WEST TENNESSEE