

AC Recondition Repair Report

FolderID: 97884 FormID: 10076192

P5

7030 Ryburn Dr Millington, Tn 38053 901-873-5300

Hi-Speed Industrial Service

Kimberly Clark (10176-KCM) 500 Murphy Dr. Maumelle, AR 72113

Priorities Found: 1 - High

16 - Good

Genera	General		
1.	Job Number	97884	
2.	Report Date		
3.	Customer	KIMBERLY-CLARK	
Name Plate Information		O	

GE Manufacturer













































5.	Model		
6.	Serial Number	RK6173045	
7.	Horsepower	150	
8.	KW		
9.	Volts	460	
10.	Amps	161	
11.	RPM	1785	
12.	Frame	449T	
13.	Enclosure	TEFC	
14.	Cycles	60	
15.	Phase	3	



Initial Inspection 18. Number of Leads 3



19.	Lead Length	7 Inches
20.	Lead Size	
21.	Lead Condition	(P) Pass
22.	Lead Markings	
23.	Lug Size, Condition, and Type	
24.	Winding RTD's	
25.	Winding Rtd's Condition	
26.	Shaft Run Out	
27.	Does Shaft Turn Freely	yes
28.	Does Shaft Have Visible Damage	no
29.	Bearing Rtd's	
30.	Bearing Rtd's Condition	
31.	Contamination	
	Grease dirty	
32.	Frame Condition	(P) Pass
33.	Fan Condition	(P) Pass P109



34. Broken or missing components Fan cover bolt broken off

P113

P13



Initial Electric Test

0

Mohm P7



- 36. Winding Resistance 1-2
- 37. Winding Resistance 2-3
- 38. Winding Resistance 1-3
- 39. Resistive Imbalance
- 40. Hi-Pot
- 41. Surge Test

(P) Pass

P58



P65 Stator Condition pass



Failure Location

Initial Rotor Inspection

0

P4





45.	Air Gap <10% Variation	
46.	Number of Rotor Bars	0
47.	Number of Broken Rotor Bars	
48.	Growler Test	(P) Pass
49.	Rotor Condition	(P) Pass

Mechanical Inspection

0 P1 Bearing Manufacture koyo



}	nu6318	Bearing DE Size	51.
ı	NU	2. Bearing DE Type	52.
	1	B. DE Bearing Qty.	53.
•	6318Z/C3	4. Bearing ODE Size	54.
	regular ball bearing	5. Bearing ODE Type	55.
	1	6. ODE Bearing Qty.	56.
)	no	7. Insulated Bearing	57.
	grease	3. Lubrication Type	58.
il P74	(F) Fail	9. Grease Condition	59.



69. Service Technician



Terrence Holland

6 0.	Bearing Retainers	(Y) Yes
61.	Shaft Grounding Device	(NA) Not Applicable
62.	DE Seal	(NA) Not Applicable
63.	DE Seal Type/Size	
64.	ODE Seal	(NA) Not Applicable
65.	ODE Seal Type/Size	
Root C	ause of Failure	
66.	Component Failure	bearings
67.	Cause of Failure	
	Contaminated grease	
68.	Comments	

Tom Holland

Customer request modification for tach attachment on ode.

Machine Fit Inspection Report			
	70.	Shaft Run Out	(P) Pass
	71.	Initial Shaft Run Out	0.002 "
	72.	Final Shaft Run Out	0.002 "
	73.	DE Bearing Shaft Fit	(P) Pass
	74.	DE Initial Shaft Bearing Fit Size 1	3.5449 "
	75.	DE Initial Shaft Bearing Fit Size 2	3.5448 "
	76.	DE Initial Shaft Bearing Fit Size 3	3.5449 "

77.	DE Finial Shaft Bearing Fit Size 1	3.5449 "
78.	DE Finial Shaft Bearing Fit Size 2	3.5449 "
79.	DE Finial Shaft Bearing Fit Size 3	3.5449 "
8 0.	ODE Bearing Shaft Fit	(P) Pass
81.	ODE Initial Shaft Bearing Fit Size 1	3.5434 "
82.	ODE Initial Shaft Bearing Fit Size 2	3.5434 "
83.	ODE Initial Shaft Bearing Fit Size 3	3.5434 "
84.	ODE Finial Shaft Bearing Fit Size 1	3.5434 "
85.	ODE Finial Shaft Bearing Fit Size 2	3.5434 "
86.	ODE Finial Shaft Bearing Fit Size 3	3.5434 "
87.	DE Air Seal Shaft Fit	
88.	DE Initial Air Seal Shaft Size	
89.	DE Final Air Seal Shaft Size	
90.	ODE Air Seal Shaft Fit	
91.	ODE Initial Air Seal Shaft Size	
92.	ODE Final Air Seal Shaft Size	
93.	DE Endbell Fit	(P) Pass
94.	DE Initial Endbell Fit Size 1	7.4812 "
95.	DE Initial Endbell Fit Size 2	7.4814 "
96.	DE Initial Endbell Fit Size 3	7.4814 "
97.	DE Final Endbell Fit Size 1	
98.	DE Finial Endbell Fit Size 2	
99.	DE Final Endbell Fit Size 3	
	DE Endbell Fit Insulated	(NA) Not Applicable
	DE Endbell Air Seal Fit	(ivi) iter rippiisasis
	Initial Endbell Air Seal Fit Size	
	Finial Endbell Air Seal Fit Size	
	ODE Endbell Fit	(P) Pass
	ODE Initial Endbell Fit Size 1	7.4809 "
	ODE Initial Endbell Fit Size 2	7.4811 "
	ODE Initial Endbell Fit Size 3	7.4809 "
108.		
109.		
	ODE Final Endbell Fit Size 3	
111.		
112.		
113.		
114.		
	Foot Flatness	(P) Pass
_	Foot Condition	(P) Pass
	Flange Condition	(NA) Not Applicable
	Service Technician	Terrence Holland
7-	Jell 1	
Balanc	ing Report	io io
Balanc	ing Report	Ō

P6 119. Balance Type **Standard**





120. Balance Operating Speed **RPM**

121. Start Left End

122. Start Right End

123. Balancing Specification

124. Finish Left End

125. Finish Right End

126. Service Technician **Terrence Holland**

Assembly and Final Test

Mohm

127. Meggar Testing Reading

0

Р3



128. Surge Test (P) Pass

129. Hi-Pot

130. Winding Resistance 1-2

131. Winding Resistance 2-3

132. Winding Resistance 1-3

133. Test Run Voltage Phase A

134. Test Run Amps A

135. Test Run Voltage Phase B

136. Test Run Amps B	
137. Test Run Voltage Phase C	
138. Test Run Amps C	
139. DE Horizontal Vibration Reading	0.06 In/Sec
140. DE Vertical Vibration Reading	0.04 In/Sec
141. DE Axial Vibration Reading	0.02 In/Sec
142. ODE Horizontal Vibration Reading	4 In/Sec
143. ODE Vertical Vibration Reading	0.05 In/Sec
144. ODE Axial Vibration Reading	0.03 In/Sec
145. Ambient Temp at start of Test Run	
146. Temp at 5 minutes	
147. Temp at 10 minutes	
148. Temp at 15 minutes	
149. Temp at 20 minutes	
150. Temp at 25 minutes	
151. Temp at 30 minutes	
152. Temp at 35 minutes	
153. Temp at 40 minutes	
154. Temp at 45 minutes	
155. Temp at 50 minutes	
156. Temp at 55 minutes	
157. Temp at 60 minutes	
158. Motor Paint	P136










Hi-Speed Industrial Service disclaims all warranties, both express and implied, relating to the information, reports, opinions and analysis disclosed to the Customer by Hi-Speed. Hi-Speed shall not be liable for any errors or omissions, or any losses, injury or damages arising from the use of such information, reports, opinions and analysis by the Customer.





















159. Service Technician

Lever Holland

Terrence Holland