

AC Recondition Repair Report

FolderID: 97719 FormID: 9743197

7030 Ryburn Dr Millington, Tn 38053 901-873-5300

Hi-Speed Industrial Service

0

P5

Welspun Tubular (11685)

9301 Frazier Pike Little Rock, AR 72206

Priorities Found: 1 - High

15 - Good


General

- 97719 1. Job Number
- Report Date
- 3. Customer


Name Plate Information

Manufacturer









5.	Model	FOM160L
6.	Serial Number	06062692
7.	Horsepower	
8.	KW	15 KW
9.	Volts	48 Volts
10.	Amps	28.6 Amps
11.	RPM	RPM
12.	Frame	
13.	Enclosure	
14.	Cycles	
15.	Phase	

16.	Service Factor	
17.	Motor Mount Position	
	nspection	
18.	Number of Leads	6
19.	Lead Length	6 Inches
20.	Lead Size	10
21.	Lead Condition	(P) Pass
22.	Lead Markings	printed labels
23.	Lug Size, Condition, and Type	pou
24.	Winding RTD's	(Y) Yes
25.	Winding Rtd's Condition	(P) Pass
26.	Shaft Run Out	()
27.	Does Shaft Turn Freely	rough to turn
28.	Does Shaft Have Visible Damage	_
29.	Bearing Rtd's	(NA) Not Applicable
30.	Bearing Rtd's Condition	
31.	Contamination	
32.	Frame Condition	
33.	Fan Condition	(F) Fail
-	Fan and cover missing	
34.	Broken or missing components	
	Fan and cover	
nitial l	Electric Test	
35.	Resistance to Ground	Mohm
36.	Winding Resistance 1-2	Ohm
37.	Winding Resistance 2-3	
38.	Winding Resistance 1-3	
39.	Resistive Imbalance	%
40.	Hi-Pot	Ua
41.	Surge Test	(P) Pass
42.	Stator Condition	good
43.	Failure Location	
nitial l	Rotor Inspection	
44.	Rotor Type	cast aluminum
45.	Air Gap <10% Variation	
46.	Number of Rotor Bars	28
47.	Number of Broken Rotor Bars	
48.	Growler Test	(P) Pass
49.	Rotor Condition	(P) Pass
Mecha	nical Inspection	
50.	Bearing Manufacture	NSK
51.	Bearing DE Size	6309 2Z
52.	Bearing DE Type	deep groove ball
53.	DE Bearing Qty.	1
54.	Bearing ODE Size	6309 2Z
55.	Bearing ODE Type	deep groove ball
56.	ODE Bearing Qty.	1
57.	Insulated Bearing	

58.	Lubrication Type		
59.	Grease Condition		
60.	Bearing Retainers		
61.	Shaft Grounding Device		
62.	DE Seal	(Y) Yes	
63.	DE Seal Type/Size	45 62 12	
64.	ODE Seal	(Y) Yes	
65.	ODE Seal Type/Size	45 62 12	
Root Cause of Failure			
66.	Component Failure	contaminated bearings	
67.	Cause of Failure		
	Environmental		
68.	Comments		
	2 - 45x56x12 seals 2 - 6309 2Z bearings		
	Service Technician	David Maclin	

DA

Machi	ne Fit Inspection Report	
70.	Shaft Run Out	
71.	Initial Shaft Run Out	
72.	Final Shaft Run Out	
73.	DE Bearing Shaft Fit	(P) Pass
74.	DE Initial Shaft Bearing Fit Size 1	1.772 "
75.	DE Initial Shaft Bearing Fit Size 2	1.7721 "
76.	DE Initial Shaft Bearing Fit Size 3	1.7719 "
77.	DE Finial Shaft Bearing Fit Size 1	
78.	DE Finial Shaft Bearing Fit Size 2	
79.	DE Finial Shaft Bearing Fit Size 3	
80.	ODE Bearing Shaft Fit	(P) Pass
81.	ODE Initial Shaft Bearing Fit Size 1	1.7721 "
82.	ODE Initial Shaft Bearing Fit Size 2	1.7721 "
83.	ODE Initial Shaft Bearing Fit Size 3	1.7721 "
84.	ODE Finial Shaft Bearing Fit Size 1	
85.	ODE Finial Shaft Bearing Fit Size 2	
86.	ODE Finial Shaft Bearing Fit Size 3	
87.	DE Air Seal Shaft Fit	
88.	DE Initial Air Seal Shaft Size	
89.	DE Final Air Seal Shaft Size	
90.	ODE Air Seal Shaft Fit	
91.	ODE Initial Air Seal Shaft Size	
92.	ODE Final Air Seal Shaft Size	
93.	DE Endbell Fit	(P) Pass
94.	DE Initial Endbell Fit Size 1	3.9373 "
95.	DE Initial Endbell Fit Size 2	3.9373 "

96.			
	DE Initial Endbell Fit Size 3	3.9374 "	
97.	DE Final Endbell Fit Size 1		
98.	DE Finial Endbell Fit Size 2		
99.	DE Final Endbell Fit Size 3		
100.	DE Endbell Fit Insulated		
101.	DE Endbell Air Seal Fit		
102.	Initial Endbell Air Seal Fit Size		
103.	Finial Endbell Air Seal Fit Size		
104.	ODE Endbell Fit	(P) Pass	
105.	ODE Initial Endbell Fit Size 1	3.9375 "	
106.	ODE Initial Endbell Fit Size 2	3.9374 "	
107.	ODE Initial Endbell Fit Size 3	3.9371 "	
108.	ODE Final Endbell Fit Size 1		
109.	ODE Final Endbell Fit Size 2		
110.	ODE Final Endbell Fit Size 3		
111.	ODE Endbell Fit Insulated		
112.	ODE Endbell Air Seal Fit		
113.	ODE Initial Endbell Seal Fit Size		
114.	ODE Finial Endbell Seal Fit Size		
115.	Foot Flatness	(NA) Not Applicable	
116.	Foot Condition	(NA) Not Applicable	
117.	Flange Condition	(P) Pass	
118.	Service Technician	David Maclin	
	71		
Balanc	ing Report		
	ing Report Balance Type	nema	F

120. Balance Operating Speed

123. Balancing Specification

121. Start Left End122. Start Right End


124. Finish Left End

	125.	Finish Right End		
	126.	Service Technician		
Α	Assembly and Final Test			
	127.	Meggar Testing Reading Mohm		
	128.	Surge Test (P) Pass		
	129.	Hi-Pot		
	130.	Winding Resistance 1-2		
	131.	Winding Resistance 2-3		
	132.	Winding Resistance 1-3		
	133.	Test Run Voltage Phase A		
	134.	Test Run Amps A		
	135.	Test Run Voltage Phase B		
	136.	Test Run Amps B		
	137.	Test Run Voltage Phase C		
	138.	Test Run Amps C		
	139.	DE Horizontal Vibration Reading		
	140.	DE Vertical Vibration Reading		
	141.	DE Axial Vibration Reading		
	142.	ODE Horizontal Vibration Reading		
	143.	ODE Vertical Vibration Reading		
	144.	ODE Axial Vibration Reading		
	145.	Ambient Temp at start of Test Run		
	146.	Temp at 5 minutes		
	147.	Temp at 10 minutes		
	148.	Temp at 15 minutes		
	149.	Temp at 20 minutes		
	150.	Temp at 25 minutes		
	151.	Temp at 30 minutes		
	152.	Temp at 35 minutes		
	153.	Temp at 40 minutes		
	154.	Temp at 45 minutes		
	155.	Temp at 50 minutes		
	156.	Temp at 55 minutes		
	157.	Temp at 60 minutes		
	158.	Motor Paint (P) Pass	P136	













159. Service Technician

La Holland

Terrence Holland