

Job Information

Job #: 94425 Date: July 10, 2018

Priority: — Authorized OT: No Authorized by:

Customer Information

Name: FlakeBoard Motor#:

Name Plate Information

Manufacturer: Reliance Enclosure: Open Drop Proof Horsepower/kW: 100

(ODP)

Serial#: 2MA460269-G5-KC Model#: Service Factor: 1.15

Frame: 444TS Rated RPM: 1180 Rated Voltage: 460

Phase: 3 Rated Amps: 120 Cycles: 60

Special design: No

AC Electrical Inspection

Megs after rewind: Good Surge after rewind: Good Hi-pot after rewind: Good

Core loss: Good Thermistors: None Thermostat: None

RTD: None ohms at degrees C

Motor Heater(s) Present: Yes Qty: Voltage: Wattage:

Sollier



AC Electrical Inspection (Continued)

Core Test Data

Flux Watts Watts loss per lb Condition of iron

Before burnout

After burnout

Conclusion

Service Tech name: Robert Wiley

Service Tech signature:



Pol	V	ph	nas	е	Α	C	W	/i	n	d	ii	1	C
ΓUI	ועו	וע	เฉจ	C	H	C	V	7	Ш	u	ш		Ĺ

Hp/kw: 100 RPM:

1180

Poles:

6 Manufacturer:

Polyphase Date:

July 10, 2018

Reliance

Slots:

72

Type:

460 Volts:

Coils:

72

15

11

Model:

Amps:

120

3

18

Of 4

Serial#:

2MA460269-G5-KC

Phase:

Hertz:

Grouping

Of

17

Lead length:

Lead marking:

20

C Rise:

Frame:

Wire Size

Turns/Coil:

16

Lead size:

2

3

Duty:

Eff.:

C AMB:

Ins.Cls.:

Wire Mult.

2 1

Num.Leads: □ DP

COIL

TEFC

XPRF

TENV

S.F.:

Pitch 1 to: Connection:

3 Delta

Jumper:

14

5.125

Core length:

14

Back iron:

Core ID:

1.625

Slot depth:

1.1375

Slot/tooth w:

Wire weight:

78

Vents:

Size

Rotor bars:

Connection End

(Facing Terminal Box) ✓ Left

Right

Fax 901-873-5301



Single Phase				{		t Phas acitor:	Phase			Start & Run			un	Perm. Split				
Hp/kw:	100			RPM:	1	180			Manu	facture	er:	Reliar	nce					
		Run		Start			Type:							٧	olts:	460)	
No. Slots	 S					1	Model:								mps:	120)	
No. Poles	8						Style:							H	ertz:			
							Form:							Fra	ame:			
Coils/pole)																	
Dwg No							C Ris	e:			Hrs.:			Ca	ap. Mf	d.:		
Wire Size)					S	erial#:	2	MA460	0269-G	35-KC							
Wires in par							Dut	ty: -	_					☐ E	3B		SB	
No. Circuits	6						Ope	n: -	_									
Coil Ext						Sta.l	ength:						Sta	.b.i.:				
Stator Bore)																	
			l															
Running																		
Slot No	. 1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18
Starting	; 																	
Customer	: F	lakeBo	ard															

(Please return a copy to EASA Headquarters, 1331 Baur Blvd., St. Louis, MO 63132)



AC Stator Form Coil Data


- 1. Core bore diameter
- 2. Total core length
- 3. Back iron
- 4. No. of vents
- 5. Width of vents
- 6. Finger plate width
- 7. Overall coil length
- 8. Connnection end extension
- 9. Opposite Conn. End Ext.
- 10. Straight length bottom side
- 11. Straight length top side
- 12. Small knuckle drop. CE


OCE


13. Large knuckle drop. CE


OCE

- 14. Conn. Support Ring from core
- 15. Opp. Conn. Supp. Ring from core
- 16. Connection support ring ID
- 17. Opp. Conn. Supp. Ring ID
- 18. Total slot depth
- 19. Slot depth under wedge
- 20. Slot width











CENTRAL ARKANSAS



AC Stator Form Coil Data (Continued)

21. Lead location A B C D

23. Coil leads Long# LG

Short# LG

Out Down

24. Jumper —

25. Connection —

26. No. of circuits

27. No. of slots

28. Coil throw

29. Turns per coil

30. Total wires in parallel

31. Bare wire sizes () x

() x

32. Strand insulation


☐ Film ☐ Glass ☐ Mica ☐ Bare ☐ Other


33. Coil weight Lbs.


34. Groups of Coils

Groups of Coils

35. Iron skewed Right Left in











AC Stator Form Coil Data (Continued)

Special Features	Yes	No						
Data change								
Coil support ring steel								
Terrace wound								
Corona Protection								
RTDs								
Ohms Qty								
Hermetic								
Slot paper used								
Insulation class B B H								
☐ VPI ☐ Dip 8	& Bake	Sealed						
Leads taped	Leads s	leeved						
Comments								

