

Job Information

Job #:	95430				Date:	June 28, 2019	
Priority:	_	Authorized OT:	No	Authorized by:			
Custome	r Information						
Name:	Welspun			Motor#	:		

Name Plate Information

Manufacturer:	AJAY	Enclosure :	Open Drop Proof (ODP)	Horsepower/kW:	25
Serial#:	22255	Model#:		Service Factor:	
Frame:		Rated RPM:	3450	Rated Voltage:	480
Phase:	3	Rated Amps:	33	Cycles:	60

Special design: No

AC Electrical Inspection

Megs aft	er rewind:	Good	Surge afte	er rewind: Good	Hi-pot after rewind:	Good
Core loss:	Good		Thermistors:	None	Thermostat: None	
RTD:	None			ohms at	degrees C	
Motor Heat	er(s) Present:	Yes	Qty:	Voltage:	Wattage:	

VUEST TENNESSEE 7030 Ryburn Drive Millington, TN 38053 Phone 901-873-5300 Fax 901-873-5301



MILLINGTON, TN LITTLE ROCK, AR

AC Electrical Inspection (Continued)

Core Test Data

	Flux	Watts	Watts loss per lb	Condition of iron
Before burnout				
After burnout	84.737	0.587	1.977	253

Conclusion

Service Tech name: RHR

Service Tech signature:

MA A VIAn

WEST TENNESSEE 7030 Ryburn Drive

Millington, TN 38053 Phone 901-873-5300 Fax 901-873-5301

HI-SPEED


MILLINGTON, TN LITTLE ROCK, AR


Polyphase AC Winding

Polyph	ase A	C Winding				Polyphas	se Date:	June 28, 2019
Hp/kw:	25	RPM:	3450	Poles:		2 Manuf	acturer:	AJAY
Slots:		36	Type:				Volts:	480
Coils:		18	Model:				Amps:	33
	6	Of 3	Serial#:	22255			Phase:	3
Groupir	ng	Of	Lead marking:		1-2	-3-10-11-12	Hertz:	60
Turns/Coil:		16	Lead length:	1	C Rise:		Frame:	
Wire Size	17	19	Lead size:	14	Duty:		C AMB:	
Wire Mult.	2	3	Num.Leads:	6	Eff.:	I	Ins.Cls.:	
Pitch 1 to:		14		TEFC	XPRF	TENV	S.F.:	
Connection:		1Y1D	COIL					
Jumper:			-					
Core length:		8.875			14 - x-1		1	
Core ID:		5.25	\langle	T		I	\geq	
Back iron:		1.375				I		
Slot depth:		0.75		1				
Slot/tooth w:		0.250	4	►Ì		Ì	<>	
Wire weight:		24	🔽 Left		Connection cing Termin		Right	
Vents:		Size						
Rotor bars:								•Mechanical Authority

The Electro•Mechanical Authority

WEST TENNESSEE 7030 Ryburn Drive Millington, TN 38053 Phone 901-873-5300 Fax 901-873-5301





(Please return a copy to EASA Headquarters, 1331 Baur Blvd., St. Louis, MO 63132)

WEST TENNESSEE 7030 Ryburn Drive Millington, TN 38053 Phone 901-873-5300 Fax 901-873-5301



MILLINGTON, TN LITTLE ROCK, AR

AC Stator Form Coil Data

- 1. Core bore diameter
- 2. Total core length
- 3. Back iron
- 4. No. of vents
- 5. Width of vents
- 6. Finger plate width
- 7. Overall coil length
- 8. Connnection end extension
- 9. Opposite Conn. End Ext.
- 10. Straight length bottom side
- 11. Straight length top side
- 12. Small knuckle drop. CE
- 13. Large knuckle drop. CE
- 14. Conn. Support Ring from core
- 15. Opp. Conn. Supp. Ring from core
- 16. Connection support ring ID
- 17. Opp. Conn. Supp. Ring ID
- 18. Total slot depth
- 19. Slot depth under wedge
- 20. Slot width







WEST TENNESSEE 7030 Ryburn Drive Millington, TN 38053 Phone 901-873-5300 Fax 901-873-5301 CENTRAL ARKANSAS 6812 Lindsey Rd. Little Rock, AR 72206 Phone 501-375-9178 Fax 501-375-4254

OCE

OCE

MILLINGTON, TN LITTLE ROCK, AR

AC Stator For	m Coil Data (Co	ontinued)			-
21. Lead location	🗌 А 🗌 В 🗌] C 🗌 D			
22. Coil type	Left hand] Right hand	16	(1) (1)	
23. Coil leads	Long# LG		12 18	2	
	Short# LG				5
	Out	Down	1		
24. Jumper	_		13		23 4-(15->
25. Connection	-				OPPOSITE
26. No. of circuits			END	LEADS	CONNECTION
27. No. of slots			Left-Ha	and Coil 21 + 2	Right-Hand Coil
28. Coil throw	1-		Top	B	Тор
29. Turns per coil			A	\sim	
30. Total wires in para	allel			Bottom	Bottom
31. Bare wire sizes	() x	514		
	() x		19	
32. Strand insulation	Mica Bare	Other			
33. Coil weight	Lt	DS.			
34. Gr	oups of	Coils			EASA
Gr	oups of	Coils			The Electro•Mechanical Authority
35. Iron skewed	Right 🗌 Left	in			
WEST TENNES: 7030 Ryburn Drive Millington, TN 38053 Phone 901-873-5300 Fax 901-873-5301	CENTRAL ARKA 6812 Lindsey Rd. Little Rock, AR 72206 Phone 501-375-9178 Fax 501-375-4254	NSAS			

HI-SPEED



AC Stator Form Coil Data (Continued)



Comments





WEST TENNESSEE 7030 Ryburn Drive Millington, TN 38053 Phone 901-873-5300 Fax 901-873-5301