

Job Information

Job #: 96410 Date: February 28,

2020

Priority: — Authorized OT: No Authorized by:

Customer Information

Name: 3M Motor#:

Name Plate Information

Manufacturer: SIEMENS Enclosure: Open Drop Proof Horsepower/kW: 250

(ODP)

Serial#: J06T2010ES1 Model#: 1LA0449HE4N Service Factor: 1.15

Frame: B449T Rated RPM: 1185 Rated Voltage: 460

Phase: 3 Rated Amps: 280 Cycles: 60

Special design: No

AC Electrical Inspection

Megs after rewind: Good Surge after rewind: Good Hi-pot after rewind: Good

Core loss: Good Thermistors: None Thermostat: None

RTD: None ohms at degrees C

Motor Heater(s) Present: Yes Qty: Voltage: Wattage:



AC Electrical Inspection (Continued)

Core Test Data

	Flux	Watts	Watts loss per lb	Condition of iron
Before burnout	85.622	0.592	1.473	227
After burnout	85.098	0.765	2.382	286

Conclusion

Service Tech name: RHR

Service Tech signature:

(MA



Polyphase	AC W	inding
------------------	------	--------

Polyphase Date: February 28,

2020

Hp/kw: 250 RPM: 1185 Poles: 6 Manufacturer: SIEMENS

Slots: 72 Type: RGZESD Volts: 460

Coils: 72 Model: 1LA0449HE4N Amps: 280

18 Of 4 Serial#: J06T2010ES1 Phase: 3

Grouping

Lead marking: 1-1-2-2-3-3 Hertz: 60

Turns/Coil: 5 Lead length: 16 C Rise: Frame: B449T

Wire Size 16 17 Lead size: 2 Duty: CONT C AMB:

Wire Mult. 7 4 Num.Leads: 6 Eff.: Ins.Cls.: F

Pitch 1 to: 11 DP TEFC XPRF TENV S.F.: 1.15

Connection: 6Y

Core length: 23.625

Jumper:

Core ID: 12.125

Back iron: 1.0


Slot depth: 1.375

Slot/tooth w: 0.284

Wire weight: 198

Vents: Size

Rotor bars:







Single Phase				Split Phase															
				Capacitor: Start Start Start & Run						Perm. Split									
Hp/kw:	250			RPM:	1	185			Manu	facture	er:	SIEM	ENS						
		Run		Start	:		Type:							٧	olts:	46	60		
No. Slots						ľ	Model:		LA044	9HE4N	١				mps:	28	30		
No. Poles	5						Style: Form:								ertz: ame:				
Coils/pole)						FOIIII.							П	anie.				
Dwg No							C Ris	se:			Hrs.:			Ca	ap. Mi	fd.:			
Wire Size	Wire Size Serial#: J06T2010ES1																		
Wires in par				Duty: — BB SB															
No. Circuits	6			Open: —															
Coil Ext				Sta.length: Sta.b.i.:															
Stator Bore)																		
			1																
Running																			
Slot No	. 1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	5 10	3 17	7 -	18
Starting																			
Customer	: 3	BM																	

(Please return a copy to EASA Headquarters, 1331 Baur Blvd., St. Louis, MO 63132)



AC Stator Form Coil Data


- 1. Core bore diameter
- 2. Total core length
- 3. Back iron
- 4. No. of vents
- 5. Width of vents
- 6. Finger plate width
- 7. Overall coil length
- 8. Connnection end extension
- 9. Opposite Conn. End Ext.
- 10. Straight length bottom side
- 11. Straight length top side
- 12. Small knuckle drop. CE


OCE


13. Large knuckle drop. CE


OCE

- 14. Conn. Support Ring from core
- 15. Opp. Conn. Supp. Ring from core
- 16. Connection support ring ID
- 17. Opp. Conn. Supp. Ring ID
- 18. Total slot depth
- 19. Slot depth under wedge
- 20. Slot width











CENTRAL ARKANSAS



AC Stator Form Coil Data (Continued)

21. Lead location A B C D

23. Coil leads Long# LG

Short# LG

Out Down

24. Jumper —

25. Connection —

26. No. of circuits

27. No. of slots

28. Coil throw

29. Turns per coil

30. Total wires in parallel

31. Bare wire sizes () x

() x

32. Strand insulation


☐ Film ☐ Glass ☐ Mica ☐ Bare ☐ Other


33. Coil weight Lbs.


34. Groups of Coils

Groups of Coils

35. Iron skewed Right Left in











AC Stator Form Coil Data (Continued)

Special Features	Yes	No					
Data change							
Coil support ring steel							
Terrace wound							
Corona Protection							
RTDs							
Ohms Qty							
Hermetic							
Slot paper used							
Insulation class B B H							
☐ VPI ☐ Dip & Bake ☐ Sealed							
Leads taped Leads sleeved							
Comments							

