



## Infrared Thermography Report

Chemours NaCN September 23, 2020

All electrical panels were scanned using a  P60 infrared camera. The following report only contains defects that were found during the survey. Below is our classification system for each defect included in this report. If there are any questions or comments, please feel free to contact us at any time. The following pages reflect issues found during the survey.



employs a three-tier defect rating system:

**CLASS I:** A defect or defects are present that are likely to cause a problem in the long term (2-6 months). Should be addressed in the normal course of maintenance scheduling.

**CLASS II:** A defect or defects are present that are likely to cause a failure in the short term (less than 2 months). Should be addressed as soon as practical, on a high maintenance priority. Consideration should be given to increase monitoring frequency.

**CLASS III:** A defect or defects are present that make continued component reliability unpredictable and likelihood of secondary damage is high. Consideration should be given to an unscheduled shutdown to correct.




*tests and inspects industrial machinery and equipment and makes recommendations concerning maintenance and repairs based on its experience in the field of industrial repair and maintenance. The information contained herein is provided as an opinion only, not as a guaranty or warranty of the matters discussed herein.*

<b>Component</b>	North side cooling fins and transformer body
<b>Equipment/Bucket ID</b>	Sub 252-B




Sp1	92.8 °F
Sp2	101.7 °F
Li1 Minimum	81.2 °F
Li1 Maximum	100.0 °F
Areas	-



<b>Fault</b>	None
<b>Defect Rating</b>	NA

<b>Recommendations</b>	None
------------------------	------

<b>Component</b>	South side cooling fins and transformer body
<b>Equipment/Bucket ID</b>	Sub 252-B




Sp1	93.9 °F
Sp2	100.9 °F
Li1 Minimum	73.0 °F
Li1 Maximum	102.7 °F
Areas	-




<b>Fault</b>	Multiple non-functional cooling fins
<b>Defect Rating</b>	Class I

<b>Recommendations</b>	Check the coolant level and fins for plugging. Replace damaged fin section.
------------------------	---

<b>Component</b>	Left (East) door connections
<b>Equipment/Bucket ID</b>	Sub 252-B




Sp1	85.0 °F
Li1 Minimum	89.7 °F
Li1 Maximum	98.5 °F
Areas	-




<b>Fault</b>	None
<b>Defect Rating</b>	NA

<b>Recommendations</b>	None
------------------------	------

<b>Component</b>	Middle door connections
<b>Equipment/Bucket ID</b>	Sub 252-B




Sp1	84.4 °F
Li1 Minimum	79.5 °F
Li1 Maximum	84.2 °F
Areas	-




<b>Fault</b>	None
<b>Defect Rating</b>	NA

<b>Recommendations</b>	None
------------------------	------

<b>Component</b>	Right (West) door connections
<b>Equipment/Bucket ID</b>	Sub 252-B




Sp1	84.4 °F
Li1 Minimum	80.6 °F
Li1 Maximum	85.4 °F
Areas	-




<b>Fault</b>	None
<b>Defect Rating</b>	NA

<b>Recommendations</b>	None
------------------------	------

<b>Component</b>	North side cooling fins
<b>Equipment/Bucket ID</b>	Sub 231




Sp1	86.7 °F
Sp2	86.7 °F
Li1 Minimum	73.6 °F
Li1 Maximum	87.9 °F
Areas	-




<b>Fault</b>	None
<b>Defect Rating</b>	NA

<b>Recommendations</b>	None
------------------------	------

<b>Component</b>	Fuse clips
<b>Equipment/Bucket ID</b>	ECR MCC 1R 4 <sup>th</sup> floor vent fan South



Sp1	125.6 °F
Sp2	101.7 °F
Li1 Minimum	86.8 °F
Li1 Maximum	129.1 °F
Areas	-




<b>Fault</b>	Weak fuse clips
<b>Defect Rating</b>	Class I

**Recommendations**

Inspect the fuse block clips for tension and surface wear, as well as the fuses. Check for load balance. Replace worn components as time allows.

<b>Component</b>	Switch
<b>Equipment/Bucket ID</b>	ECR MCC 2F Recycle Scrubber Blower



Sp1	146.7 °F
Sp2	118.5 °F
Li1 Minimum	83.3 °F
Li1 Maximum	146.1 °F
Areas	-



<b>Fault</b>	Poor contact at switch
<b>Defect Rating</b>	Class I



**Recommendations**

Large temperature delta between fuse body and switch contact area leads us to believe the switch contacts are worn. Inspect the switch. Service or replace by years end.

<b>Component</b>	Switch
<b>Equipment/Bucket ID</b>	ECR MCC 4 HVAC RTU #1 North Side




Sp1	178.5 °F
Sp2	108.4 °F
Sp3	119.2 °F
Li1 Minimum	97.3 °F
Li1 Maximum	179.0 °F
Areas	-




<b>Fault</b>	Poor connection at switch contacts or lugs on C phase
<b>Defect Rating</b>	Class II

**Recommendations**  
 Excessive heat is being generated at the C phase contact or just adjacent to it in a lug connection. Inspect the switch for defects as well as adjacent components. Service or replace the switch at the next opportunity.

<b>Component</b>	Switch
<b>Equipment/Bucket ID</b>	ECR MCC 6 Vacuum Pump #2



Sp1	120.3 °F
Sp2	96.6 °F
Li1 Minimum	80.7 °F
Li1 Maximum	120.3 °F
Areas	-



<b>Fault</b>	Poor contact at switch A phase
<b>Defect Rating</b>	Class I

<b>Recommendations</b>	Small hot spot On the A phase of the switch indicates a poor connection there. Inspect the switch. Repair or replace. Check all adjacent connections. Perform as time allows.
------------------------	---

<b>Component</b>	Switch
<b>Equipment/Bucket ID</b>	ECR MCC 3 Dust and Fume Blower



Sp1	130.8 °F
Sp2	107.0 °F
Li1 Minimum	95.0 °F
Li1 Maximum	127.8 °F
Areas	-




<b>Fault</b>	Poor contact at switch C phase
<b>Defect Rating</b>	Class I

<b>Recommendations</b>	Hot spot On the C phase of the switch indicates a poor connection there. Inspect the switch and adjacent components. Repair or replace. Check all adjacent connections. Perform as time allows.
------------------------	---

<b>Component</b>	Fuse clip
<b>Equipment/Bucket ID</b>	ECR MCC 3 4 <sup>th</sup> Floor Exhaust Fan Middle



Sp1	130.0 °F
Sp2	105.1 °F
Li1 Minimum	86.4 °F
Li1 Maximum	130.1 °F
Areas	-



<b>Fault</b>	Weak fuse clip or loose lug connection
<b>Defect Rating</b>	Class I

**Recommendations**  
 Inspect the fuse block clips for tension and surface wear, as well as the fuses. Check for load balance. Replace worn components as time allows.

<b>Component</b>	Switch
<b>Equipment/Bucket ID</b>	ECR MCC7 Crystallizer Circulation Pump



Sp1	144.8 °F
Sp2	108.6 °F
Li1 Minimum	107.8 °F
Li1 Maximum	144.7 °F
Areas	-



<b>Fault</b>	Weak connection at switch
<b>Defect Rating</b>	Class I

<b>Recommendations</b>	Hot spot On the A phase of the switch indicates a poor connection there. Inspect the switch and adjacent components. Repair or replace. Check all adjacent connections. Perform as time allows.
------------------------	---

<b>Component</b>	Switch
<b>Equipment/Bucket ID</b>	ECR MCC 7 Filter Feed Pump



Sp1	127.9 °F
Sp2	108.4 °F
Li1 Minimum	92.9 °F
Li1 Maximum	127.9 °F
Areas	-





<b>Fault</b>	Poor connection at switch or adjacent lug
<b>Defect Rating</b>	Class I

<b>Recommendations</b>	Hot spot On the C phase of the switch indicates a poor connection there. Inspect the switch and adjacent components. Repair or replace. Check all adjacent connections. Perform as time allows.
------------------------	---

<b>Component</b>	Switch
<b>Equipment/Bucket ID</b>	Caustic Unloading Middle Caustic Transfer Pump




Sp1	140.1 °F
Sp2	117.5 °F
Li1 Minimum	91.0 °F
Li1 Maximum	140.1 °F
Areas	-





<b>Fault</b>	Poor connections at switch or adjacent lugs.
<b>Defect Rating</b>	Class I

<b>Recommendations</b>	Hot spot On the A phase of the switch indicates a poor connection there. Inspect the switch and adjacent components. B phase also shows some heat. Repair or replace. Check all adjacent connections. Perform as time allows.
------------------------	---

<b>Component</b>	Switch
<b>Equipment/Bucket ID</b>	Caustic Unloading East Caustic Pump



Sp1	136.5 °F
Sp2	102.7 °F
Li1 Minimum	80.4 °F
Li1 Maximum	135.4 °F
Areas	-




<b>Fault</b>	Poor switch contact
<b>Defect Rating</b>	Class I

<b>Recommendations</b>	Hot spot On the A phase of the switch indicates a poor connection there. Inspect the switch and adjacent components. Repair or replace. Check all adjacent connections. Perform as time allows.
------------------------	---

<b>Component</b>	Switch
<b>Equipment/Bucket ID</b>	Caustic Unloading West Caustic Pump



Sp1	137.6 °F
Sp2	108.7 °F
Li1 Minimum	87.7 °F
Li1 Maximum	138.8 °F
Areas	-



<b>Fault</b>	Poor connections at switch
<b>Defect Rating</b>	Class I

**Recommendations**  
 Hot spot On the B phase of the switch indicates a poor connection there. Inspect the switch and adjacent components. A phase also shows some heat. Repair or replace. Check all adjacent connections. Perform as time allows.

# Summary

Image Date&Time	Page number
8/19/2020 7:15:45 AM	3
8/19/2020 7:23:08 AM	4
9/18/2020 6:12:35 AM	3
9/18/2020 6:14:39 AM	4
9/18/2020 6:18:12 AM	5
9/18/2020 6:19:15 AM	6
9/18/2020 6:19:50 AM	7
9/18/2020 6:27:00 AM	8
9/18/2020 7:42:07 AM	9
9/23/2020 8:08:51 AM	10
9/18/2020 7:54:00 AM	11
9/23/2020 8:08:51 AM	12
9/18/2020 8:04:35 AM	13
9/18/2020 8:09:30 AM	14
9/18/2020 8:15:42 AM	15
9/18/2020 8:18:53 AM	16
9/18/2020 9:18:31 AM	17
9/18/2020 9:20:49 AM	18
9/18/2020 9:23:26 AM	19

This concludes our survey report. Please feel free to contact us at any time for question or comments.

Thank you for your business,

*David W. Shook*



ITC Certified Level I Infrared Thermographer

(901) 833-1101

[dshook@gohispeed.com](mailto:dshook@gohispeed.com)