

### **Job Information**

Job #: 140451 Date: September 6,

2019

Priority: — Authorized OT: No Authorized by:

#### **Customer Information**

Name: INSITUFORM Motor#:

### **Name Plate Information**

Manufacturer: Leroy Somer Enclosure : Open Drop Proof

(ODP)

Date

Serial#: Model#:

Service Factor: Frame:

Horsepower/kW: 42.7 kw Rated RPM: 2820

Armature Volts 400 Volts 190

Amps 119 Amps 1.98

# **Test Run Inspection**

I have merged this motor and verified that all electrical tests are complete!

**Power Supply** 

Phase A Phase B Phase C

No Load Voltage

No Load Current



## **Test Run Inspection (Continued)**

**Temperatures: (Degrees Fahrenheit)** 

Test run ball-bearing motors for 15 minutes.

Test run sleeve bearing motors for 60 minutes.

Temperature rise at the end of test run should be less than 2° every five minutes.

#### **Ambient Temp:**

Ambient Temp:					
	TIME	DE	Degree Change	ODE	Degree Change
	START:	78	0	78	0
	5 MIN:	80	2	80	2
	10 MIN:	81	1	81	1
	15 MIN:	82	1	82	1
	20 MIN:				
	25 MIN:				
	30 MIN:				
	35 MIN:				
	40 MIN:				
	45 MIN:				
	50 MIN:				
	55 MIN:				

7030 Ryburn Drive Millington, TN 38053 Phone 901-873-5300

Fax 901-873-5301

60 MIN:



## **Test Run Inspection (Continued)**

Vibration Data: In./Sec-Peak (Readings should be less than .08 In/Sec Peak)

Horizontal VDE Axial

DE 0.085 0.072 0.042

ODE 0.087 0.074 0.049

Magnetic Center Measurements (Only Applies to Sleeve Bearing Motors)

Magnetic Center line distance from shaft shoulder

Magnetic Center line distance from all the way out mark

Magnetic Center line distance from all the way in mark

Total Motor End Float

## **Additional photos**







Yes, the shaft has been isolated for delivery.

Service Tech name: Shawn

Service Tech signature:

Shill ship