



MILLINGTON, TN

LITTLE ROCK, AR

Job Information

Job #: 141700

Date: April 3, 2020

Priority: —

Authorized OT: No

Authorized by:

Customer Information

Name:

Motor#: 141700

Name Plate Information

Manufacturer: TOSHIBA

Enclosure : Open Drop Proof
(ODP)

Serial#: 8716470

Model#:

Service Factor:

Frame:

Horsepower/kW: 26/52

Rated RPM: 630/1260

Armature

Volts 460

Amps 10.0

Fields

Volts 230

Amps 5.4

Test Run Inspection

Date April 3, 2020

— I have merged this motor and verified that all electrical tests are complete!

Power Supply

Phase A

Phase B

Phase C

No Load Voltage

No Load Current

WEST TENNESSEE
7030 Ryburn Drive
Millington, TN 38053
Phone 901-873-5300
Fax 901-873-5301

CENTRAL ARKANSAS
6812 Lindsey Rd.
Little Rock, AR 72206
Phone 501-375-9178
Fax 501-375-4254



MILLINGTON, TN

LITTLE ROCK, AR

Test Run Inspection (Continued)

Temperatures: (Degrees Fahrenheit)

Test run ball-bearing motors for 15 minutes.

Test run sleeve bearing motors for 60 minutes.

Temperature rise at the end of test run should be less than 2° every five minutes.

Ambient Temp: 79

TIME	DE	Degree Change	ODE	Degree Change
START:	79	0	74	0
5 MIN:				
10 MIN:				
15 MIN:	80	1	75	1
20 MIN:				
25 MIN:				
30 MIN:	81	1	75	0
35 MIN:				
40 MIN:				
45 MIN:				
50 MIN:				
55 MIN:				
60 MIN:				

WEST TENNESSEE
7030 Ryburn Drive
Millington, TN 38053
Phone 901-873-5300
Fax 901-873-5301

CENTRAL ARKANSAS
6812 Lindsey Rd.
Little Rock, AR 72206
Phone 501-375-9178
Fax 501-375-4254

Test Run Inspection (Continued)

Vibration Data: In./Sec-Peak (Readings should be less than .08 In/Sec Peak)

	Horizontal	VDE	Axial
DE	0.022	0.028	0.033
ODE	0.019	0.025	0.032

Magnetic Center Measurements (Only Applies to Sleeve Bearing Motors)

Magnetic Center line distance from shaft shoulder

Magnetic Center line distance from all the way out mark

Magnetic Center line distance from all the way in mark

Total Motor End Float

Additional photos



☐ Yes, the shaft has been isolated for delivery.

Service Tech name: Jc

Service Tech signature:

