

### **Job Information**

Job #: 141872 Date: February 17,

2020

February 17, 2020

Date

Priority: — Authorized OT: No Authorized by: Terry f

#### **Customer Information**

Name: Motor#:

### **Name Plate Information**

Manufacturer: Reliance Enclosure: Open Drop Proof

(ODP)

Serial#: 1t6g305n-7 Model#:

Service Factor: Frame: 1610afc

Horsepower/kW: Rated RPM:

Armature Volts 180 Volts 200

Amps 7.4 Amps 96

# **Test Run Inspection**

I have merged this motor and verified that all electrical tests are complete!

**Power Supply** 

Phase A Phase B Phase C

No Load Voltage 179 7

No Load Current 0



## **Test Run Inspection (Continued)**

**Temperatures: (Degrees Fahrenheit)** 

Test run ball-bearing motors for 15 minutes.

Test run sleeve bearing motors for 60 minutes.

Temperature rise at the end of test run should be less than 2° every five minutes.

Ambient Temp:				
TIME	DE	Degree Change	ODE	Degree Change
START:				
5 MIN:				
10 MIN:				
15 MIN:				
20 MIN:				
25 MIN:				
30 MIN:				
35 MIN:				
40 MIN:				
45 MIN:				
50 MIN:				
55 MIN:				
60 MIN:				

Fax 901-873-5301



## **Test Run Inspection (Continued)**

Vibration Data: In./Sec-Peak (Readings should be less than .08 In/Sec Peak)

Horizontal VDE Axial

DE 0.033 0.032 0.019

ODE 0.032 0.043 0.020

Magnetic Center Measurements (Only Applies to Sleeve Bearing Motors)

Magnetic Center line distance from shaft shoulder

Magnetic Center line distance from all the way out mark

Magnetic Center line distance from all the way in mark

Total Motor End Float

### **Additional photos**







Yes, the shaft has been isolated for delivery.

Service Tech name: Terry f

Service Tech signature:

2