June 19, 2018

Date



Job Information

Job #: 94215 Date: June 19, 2018

Priority: — Authorized OT: No Authorized by:

Customer Information

Name: Bryce Motor#:

Name Plate Information

Manufacturer: Mawdsley's Enclosure: Open Drop Proof

(ODP)

Serial#: Model#:

Service Factor: Frame:

Horsepower/kW: 7.5kW Rated RPM: 2500

Armature Volts 480 Volts 360

Amps 18 Amps

Test Run Inspection

— I have merged this motor and verified that all electrical tests are complete!

Power Supply

Phase A Phase B Phase C

No Load Voltage

No Load Current



Test Run Inspection (Continued)

Temperatures: (Degrees Fahrenheit)

Test run ball-bearing motors for 15 minutes.

Test run sleeve bearing motors for 60 minutes.

Temperature rise at the end of test run should be less than 2° every five minutes.

Ambient Temp:				
TIME	DE	Degree Change	ODE	Degree Change
START:				
5 MIN:				
10 MIN:				
15 MIN:				
20 MIN:				
25 MIN:				
30 MIN:				
35 MIN:				
40 MIN:				
45 MIN:				
50 MIN:				
55 MIN:				
60 MIN:				

Fax 901-873-5301



Test Run Inspection (Continued)

Vibration Data: In./Sec-Peak (Readings should be less than .08 In/Sec Peak)

Horizontal VDE Axial

DE

ODE

Magnetic Center Measurements (Only Applies to Sleeve Bearing Motors)

Magnetic Center line distance from shaft shoulder

Magnetic Center line distance from all the way out mark

Magnetic Center line distance from all the way in mark

Total Motor End Float

Additional photos



Not Available Not Available

Yes, the shaft has been isolated for delivery.

Service Tech name: Lynn McDonald

Service Tech signature:

Lynn Mr Donald