

### **Job Information**

Job #: 139168 Date: February 20,

2019

Priority: — Authorized OT: No Authorized by:

#### **Customer Information**

Name: RAPAC Motor#: 003899

### **Name Plate Information**

Manufacturer: RELIANCE Enclosure: Open Drop Proof

(ODP)

Serial#: N/A Model#: 01KA515047-EE

Service Factor: N/A Frame: 2812ATZ

Horsepower/kW: 100 Rated RPM: 1750/2000

Armature Volts 500 Volts 300

Amps 167 Amps 3.122

# **Mechanical Inspection**

Inspect bolt holes and fasteners. Validate correct fasteners.

Bearings DE: Worn Bearings DE make: SKF

Insulated: No Bearing DE Size: 6313

Bearings ODE: Worn Bearings ODE make: SKF

Bearing Type: Ball Bearing ODE Size: 6211

Bearings Retainer: Yes Thermal Protection: Yes

Retainer condition: Good Thermal Protection Type: —



# **Mechanical Inspection (Continued)**

Seals DE type: Slinger Seals Image:

Seals DE size: 2.558 Not Available

Seals DE (inbound)

condition:

Seals ODE condition: Worn

Seals Image 2:

Seals ODE type: Slinger

Seals ODE size: 2.188 Available

Seals ODE (inbound)

condition:

Lubrication Type: Oil Thermal Protection device DE: —

Lubrication brand inbound: Mobile Polyrex EM Thermal Protection device ODE: —

Lubrication brand

outbound:

Mobile Polyrex EM

Grease Amt DE: Full Grease Cond. DE: New

Grease Amt ODE: Full Grease Cond. ODE: New

Seals DE condition: Worn



# **Mechanical Inspection (Continued)**

Brg. Seats DE: Undersized Shaft damage: Salvageable

If DE undersized, amt.: -.002 Shaft damage cause: Other

Brg. Seats ODE: Undersized Bushings/sleeves DE: Ok

If ODE undersized, amt.: -.002 Bushings/sleeves ODE: Ok

Endbell fits/damage: Good Endbell type: Single piece

Endbell DE size: 5.512 Endbell ODE size: 3.937

Endbell DE insulated?: No Endbell ODE insulated?: No

### Conclusion

Service Tech name: BILLY MAYS

Service Tech signature: