

## **Job Information**

Job #: 94532 July 31, 2018 Date:

Priority: Authorized OT: No Authorized by:

### **Customer Information**

Plastic Ingenuity Motor#: Name:

#### Name Plate Information

Manufacturer: Reliance Enclosure: Open Drop Proof

(ODP)

Serial#: Model#:

Service Factor: Frame: HC2113ATZ

Horsepower/kW: 25 Rated RPM: 1750/2300

Volts 500 Volts 300 Armature **Fields** 

> 1.36 **Amps** 46 **Amps**

# **Mechanical Inspection**

Inspect bolt holes and fasteners. Validate correct fasteners.

Bearings DE: Worn Bearings DE make: Koyo

Bearing DE Size: 6310ZZ Insulated: No

Bearings ODE: Bearings ODE make: Worn Koyo

Bearing Type: Ball Bearing ODE Size: 6209ZZ

Thermal Protection: Bearings Retainer: Yes No

CENTRAL ARKANSAS

Thermal Protection Type: Retainer condition: Good Thermocouple



# **Mechanical Inspection (Continued)**

Seals DE type: N/A Seals Image:

Seals DE size:

Not

Available

Seals DE (inbound)

condition:

Seals ODE condition: None

Seals Image 2:

Seals ODE type: N/A Not

Seals ODE size:

Available

Seals ODE (inbound)

condition:

Lubrication Type: Grease Thermal Protection device DE: —

Lubrication brand inbound: Mobile Polyrex EM Thermal Protection device ODE: —

Lubrication brand

outbound:

Mobile Polyrex EM

Grease Amt DE: Full Grease Cond. DE: New

Grease Amt ODE: Full Grease Cond. ODE: New

Seals DE condition: None



# **Mechanical Inspection (Continued)**

Brg. Seats DE: Good Shaft damage: OK

If DE undersized, amt.: Shaft damage cause: None

Brg. Seats ODE: Good Bushings/sleeves DE: Ok

If ODE undersized, amt.:

Bushings/sleeves ODE: Ok

Endbell fits/damage: Good Endbell type: Single piece

Lyns McDaule

Endbell DE size: Endbell ODE size:

Endbell DE insulated?: No Endbell ODE insulated?: No

## Conclusion

Service Tech name: Lynn McDonald

Service Tech signature: