


7030 Ryburn Drive Millington, TN 38053 Office: 901-873-5300 Fax: 901-873-5301 gohispeed.com



## **ICE** Industries

David W. Shook

ITC Certified Level I Infrared Thermographer dshook@gohispeed.com

Job Number	140286
Survey Date	7-31-19
Report Date	7-31-19



All electrical panels were scanned using a FLIR P60 infrared camera. The following report only contains defects that were found during the survey. Below is our classification system for each defect contained in this report. If there are any questions or comments, please feel free to contact us at any time.

Hi-Speed Industrial Service QualiTest Diagnostics employs a three-step defect rating system:

**CLASS I** - A defect or defects are present that are likely to cause a problem in the long term (2-6 months). Should be addressed in the normal course of maintenance scheduling; continue to monitor.

<u>CLASS II</u> - A defect or defects are present that are likely to cause a failure in the short term (less than 2 months). Should be addressed as soon as is practical, on a high maintenance priority. Consideration should be given to increased monitoring frequency.

**CLASS III** - A defect or defects are present that make continued component reliability unpredictable, and likelihood of secondary damage is high. Consideration should be given to an unscheduled shutdown to correct.

Hi-Speed Industrial Service tests and inspects industrial and equipment and makes recommendations concerning maintenance and repairs based on its experience in the field of industrial repair and maintenance. The information provided herein is provided as an opinion only, not as a guaranty or warranty of.







Component	Equipment/Bucket ID	Plant/Area	Date	
Starter Coil	left Panel	Versen Press	7-31-19	
LIO1	SP01. SP02.	132.5 °F - 130 - 120 - 120 - 120 - 120 - 120 - 120 - 100 - 100 - 100 - 100 - 100 - 101 : max Li01 : max Li01 : max - 120 - 90 - 84.0 °F		
		<pre></pre>	IR01	
Fault	Hot Coil			
Defect Rating	Class I			
Recommendation	-			
Replace the starter coil as time	allows.			







Component	Equipment/Bucket ID	Plant/Area	Date
Main Switch terminal	Volvo Heim Press	Back Building	7-31-19
LI01 SPU3 SP02		114.5°F Label IR : max IR : min F 105 F 105 F 100 F 95 F 90 88.0°F	87.2°F 116.5°F 110.0°F 101.3°F ax 116.9°F
		°F 115 110 105 105 100 100 100 100	IR01
Fault	Poor connection		

Fault	Poor connection
Defect Rating	Class I
Recommendation	

Localized heating at load side of "C" phase on main switch. Inspect the wire termination as well as the fuse clip. Repair or replace.







Component	Equipment/Bucket ID	Plant/Area	Date
Main switch "C" phase	Head Press 2	Back Building	7-31-19
LI01 SP01 SI	SP034	122.4°F - 120 - 110 - 5P01 - 5P02 - 5P03 - 100 - 5P02 - 5P03 - 100 - 5P03 - 5P05 - 5P05	
		9F 110 105 105 100 95 Line M li01 93.2	IR01
Fault	Poor connection at switch		

Fault	Poor connection at switch	
Defect Rating	Class I	
Decommendation		

Recommendation

Excessive heat found "C" phase line side fuse clip or possibly internal switch connection. Clean and inspect, repair or replace.







Component	Equipment/Bucket ID	Plant/Area		Date	
Left Panel	Paint Line	Back Building 7-3		7-31-19	
SP01 LI01	SP03	- 140 IR - 140 IR - 130 SP - 120 SP - 120 SP - 110 LIC	: max : min 201 202	Value 177.0°F 95.5°F 130.7°F 138.0°F 157.7°F 155.1°F 101.2°F	
<image/>	Poor connections	•F   150   140      130      120   110   Line   li01	     		
Defect Rating	Class II			_	
2010001100119					

## Recommendation

Bottom Left Fuse Blocks have multiple poor connections at the fuse clips and wire terminations. 2nd from left to the 5th have noteable issues. Clean and inspect, repair or replace.







Component	Equipment/Bucket ID	Plant/Area	Date	
Right Middle Fuse Blocks	Paint Line	Back Building	7-31-19	
SP01+	SP03	153.2 °F Label IR : max IR : min SP01 130 SP02 120 Li01 : mi 100 95.7 °F	96.7°F 129.1°F 102.7°F 110.3°F ax 144.0°F	
		°F 140 130 130 120 110 100 Line N 101 98.3	IR01	
Fault	Poor Connections at fuse bloc	cks		
Defect Rating	Class I			
Recommendation				

Paint Panel right middle fuse blocks. Inspect the 1st and 3rd fuse blocks. Clean and inspect. Repair or Replace.