

Motor Storage Inspection

Prepared for KTG USA (0003468)

400 Mahannah Ave.
Memphis TN 38107

Table of Contents

Motor Storage Inspection		1.0
Motor Storage Inspection		2.0
Motor Storage Inspection - A111	Motor Storage: <i>DIRECT DRIVE</i>	3.0
Motor Storage Inspection - A122	Motor Storage: <i>DIRECT CRIVE</i>	4.0
Motor Storage Inspection - A121	Motor Storage: <i>DIRECT DRIVE</i>	5.0
Motor Storage Inspection - A131	Motor Storage: <i>DIRECT DRIVE</i>	6.0
Motor Storage Inspection - A132	Motor Storage: <i>DIRECT CRIVE</i>	7.0
Motor Storage Inspection - A141	Motor Storage: <i>DIRECT DRIVE</i>	8.0
Motor Storage Inspection - A142	Motor Storage: <i>VERT. DIRECT DRIVE</i>	9.0
Motor Storage Inspection - A211	Motor Storage: <i>DIRECT DRIVE</i>	10.0
Motor Storage Inspection - A221	Motor Storage: <i>DIRECT DRIVE</i>	11.0
Motor Storage Inspection - A222	Motor Storage: <i>DIRECT DRIVE</i>	12.0
Motor Storage Inspection - A231	Motor Storage: <i>GEARBOX DIRECT DRIVE</i>	13.0
Motor Storage Inspection - A242	Motor Storage: <i>DIRECT DRIVE</i>	14.0
Motor Storage Inspection - A242a	Motor Storage: <i>DIRECT DRIVE</i>	15.0
Motor Storage Inspection - A311	Motor Storage: <i>DIRECT DRIVE</i>	16.0
Motor Storage Inspection - A312	Motor Storage: <i>DIRECT DRIVE</i>	17.0
Motor Storage Inspection - A321	Motor Storage: <i>DIRECT DRIVE</i>	18.0
Motor Storage Inspection - A322	Motor Storage: <i>DIRECT DRIVE</i>	19.0
Motor Storage Inspection - A331	Motor Storage: <i>DIRECT DRIVE</i>	20.0
Motor Storage Inspection - A332	Motor Storage: <i>DI4ECT DRIVE</i>	21.0
Motor Storage Inspection - A341	Motor Storage: <i>DIRECT DRIVE</i>	22.0
Motor Storage Inspection - A342	Motor Storage: <i>DIRECT DRIVE</i>	23.0
Motor Storage Inspection - B 331	Motor Storage: <i>DIRECT DRIVE</i>	24.0
Motor Storage Inspection - B111	Motor Storage: <i>DIRECT DRIVE</i>	25.0
Motor Storage Inspection - B112	Motor Storage: <i>DIRECT DRIVE</i>	26.0
Motor Storage Inspection - B121	Motor Storage: <i>DIRECT DRIVE</i>	27.0
Motor Storage Inspection - B122	Motor Storage: <i>DIRECT DRIVE</i>	28.0
Motor Storage Inspection - B131	Motor Storage: <i>DIRECT DRIVE</i>	29.0

Hi-Speed Industrial Service disclaims all warranties, both express and implied, relating to the information, reports, opinions and analysis disclosed to the Customer by Hi-Speed. Hi-Speed shall not be liable for any errors or omissions, or any losses, injury or damages arising from the use of such information, reports, opinions and analysis by the Customer.

Motor Storage Inspection - B132	Motor Storage: <i>DIRECT DRIVE</i>	30.0
Motor Storage Inspection - B141	Motor Storage: <i>A1609152038</i>	31.0
Motor Storage Inspection - B142	Motor Storage: <i>DIRECT DRIVE</i>	32.0
Motor Storage Inspection - B211	Motor Storage: <i>DC MOTOR</i>	33.0
Motor Storage Inspection - B212	Motor Storage: <i>DIRECT DRIVE</i>	34.0
Motor Storage Inspection - B221	Motor Storage: <i>DIRECT DRIVE</i>	35.0
Motor Storage Inspection - B231	Motor Storage: <i>DIRECT DRIVE</i>	36.0
Motor Storage Inspection - B232	Motor Storage: <i>DIRECT DRIVE</i>	37.0
Motor Storage Inspection - B241	Motor Storage: <i>DIRECT DRIVE</i>	38.0
Motor Storage Inspection - B311	Motor Storage: <i>DIRECT DRIVE</i>	39.0
Motor Storage Inspection - B312	Motor Storage: <i>DIRECT DRIVE</i>	40.0
Motor Storage Inspection - B321	Motor Storage: <i>DIRECT DRIVE</i>	41.0
Motor Storage Inspection - B322	Motor Storage: <i>DIRECT DRIVE</i>	42.0
Motor Storage Inspection - B341	Motor Storage: <i>DIRECT DRIVE</i>	43.0
Motor Storage Inspection - B342	Motor Storage: <i>DIRECT DRIVE</i>	44.0
Motor Storage Inspection - C111	Motor Storage: <i>DIRECT DRIVE</i>	45.0
Motor Storage Inspection - C112	Motor Storage: <i>DIRECT DRIVE</i>	46.0
Motor Storage Inspection - C122	Motor Storage: <i>DIRECT DRIVE</i>	47.0
Motor Storage Inspection - C211	Motor Storage: <i>DIRECT DRIVE</i>	48.0
Motor Storage Inspection - C211A	Motor Storage: <i>DIRECT DRIVE</i>	49.0
Motor Storage Inspection - C212	Motor Storage: <i>DIRECT DRIVE</i>	50.0
Motor Storage Inspection - C312	Motor Storage: <i>DIRECT DRIVE</i>	51.0
Motor Storage Inspection - D111	Motor Storage: <i>DIRECT DRIVE</i>	52.0
Motor Storage Inspection - D211	Motor Storage: <i>DIRECT DRIVE</i>	53.0
Motor Storage Inspection - <i>Default</i>	Motor Storage: <i>DIRECT DRIVE</i>	54.0
Motor Storage Inspection - E122a	Motor Storage: <i>DIRECT DRIVE</i>	55.0
Motor Storage Inspection - E122b	Motor Storage: <i>DIRECT DRIVE</i>	56.0
Motor Storage Inspection - <i>Floor A7</i>	Motor Storage: <i>DIRECT DRIVE</i>	57.0
Motor Storage Inspection - E112	Motor Storage: <i>DIRECT DRIVE</i>	58.0
Motor Storage Inspection - F111	Motor Storage: <i>DIRECT DRIVE</i>	59.0
Motor Storage Inspection - F112	Motor Storage: <i>DIRECT DRIVE</i>	60.0

Hi-Speed Industrial Service disclaims all warranties, both express and implied, relating to the information, reports, opinions and analysis disclosed to the Customer by Hi-Speed. Hi-Speed shall not be liable for any errors or omissions, or any losses, injury or damages arising from the use of such information, reports, opinions and analysis by the Customer.

Motor Storage Inspection - <i>F121</i>	Motor Storage: <i>DIRECT DRIVE</i>	61.0
Motor Storage Inspection - <i>F122</i>	Motor Storage: <i>DIRECT DRIVE</i>	62.0
Motor Storage Inspection - <i>Floor</i>	Motor Storage: <i>DIRECT DRIVE</i>	63.0
Motor Storage Inspection - <i>Floor2</i>	Motor Storage: <i>DIRECT DRIVE</i>	64.0
Motor Storage Inspection - <i>Floor3</i>	Motor Storage: <i>DIRECT DRIVE</i>	65.0
Motor Storage Inspection - <i>Floor4</i>	Motor Storage: <i>DIRECT DRIVE</i>	66.0
Motor Storage Inspection - <i>Floor5</i>	Motor Storage: <i>DIRECT DRIVE</i>	67.0
Motor Storage Inspection - <i>Floor6</i>	Motor Storage: <i>DIRECT DRIVE</i>	68.0
Motor Storage Inspection - <i>Floor7</i>	Motor Storage: <i>DIRECT DRIVE</i>	69.0
Motor Storage Inspection - <i>Floor8</i>	Motor Storage: <i>DIRECT DRIVE</i>	70.0
Motor Storage Inspection - <i>Floor9</i>	Motor Storage: <i>DIRECT DRIVE</i>	71.0
Motor Storage Inspection - <i>FloorA2</i>	Motor Storage: <i>DIRECT DRIVE</i>	72.0
Motor Storage Inspection - <i>FloorA3</i>	Motor Storage: <i>DIRECT DRIVE</i>	73.0
Motor Storage Inspection - <i>FloorA4</i>	Motor Storage: <i>DIRECT DRIVE</i>	74.0
Motor Storage Inspection - <i>FloorA5</i>	Motor Storage: <i>DIRECT DRIVE</i>	75.0
Motor Storage Inspection - <i>FloorA6</i>	Motor Storage: <i>DIRECT DRIVE</i>	76.0
Motor Storage Inspection - <i>FoorA1</i>	Motor Storage: <i>DIRECT DRIVE</i>	77.0
Motor Storage Inspection - <i>N.e. Floor</i>	Motor Storage: <i>DIRECT DRIVE</i>	78.0
Motor Storage Inspection - <i>Ne Floor</i>	Motor Storage: <i>DIRECT DRIVE</i>	79.0
Motor Storage Inspection - <i>Understairs</i>	Motor Storage: <i>DIRECT DRIVE</i>	80.0
Motor Storage Inspection - <i>West Floor</i>	Motor Storage: <i>DIRECT CRIVE</i>	81.0



Hi-Speed Industrial Service
7030 Ryburn Dr
Millington, Tn 38053
901-873-5300

Motor Storage Inspection

FolderID: 1016
FormID: 6354894

KTG USA (0003468)
400 Mahannah Ave.
Memphis, TN 38107

Priorities Found:

General
1. Inspection Date
2. Storage Location
Electrical Inspection
3. Meggar Reading
4. PI Check
Mechanical Inspection
5. Shaft Rotations
6. Bearing Condition
7. Bearing Grease
Inspection Complete
8. Signature

Hi-Speed Industrial Service disclaims all warranties, both express and implied, relating to the information, reports, opinions and analysis disclosed to the Customer by Hi-Speed. Hi-Speed shall not be liable for any errors or omissions, or any losses, injury or damages arising from the use of such information, reports, opinions and analysis by the Customer.

Printed on 09/05/2019

Powered by [INSPECTALL](#)

1.0



Hi-Speed Industrial Service
7030 Ryburn Dr
Millington, Tn 38053
901-873-5300

Motor Storage Inspection

FolderID: 1016
FormID: 6354895

KTG USA (0003468)
400 Mahannah Ave.
Memphis, TN 38107

Priorities Found:

General
1. Inspection Date
2. Storage Location
Electrical Inspection
3. Meggar Reading
4. PI Check
Mechanical Inspection
5. Shaft Rotations
6. Bearing Condition
7. Bearing Grease
Inspection Complete
8. Signature

Hi-Speed Industrial Service disclaims all warranties, both express and implied, relating to the information, reports, opinions and analysis disclosed to the Customer by Hi-Speed. Hi-Speed shall not be liable for any errors or omissions, or any losses, injury or damages arising from the use of such information, reports, opinions and analysis by the Customer.

Printed on 09/05/2019

Powered by [INSPECTALL](#)

2.0



Hi-Speed Industrial Service
7030 Ryburn Dr
Millington, Tn 38053
901-873-5300

Motor Storage Inspection

KTG USA (0003468)

400 Mahannah Ave.
Memphis, TN 38107

FolderID: 1016
FormID: 6354899



Motor Storage

Completed by: Erich Sodam on 09/03/2019

Location: A111

Serial Number: DIRECT DRIVE

Manufacturer: Allis Chalmers

HP / KW: 250

Phase: 3

HZ: 60

Amps: 265

RPM: 3575

Frame Size: 449TS

Voltage: 460

Enclosure: TEFC

Wire Leads : 6

Jbox Included: No

Driveshaft Coupling
Included: No

Date Received : 01/16/2019

Priorities Found: ● 4 - Good

General

- | | |
|---------------------|------------|
| 1. Inspection Date | 09/03/2019 |
| 2. Storage Location | a111 |

Electrical Inspection

- | | |
|--|----------|
| 3. Meggar Reading | inf |
| ● 4. PI Check | (P) Pass |

Mechanical Inspection

- | | |
|---|----------|
| ● 5. Shaft Rotations | 15 |
| ● 6. Bearing Condition | (P) Pass |
| ● 7. Bearing Grease | (P) Pass |

Inspection Complete

- | | |
|--------------|---------------|
| 8. Signature | Stone Hubbard |
|--------------|---------------|

Stone Hubbard



Hi-Speed Industrial Service
7030 Ryburn Dr
Millington, Tn 38053
901-873-5300

Motor Storage Inspection

KTG USA (0003468)

400 Mahannah Ave.
Memphis, TN 38107

FolderID: 1016
FormID: 6354897



Motor Storage

Completed by: Erich Sodam on 09/03/2019

Location: A122

Serial Number: DIRECT CRIVE

Manufacturer: Allis Chalmers

HP / KW: 125

Phase: 3

HZ: 60

Amps: 156

RPM: 1770

Frame Size: 445US

Voltage: 460

Enclosure: TEFC

Wire Leads : 6

Jbox Included: Yes

Driveshaft Coupling
Included: No

Date Received : 10/12/2017

Priorities Found: ● 4 - Good

General

- | | |
|---------------------|------------|
| 1. Inspection Date | 09/03/2019 |
| 2. Storage Location | a122 |

Electrical Inspection

- | | |
|--|----------|
| 3. Meggar Reading | inf |
| ● 4. PI Check | (P) Pass |

Mechanical Inspection

- | | |
|---|----------|
| ● 5. Shaft Rotations | 15 |
| ● 6. Bearing Condition | (P) Pass |
| ● 7. Bearing Grease | (P) Pass |

Inspection Complete

- | | |
|--------------|---------------|
| 8. Signature | Stone Hubbard |
|--------------|---------------|

Stone Hubbard



Hi-Speed Industrial Service
7030 Ryburn Dr
Millington, Tn 38053
901-873-5300

Motor Storage Inspection

KTG USA (0003468)

400 Mahannah Ave.
Memphis, TN 38107

FolderID: 1016
FormID: 6354896



Motor Storage

Completed by: Erich Sodam on 09/03/2019

Location: A121

Serial Number: DIRECT DRIVE

Manufacturer: Baldor

HP / KW: 350

Phase: 3

HZ: 60

Amps: 375

RPM: 3570

Frame Size: 449TS

Voltage: 460

Enclosure: TEFC

Wire Leads : 6

Jbox Included: No

Driveshaft Coupling
Included: No

Date Received : 10/12/2017

Priorities Found: ● 4 - Good

General

- | | |
|---------------------|------------|
| 1. Inspection Date | 09/03/2019 |
| 2. Storage Location | A121 |

Electrical Inspection

- | | |
|--|----------|
| 3. Meggar Reading | inf |
| ● 4. PI Check | (P) Pass |

Mechanical Inspection

- | | |
|---|----------|
| ● 5. Shaft Rotations | 15 |
| ● 6. Bearing Condition | (P) Pass |
| ● 7. Bearing Grease | (P) Pass |

Inspection Complete

- | | |
|--------------|--------|
| 8. Signature | B Mays |
|--------------|--------|



Hi-Speed Industrial Service
7030 Ryburn Dr
Millington, Tn 38053
901-873-5300

Motor Storage Inspection

KTG USA (0003468)

400 Mahannah Ave.
Memphis, TN 38107

FolderID: 1016
FormID: 6354913



Motor Storage

Completed by: Erich Sodam on 09/03/2019

Location: A131

Serial Number: DIRECT DRIVE

Manufacturer:

TECO Westinghouse

Priorities Found: ● 4 - Good

General

- | | |
|---------------------|------------|
| 1. Inspection Date | 09/03/2019 |
| 2. Storage Location | a131 |

Electrical Inspection

- | | |
|--|----------|
| 3. Meggar Reading | inf |
| ● 4. PI Check | (P) Pass |

Mechanical Inspection

- | | |
|---|----------|
| ● 5. Shaft Rotations | 15 |
| ● 6. Bearing Condition | (P) Pass |
| ● 7. Bearing Grease | (P) Pass |

Inspection Complete

- | | |
|--------------|---------------|
| 8. Signature | Stone Hubbard |
|--------------|---------------|

Stone Hubbard



Hi-Speed Industrial Service
7030 Ryburn Dr
Millington, Tn 38053
901-873-5300

Motor Storage Inspection

KTG USA (0003468)

400 Mahannah Ave.
Memphis, TN 38107

FolderID: 1016
FormID: 6354898



Motor Storage

Completed by: Erich Sodam on 09/03/2019

Location: A132

Serial Number: DIRECT CRIVE

Manufacturer: TECO Westinghouse

HP / KW: 125

Phase: 3

HZ: 60

Amps: 31

RPM: 1775

Frame Size: 445TS

Voltage: 2300

Enclosure: TEFC

Wire Leads : 3

Jbox Included: No

Driveshaft Coupling
Included: Yes

Date Received : 10/12/2017

Priorities Found: 4 - Good

General

- | | |
|---------------------|------------|
| 1. Inspection Date | 09/03/2019 |
| 2. Storage Location | A132 |

Electrical Inspection

- | | |
|-------------------|----------|
| 3. Meggar Reading | inf |
| 4. PI Check | (P) Pass |

Mechanical Inspection

- | | |
|----------------------|----------|
| 5. Shaft Rotations | 15 |
| 6. Bearing Condition | (P) Pass |
| 7. Bearing Grease | (P) Pass |

Inspection Complete

- | | |
|--------------|------------|
| 8. Signature | Billy Mays |
|--------------|------------|



Hi-Speed Industrial Service
7030 Ryburn Dr
Millington, Tn 38053
901-873-5300

Motor Storage Inspection

KTG USA (0003468)

400 Mahannah Ave.
Memphis, TN 38107

FolderID: 1016
FormID: 6354907



Motor Storage

Completed by: Erich Sodam on 09/03/2019

Location: A141

Serial Number: DIRECT DRIVE

Manufacturer:	GE
Product Number:	5KS365SS30801
HP / KW:	50
Phase:	3
HZ:	60
Amps:	58.2
RPM:	1185
Frame Size:	365T
Voltage:	460
Enclosure:	TEFC
Wire Leads :	3
Jbox Included:	No
Driveshaft Coupling Included:	No
Date Received :	10/12/2017

Priorities Found: ● 4 - Good

General

- | | |
|---------------------|------------|
| 1. Inspection Date | 09/03/2019 |
| 2. Storage Location | A141 |

Electrical Inspection

- | | |
|--|----------|
| 3. Meggar Reading | inf |
| ● 4. PI Check | (P) Pass |

Mechanical Inspection

- | | |
|---|----------|
| ● 5. Shaft Rotations | 15 |
| ● 6. Bearing Condition | (P) Pass |
| ● 7. Bearing Grease | (P) Pass |

Inspection Complete

- | | |
|--------------|------------|
| 8. Signature | Billy Mays |
|--------------|------------|



Hi-Speed Industrial Service
7030 Ryburn Dr
Millington, Tn 38053
901-873-5300

Motor Storage Inspection

KTG USA (0003468)

400 Mahannah Ave.
Memphis, TN 38107

FolderID: 1016
FormID: 6354908



Motor Storage

Completed by: Erich Sodam on 09/03/2019

Location: A142

Serial Number: VERT. DIRECT DRIVE

Manufacturer: Reliance

HP / KW: 100

Phase: 3

HZ: 60

Amps: 120

RPM: 1200

Frame Size: 405TC

Voltage: 460

Wire Leads : 3

Jbox Included: No

Driveshaft Coupling
Included: No

Date Received : 12/27/2018

Priorities Found: ● 4 - Good

General

- | | |
|---------------------|------------|
| 1. Inspection Date | 09/03/2019 |
| 2. Storage Location | a142 |

Electrical Inspection

- | | |
|-------------------|----------|
| 3. Meggar Reading | inf |
| ● 4. PI Check | (P) Pass |

Mechanical Inspection

- | | |
|------------------------|----------|
| ● 5. Shaft Rotations | 15 |
| ● 6. Bearing Condition | (P) Pass |
| ● 7. Bearing Grease | (P) Pass |

Inspection Complete

- | | |
|--------------|------------|
| 8. Signature | Billy Mays |
|--------------|------------|



Hi-Speed Industrial Service
7030 Ryburn Dr
Millington, Tn 38053
901-873-5300

Motor Storage Inspection

KTG USA (0003468)

400 Mahannah Ave.
Memphis, TN 38107

FolderID: 1016
FormID: 6354900



Motor Storage

Completed by: Erich Sodam on 09/03/2019

Location: A211

Serial Number: DIRECT DRIVE

Manufacturer:	ABB
HP / KW:	150
Phase:	3
HZ:	60
Amps:	238
RPM:	1785
Frame Size:	315SMB
Voltage:	460
Enclosure:	TEFC
Wire Leads :	6
Jbox Included:	Yes
Driveshaft Coupling Included:	No
Date Received :	10/12/2017

Priorities Found: ● 4 - Good

General

- | | |
|---------------------|------------|
| 1. Inspection Date | 09/03/2019 |
| 2. Storage Location | a211 |

Electrical Inspection

- | | |
|--|----------|
| 3. Meggar Reading | inf |
| ● 4. PI Check | (P) Pass |

Mechanical Inspection

- | | |
|---|----------|
| ● 5. Shaft Rotations | 15 |
| ● 6. Bearing Condition | (P) Pass |
| ● 7. Bearing Grease | (P) Pass |

Inspection Complete

- | | |
|--------------|---------------|
| 8. Signature | Stone Hubbard |
|--------------|---------------|

Stone Hubbard



Hi-Speed Industrial Service
7030 Ryburn Dr
Millington, Tn 38053
901-873-5300

Motor Storage Inspection

KTG USA (0003468)

400 Mahannah Ave.
Memphis, TN 38107

FolderID: 1016
FormID: 6354947



Motor Storage

Completed by: Erich Sodam on 09/03/2019

Location: A221

Serial Number: DIRECT DRIVE

Manufacturer: TECO Westinghouse

Product Number: 8028493

HP / KW: 150

Phase: 3

HZ: 60

RPM: 1186

Frame Size: 447T

Voltage: 460

Enclosure: TEFC

Wire Leads : 3

Jbox Included: Yes

Driveshaft Coupling
Included: Yes

Date Received : 10/12/2017

Priorities Found: ● 4 - Good

General

- | | |
|---------------------|------------|
| 1. Inspection Date | 09/03/2019 |
| 2. Storage Location | a221 |

Electrical Inspection

- | | |
|-------------------|----------|
| 3. Meggar Reading | inf |
| ● 4. PI Check | (P) Pass |

Mechanical Inspection

- | | |
|------------------------|----------|
| ● 5. Shaft Rotations | 15 |
| ● 6. Bearing Condition | (P) Pass |
| ● 7. Bearing Grease | (P) Pass |

Inspection Complete

- | | |
|--------------|---------------|
| 8. Signature | Stone Hubbard |
|--------------|---------------|

Stone Hubbard



Hi-Speed Industrial Service
7030 Ryburn Dr
Millington, Tn 38053
901-873-5300

Motor Storage Inspection

KTG USA (0003468)

400 Mahannah Ave.
Memphis, TN 38107

FolderID: 1016
FormID: 6354902



Motor Storage

Completed by: Erich Sodam on 09/03/2019

Location: A222

Serial Number: DIRECT DRIVE

Manufacturer:	GE
Product Number:	5KS444SS308A
HP / KW:	100
Phase:	3
HZ:	60
Amps:	110
RPM:	1190
Frame Size:	444T
Voltage:	460
Enclosure:	TEFC
Wire Leads :	3
Driveshaft Coupling Included:	No
Date Received :	10/12/2017

Priorities Found: ● 4 - Good

General

- | | |
|---------------------|------------|
| 1. Inspection Date | 09/03/2019 |
| 2. Storage Location | a222 |

Electrical Inspection

- | | |
|-------------------|----------|
| 3. Meggar Reading | inf |
| ● 4. PI Check | (P) Pass |

Mechanical Inspection

- | | |
|------------------------|----------|
| ● 5. Shaft Rotations | 15 |
| ● 6. Bearing Condition | (P) Pass |
| ● 7. Bearing Grease | (P) Pass |

Inspection Complete

- | | |
|--------------|---------------|
| 8. Signature | Stone Hubbard |
|--------------|---------------|

Stone Hubbard



Hi-Speed Industrial Service
7030 Ryburn Dr
Millington, Tn 38053
901-873-5300

Motor Storage Inspection

KTG USA (0003468)

400 Mahannah Ave.
Memphis, TN 38107

FolderID: 1016
FormID: 6354969



Motor Storage

Completed by: Erich Sodam on 09/03/2019

Location: A231

Serial Number: GEARBOX DIRECT DRIVE

Manufacturer:	SEW Eurodrive
Product Number:	HC3RLSFO3
HP / KW:	75
RPM:	IN 1750 OUT 85.1

Priorities Found: ● 4 - Good

General

1. Inspection Date	09/03/2019
2. Storage Location	A231

Electrical Inspection

3. Meggar Reading	n/A
● 4. PI Check	(P) Pass

Mechanical Inspection

● 5. Shaft Rotations	15
● 6. Bearing Condition	(P) Pass
● 7. Bearing Grease	(P) Pass

Inspection Complete

8. Signature	Billy Mays
--------------	------------



Hi-Speed Industrial Service
7030 Ryburn Dr
Millington, Tn 38053
901-873-5300

Motor Storage Inspection

KTG USA (0003468)

400 Mahannah Ave.
Memphis, TN 38107

FolderID: 1016
FormID: 6354909



Motor Storage

Completed by: Erich Sodam on 09/03/2019

Location: A242

Serial Number: DIRECT DRIVE

Manufacturer: Baldor

HP / KW: 450

Phase: 3

HZ: 60

Amps: 472

RPM: 3560

Frame Size: 449TS

Voltage: 460

Enclosure: ODP

Wire Leads : 12

Jbox Included: No

Driveshaft Coupling
Included: No

Date Received : 07/07/2019

Priorities Found: 4 - Good

General

- | | |
|---------------------|------------|
| 1. Inspection Date | 09/03/2019 |
| 2. Storage Location | A242 |

Electrical Inspection

- | | |
|-------------------|----------|
| 3. Meggar Reading | inf |
| 4. PI Check | (P) Pass |

Mechanical Inspection

- | | |
|----------------------|----------|
| 5. Shaft Rotations | 15 |
| 6. Bearing Condition | (P) Pass |
| 7. Bearing Grease | (P) Pass |

Inspection Complete

- | | |
|--------------|------------|
| 8. Signature | Billy Mays |
|--------------|------------|

Hi-Speed Industrial Service disclaims all warranties, both express and implied, relating to the information, reports, opinions and analysis disclosed to the Customer by Hi-Speed. Hi-Speed shall not be liable for any errors or omissions, or any losses, injury or damages arising from the use of such information, reports, opinions and analysis by the Customer.

Printed on 09/05/2019

Powered by [INSPECTALL](#)

14.0



Hi-Speed Industrial Service
7030 Ryburn Dr
Millington, Tn 38053
901-873-5300

Motor Storage Inspection

KTG USA (0003468)

400 Mahannah Ave.
Memphis, TN 38107

FolderID: 1016
FormID: 6354910



Motor Storage

Completed by: Erich Sodam on 09/03/2019

Location: A242a

Serial Number: DIRECT DRIVE

Manufacturer:	Reliance
HP / KW:	25
Phase:	3
HZ:	60
Amps:	59.4/29.7
RPM:	1770
Frame Size:	284T
Voltage:	230 / 460
Enclosure:	TEFC
Wire Leads :	9
Jbox Included:	Yes
Driveshaft Coupling Included:	No
Date Received :	08/06/2018

Priorities Found: 4 - Good

General

- | | |
|---------------------|------------|
| 1. Inspection Date | 09/03/2019 |
| 2. Storage Location | A242a |

Electrical Inspection

- | | |
|-------------------|----------|
| 3. Meggar Reading | inf |
| 4. PI Check | (P) Pass |

Mechanical Inspection

- | | |
|----------------------|----------|
| 5. Shaft Rotations | 15 |
| 6. Bearing Condition | (P) Pass |
| 7. Bearing Grease | (P) Pass |

Inspection Complete

- | | |
|--------------|------------|
| 8. Signature | Billy Mays |
|--------------|------------|

Hi-Speed Industrial Service disclaims all warranties, both express and implied, relating to the information, reports, opinions and analysis disclosed to the Customer by Hi-Speed. Hi-Speed shall not be liable for any errors or omissions, or any losses, injury or damages arising from the use of such information, reports, opinions and analysis by the Customer.

Printed on 09/05/2019

Powered by [INSPECTALL](#)

15.0



Hi-Speed Industrial Service
7030 Ryburn Dr
Millington, Tn 38053
901-873-5300

Motor Storage Inspection

KTG USA (0003468)

400 Mahannah Ave.
Memphis, TN 38107

FolderID: 1016
FormID: 6354905



Motor Storage

Completed by: Erich Sodam on 09/03/2019

Location: A311

Serial Number: DIRECT DRIVE

Manufacturer: Baldor

Product Number: P36G3365

HP / KW: 75

Phase: 3

HZ: 60

Amps: 85.9

RPM: 1780

Frame Size: 365T

Voltage: 460

Enclosure: TEFC

Wire Leads : 3

Jbox Included: Yes

Driveshaft Coupling
Included: No

Date Received : 10/12/2017

Priorities Found: ● 4 - Good

General

- | | |
|---------------------|------------|
| 1. Inspection Date | 09/03/2019 |
| 2. Storage Location | a311 |

Electrical Inspection

- | | |
|--|----------|
| 3. Meggar Reading | inf |
| ● 4. PI Check | (P) Pass |

Mechanical Inspection

- | | |
|---|----------|
| ● 5. Shaft Rotations | 15 |
| ● 6. Bearing Condition | (P) Pass |
| ● 7. Bearing Grease | (P) Pass |

Inspection Complete

- | | |
|--------------|---------------|
| 8. Signature | Stone Hubbard |
|--------------|---------------|

Stone Hubbard



Hi-Speed Industrial Service
7030 Ryburn Dr
Millington, Tn 38053
901-873-5300

Motor Storage Inspection

KTG USA (0003468)

400 Mahannah Ave.
Memphis, TN 38107

FolderID: 1016
FormID: 6354906



Motor Storage

Completed by: Erich Sodam on 09/03/2019

Location: A312

Serial Number: DIRECT DRIVE

Manufacturer: Reliance

HP / KW: 250

Phase: 3

HZ: 60

Amps: 60

RPM: 1175

Frame Size: 12CS6085S

Voltage: 2300

Enclosure: DP

Wire Leads : 3

Jbox Included: No

Driveshaft Coupling
Included: Yes

Date Received : 10/12/2017

Notes: SAP#8028689. HSIS INVENTORY
CCS000038

Priorities Found: ● 4 - Good

General

- | | |
|---------------------|------------|
| 1. Inspection Date | 09/03/2019 |
| 2. Storage Location | a312 |

Electrical Inspection

- | | |
|--|----------|
| 3. Meggar Reading | inf |
| ● 4. PI Check | (P) Pass |

Mechanical Inspection

- | | |
|---|----------|
| ● 5. Shaft Rotations | 15 |
| ● 6. Bearing Condition | (P) Pass |
| ● 7. Bearing Grease | (P) Pass |

Inspection Complete

- | | |
|--------------|---------------|
| 8. Signature | Stone Hubbard |
|--------------|---------------|

Stone Hubbard



Hi-Speed Industrial Service
7030 Ryburn Dr
Millington, Tn 38053
901-873-5300

Motor Storage Inspection

KTG USA (0003468)

400 Mahannah Ave.
Memphis, TN 38107

FolderID: 1016
FormID: 6354903



Motor Storage

Completed by: Erich Sodam on 09/03/2019

Location: A321

Serial Number: DIRECT DRIVE

Manufacturer:	ABB
Product Number:	RV23384-5
HP / KW:	132
Phase:	3
HZ:	60
Amps:	232
RPM:	1487
Frame Size:	315SMC
Voltage:	460
Enclosure:	TEFC
Wire Leads :	6
Jbox Included:	Yes
Driveshaft Coupling Included:	Yes
Date Received :	10/12/2017

Priorities Found: ● 4 - Good

General

- | | |
|---------------------|------------|
| 1. Inspection Date | 09/03/2019 |
| 2. Storage Location | a321 |

Electrical Inspection

- | | |
|--|----------|
| 3. Meggar Reading | inf |
| ● 4. PI Check | (P) Pass |

Mechanical Inspection

- | | |
|---|----------|
| ● 5. Shaft Rotations | 15 |
| ● 6. Bearing Condition | (P) Pass |
| ● 7. Bearing Grease | (P) Pass |

Inspection Complete

- | | |
|--------------|---------------|
| 8. Signature | Stone Hubbard |
|--------------|---------------|

Stone Hubbard



Hi-Speed Industrial Service
7030 Ryburn Dr
Millington, Tn 38053
901-873-5300

Motor Storage Inspection

KTG USA (0003468)

400 Mahannah Ave.
Memphis, TN 38107

FolderID: 1016
FormID: 6354904



Motor Storage

Completed by: Erich Sodam on 09/03/2019

Location: A322

Serial Number: DIRECT DRIVE

Manufacturer:	Reliance
Product Number:	P40G0240N
HP / KW:	100
Phase:	3
HZ:	60
Amps:	112
RPM:	1785
Frame Size:	445T
Voltage:	460
Enclosure:	TEFC
Wire Leads :	3
Jbox Included:	Yes
Driveshaft Coupling Included:	No
Date Received :	10/10/2017

Priorities Found: ● 4 - Good

General

1. Inspection Date	09/03/2019
2. Storage Location	a322

Electrical Inspection

3. Meggar Reading	inf
● 4. PI Check	(P) Pass

Mechanical Inspection

● 5. Shaft Rotations	15
● 6. Bearing Condition	(P) Pass
● 7. Bearing Grease	(P) Pass

Inspection Complete

8. Signature	Stone Hubbard
--------------	---------------

Stone Hubbard



Hi-Speed Industrial Service
7030 Ryburn Dr
Millington, Tn 38053
901-873-5300

Motor Storage Inspection

KTG USA (0003468)

400 Mahannah Ave.
Memphis, TN 38107

FolderID: 1016
FormID: 6354915



Motor Storage

Completed by: Erich Sodam on 09/03/2019

Location: A331

Serial Number: DIRECT DRIVE

Manufacturer: Elctrin

HP / KW: 25

Phase: 3

HZ: 60

Amps: 28/23.4

RPM: 1800

Frame Size: 284TC

Voltage: 480

Enclosure: TEFC

Wire Leads : 12

Driveshaft Coupling
Included: No

Date Received : 05/30/2018

Priorities Found: ● 4 - Good

General

- | | |
|---------------------|------------|
| 1. Inspection Date | 09/03/2019 |
| 2. Storage Location | A331 |

Electrical Inspection

- | | |
|-------------------|----------|
| 3. Meggar Reading | inf |
| ● 4. PI Check | (P) Pass |

Mechanical Inspection

- | | |
|------------------------|----------|
| ● 5. Shaft Rotations | 15 |
| ● 6. Bearing Condition | (P) Pass |
| ● 7. Bearing Grease | (P) Pass |

Inspection Complete

- | | |
|--------------|--------|
| 8. Signature | B Mays |
|--------------|--------|



Hi-Speed Industrial Service
7030 Ryburn Dr
Millington, Tn 38053
901-873-5300

Motor Storage Inspection

KTG USA (0003468)

400 Mahannah Ave.
Memphis, TN 38107

FolderID: 1016
FormID: 6354914



Motor Storage

Completed by: Erich Sodam on 09/03/2019

Location: A332

Serial Number: DI4ECT DRIVE

Manufacturer:	SEW Eurodrive
HP / KW:	30HP
Phase:	3
HZ:	60
Amps:	74.4/37.2
RPM:	1765
Frame Size:	NEMATODE IP55
Voltage:	460
Enclosure:	DP
Wire Leads :	3
Jbox Included:	Yes
Driveshaft Coupling Included:	Yes
Date Received :	05/30/2018

Priorities Found: ● 4 - Good

General

- | | |
|---------------------|------------|
| 1. Inspection Date | 09/03/2019 |
| 2. Storage Location | A332 |

Electrical Inspection

- | | |
|-------------------|----------|
| 3. Meggar Reading | inf |
| ● 4. PI Check | (P) Pass |

Mechanical Inspection

- | | |
|------------------------|----------|
| ● 5. Shaft Rotations | 15 |
| ● 6. Bearing Condition | (P) Pass |
| ● 7. Bearing Grease | (P) Pass |

Inspection Complete

- | | |
|--------------|--------|
| 8. Signature | B Mays |
|--------------|--------|



Hi-Speed Industrial Service
7030 Ryburn Dr
Millington, Tn 38053
901-873-5300

Motor Storage Inspection

KTG USA (0003468)

400 Mahannah Ave.
Memphis, TN 38107

FolderID: 1016
FormID: 6354911



Motor Storage

Completed by: Erich Sodam on 09/03/2019

Location: A341

Serial Number: DIRECT DRIVE

Manufacturer:	ABB
HP / KW:	75KW
Phase:	3
HZ:	60
Amps:	128
RPM:	1480
Frame Size:	UFOLI815
Voltage:	460
Enclosure:	TEFC
Wire Leads :	3
Jbox Included:	Yes
Driveshaft Coupling Included:	No
Date Received :	10/02/2018

Priorities Found: ● 4 - Good

General

- | | |
|---------------------|------------|
| 1. Inspection Date | 09/03/2019 |
| 2. Storage Location | a341 |

Electrical Inspection

- | | |
|-------------------|----------|
| 3. Meggar Reading | inf |
| ● 4. PI Check | (P) Pass |

Mechanical Inspection

- | | |
|------------------------|----------|
| ● 5. Shaft Rotations | 15 |
| ● 6. Bearing Condition | (P) Pass |
| ● 7. Bearing Grease | (P) Pass |

Inspection Complete

- | | |
|--------------|------------|
| 8. Signature | Billy Mays |
|--------------|------------|



Hi-Speed Industrial Service
7030 Ryburn Dr
Millington, Tn 38053
901-873-5300

Motor Storage Inspection

KTG USA (0003468)

400 Mahannah Ave.
Memphis, TN 38107

FolderID: 1016
FormID: 6354912



Motor Storage

Completed by: Erich Sodam on 09/03/2019

Location: A342

Serial Number: DIRECT DRIVE

Manufacturer: Allis Chalmers

HP / KW: 45KW

Phase: 3

HZ: 60

Amps: 74

RPM: 3560

Voltage: 480

Enclosure: TEFC

Wire Leads : 3

Jbox Included: Yes

Driveshaft Coupling
Included: Yes

Date Received : 05/03/2019

Priorities Found: ● 4 - Good

General

- | | |
|---------------------|------------|
| 1. Inspection Date | 09/03/2019 |
| 2. Storage Location | A342 |

Electrical Inspection

- | | |
|-------------------|----------|
| 3. Meggar Reading | inf |
| ● 4. PI Check | (P) Pass |

Mechanical Inspection

- | | |
|------------------------|----------|
| ● 5. Shaft Rotations | 15 |
| ● 6. Bearing Condition | (P) Pass |
| ● 7. Bearing Grease | (P) Pass |

Inspection Complete

- | | |
|--------------|------------|
| 8. Signature | Billy Mays |
|--------------|------------|



Hi-Speed Industrial Service
7030 Ryburn Dr
Millington, Tn 38053
901-873-5300

Motor Storage Inspection

KTG USA (0003468)

400 Mahannah Ave.
Memphis, TN 38107

FolderID: 1016
FormID: 6354962



Motor Storage

Completed by: Erich Sodam on 09/03/2019

Location: B 331

Serial Number: DIRECT DRIVE

Manufacturer: GE

Product Number: 5013484

HP / KW: 125

Phase: 3

HZ: 60

RPM: 1190

Frame Size: 445T

Voltage: 460

Enclosure: TEFC

Wire Leads : 3

Jbox Included: No

Driveshaft Coupling
Included: No

Date Received : 10/12/2017

Priorities Found: ● 4 - Good

General

- | | |
|---------------------|------------|
| 1. Inspection Date | 09/03/2019 |
| 2. Storage Location | b331 |

Electrical Inspection

- | | |
|--|----------|
| 3. Meggar Reading | inf |
| ● 4. PI Check | (P) Pass |

Mechanical Inspection

- | | |
|---|----------|
| ● 5. Shaft Rotations | 15 |
| ● 6. Bearing Condition | (P) Pass |
| ● 7. Bearing Grease | (P) Pass |

Inspection Complete

- | | |
|--------------|---------------|
| 8. Signature | Stone Hubbard |
|--------------|---------------|

Stone Hubbard



Hi-Speed Industrial Service
7030 Ryburn Dr
Millington, Tn 38053
901-873-5300

Motor Storage Inspection

KTG USA (0003468)

400 Mahannah Ave.
Memphis, TN 38107

FolderID: 1016
FormID: 6354937



Motor Storage

Completed by: Erich Sodam on 09/03/2019

Location: B111

Serial Number: DIRECT DRIVE

Manufacturer:	GE
Product Number:	5K509AN2520
HP / KW:	600
Phase:	3
HZ:	60
Amps:	135
RPM:	1780
Frame Size:	509Z
Voltage:	2300
Enclosure:	WPI
Wire Leads :	3
Jbox Included:	Yes
Driveshaft Coupling Included:	No
Date Received :	10/12/2017

Priorities Found: ● 4 - Good

General

- | | |
|---------------------|------------|
| 1. Inspection Date | 09/03/2019 |
| 2. Storage Location | b111 |

Electrical Inspection

- | | |
|--|----------|
| 3. Meggar Reading | inf |
| ● 4. PI Check | (P) Pass |

Mechanical Inspection

- | | |
|---|----------|
| ● 5. Shaft Rotations | 15 |
| ● 6. Bearing Condition | (P) Pass |
| ● 7. Bearing Grease | (P) Pass |

Inspection Complete

- | | |
|--------------|---------------|
| 8. Signature | Stone Hubbard |
|--------------|---------------|

Stone Hubbard

Hi-Speed Industrial Service disclaims all warranties, both express and implied, relating to the information, reports, opinions and analysis disclosed to the Customer by Hi-Speed. Hi-Speed shall not be liable for any errors or omissions, or any losses, injury or damages arising from the use of such information, reports, opinions and analysis by the Customer.



Hi-Speed Industrial Service
7030 Ryburn Dr
Millington, Tn 38053
901-873-5300

Motor Storage Inspection

KTG USA (0003468)

400 Mahannah Ave.
Memphis, TN 38107

FolderID: 1016
FormID: 6354936



Motor Storage

Completed by: Erich Sodam on 09/03/2019

Location: B112

Serial Number: DIRECT DRIVE

Manufacturer:	GE
Product Number:	5K1504FG9
HP / KW:	100
Phase:	3
HZ:	60
Amps:	241/120.5
RPM:	1770
Frame Size:	504U
Voltage:	230 / 460
Enclosure:	ODP
Wire Leads :	6
Jbox Included:	No
Driveshaft Coupling Included:	No
Date Received :	10/12/2017
Notes:	PART WINDING START

Priorities Found: ● 4 - Good

General

1. Inspection Date	09/03/2019
2. Storage Location	b112

Electrical Inspection

3. Meggar Reading	inf
● 4. PI Check	(P) Pass

Mechanical Inspection

● 5. Shaft Rotations	15
● 6. Bearing Condition	(P) Pass
● 7. Bearing Grease	(P) Pass

Inspection Complete

8. Signature	Stone Hubbard
--------------	---------------

Stone Hubbard



Hi-Speed Industrial Service
7030 Ryburn Dr
Millington, Tn 38053
901-873-5300

Motor Storage Inspection

KTG USA (0003468)

400 Mahannah Ave.
Memphis, TN 38107

FolderID: 1016
FormID: 6354939



Motor Storage

Completed by: Erich Sodam on 09/03/2019

Location: B121

Serial Number: DIRECT DRIVE

Manufacturer:	Siemens
Product Number:	2017439001-2
HP / KW:	30
Phase:	3
HZ:	60
Amps:	41
RPM:	1180
Frame Size:	364T
Voltage:	460
Enclosure:	TEFC
Wire Leads :	5
Jbox Included:	Yes
Driveshaft Coupling Included:	No
Date Received :	10/12/2017

Priorities Found: ● 4 - Good

General

- | | |
|---------------------|------------|
| 1. Inspection Date | 09/03/2019 |
| 2. Storage Location | b121 |

Electrical Inspection

- | | |
|--|----------|
| 3. Meggar Reading | inf |
| ● 4. PI Check | (P) Pass |

Mechanical Inspection

- | | |
|---|----------|
| ● 5. Shaft Rotations | 15 |
| ● 6. Bearing Condition | (P) Pass |
| ● 7. Bearing Grease | (P) Pass |

Inspection Complete

- | | |
|--------------|---------------|
| 8. Signature | Stone Hubbard |
|--------------|---------------|

Stone Hubbard



Hi-Speed Industrial Service
7030 Ryburn Dr
Millington, Tn 38053
901-873-5300

Motor Storage Inspection

KTG USA (0003468)

400 Mahannah Ave.
Memphis, TN 38107

FolderID: 1016
FormID: 6354934



Motor Storage

Completed by: Erich Sodam on 09/03/2019

Location: B122

Serial Number: DIRECT DRIVE

Manufacturer: GE

Product Number: 5K444SS426

HP / KW: 75

Phase: 3

HZ: 60

Amps: 87.8

RPM: 885

Frame Size: 444TS

Voltage: 460

Enclosure: TEFC

Wire Leads : 6

Jbox Included: No

Driveshaft Coupling
Included: Yes

Date Received : 10/12/2017

Priorities Found: ● 4 - Good

General

- | | |
|---------------------|------------|
| 1. Inspection Date | 09/03/2019 |
| 2. Storage Location | b122 |

Electrical Inspection

- | | |
|--|----------|
| 3. Meggar Reading | inf |
| ● 4. PI Check | (P) Pass |

Mechanical Inspection

- | | |
|---|----------|
| ● 5. Shaft Rotations | 15 |
| ● 6. Bearing Condition | (P) Pass |
| ● 7. Bearing Grease | (P) Pass |

Inspection Complete

- | | |
|--------------|---------------|
| 8. Signature | Stone Hubbard |
|--------------|---------------|

Stone Hubbard



Hi-Speed Industrial Service
7030 Ryburn Dr
Millington, Tn 38053
901-873-5300

Motor Storage Inspection

KTG USA (0003468)

400 Mahannah Ave.
Memphis, TN 38107

FolderID: 1016
FormID: 6354922



Motor Storage

Completed by: Erich Sodam on 09/03/2019

Location: B131

Serial Number: DIRECT DRIVE

Manufacturer: GE

HP / KW: 100

Phase: 3

HZ: 60

Amps: 40

Frame Size: 445T

Voltage: 460

Enclosure: TEFC

Priorities Found: ● 4 - Good

General

- | | |
|---------------------|------------|
| 1. Inspection Date | 09/03/2019 |
| 2. Storage Location | b131 |

Electrical Inspection

- | | |
|--|----------|
| 3. Meggar Reading | inf |
| ● 4. PI Check | (P) Pass |

Mechanical Inspection

- | | |
|---|----------|
| ● 5. Shaft Rotations | 15 |
| ● 6. Bearing Condition | (P) Pass |
| ● 7. Bearing Grease | (P) Pass |

Inspection Complete

- | | |
|--------------|---------------|
| 8. Signature | Stone Hubbard |
|--------------|---------------|

Stone Hubbard



Hi-Speed Industrial Service
7030 Ryburn Dr
Millington, Tn 38053
901-873-5300

Motor Storage Inspection

KTG USA (0003468)

400 Mahannah Ave.
Memphis, TN 38107

FolderID: 1016
FormID: 6354923



Motor Storage

Completed by: Erich Sodam on 09/03/2019

Location: B132

Serial Number: DIRECT DRIVE

Manufacturer: Baldor

HP / KW: 75

Phase: 3

HZ: 60

Amps: 95

RPM: 1180

Frame Size: 405T

Voltage: 460

Enclosure: TEFC

Wire Leads : 3

Jbox Included: Yes

Driveshaft Coupling
Included: No

Date Received : 04/25/2018

Priorities Found: ● 4 - Good

General

- | | |
|---------------------|------------|
| 1. Inspection Date | 09/03/2019 |
| 2. Storage Location | b132 |

Electrical Inspection

- | | |
|-------------------|----------|
| 3. Meggar Reading | inf |
| ● 4. PI Check | (P) Pass |

Mechanical Inspection

- | | |
|------------------------|----------|
| ● 5. Shaft Rotations | 15 |
| ● 6. Bearing Condition | (P) Pass |
| ● 7. Bearing Grease | (P) Pass |

Inspection Complete

- | | |
|--------------|---------------|
| 8. Signature | Stone Hubbard |
|--------------|---------------|

Stone Hubbard



Hi-Speed Industrial Service
7030 Ryburn Dr
Millington, Tn 38053
901-873-5300

Motor Storage Inspection

KTG USA (0003468)

400 Mahannah Ave.
Memphis, TN 38107

FolderID: 1016
FormID: 6354921



Motor Storage

Completed by: Erich Sodam on 09/03/2019

Location: B141

Serial Number: A1609152038

Manufacturer: Baldor

HP / KW: 75

Phase: 3

HZ: 60

RPM: 1780

Frame Size: 365T

Voltage: 460

Enclosure: TEFC

Priorities Found: ● 4 - Good

General

- | | |
|---------------------|------------|
| 1. Inspection Date | 09/03/2019 |
| 2. Storage Location | b141 |

Electrical Inspection

- | | |
|--|----------|
| 3. Meggar Reading | inf |
| ● 4. PI Check | (P) Pass |

Mechanical Inspection

- | | |
|---|----------|
| ● 5. Shaft Rotations | 15 |
| ● 6. Bearing Condition | (P) Pass |
| ● 7. Bearing Grease | (P) Pass |

Inspection Complete

- | | |
|--------------|---------------|
| 8. Signature | Stone Hubbard |
|--------------|---------------|

Stone Hubbard



Hi-Speed Industrial Service
7030 Ryburn Dr
Millington, Tn 38053
901-873-5300

Motor Storage Inspection

KTG USA (0003468)

400 Mahannah Ave.
Memphis, TN 38107

FolderID: 1016
FormID: 6354920



Motor Storage

Completed by: Erich Sodam on 09/03/2019

Location: B142

Serial Number: DIRECT DRIVE

Manufacturer: TECO Westinghouse

HP / KW: 40

Phase: 3

HZ: 60

Amps: 92.6

RPM: 1770

Frame Size: 324T

Voltage: 230 / 460

Enclosure: ODP

Wire Leads : 3

Jbox Included: Yes

Driveshaft Coupling
Included: No

Date Received : 08/06/2019

Priorities Found: 4 - Good

General

- | | |
|---------------------|------------|
| 1. Inspection Date | 09/03/2019 |
| 2. Storage Location | b142 |

Electrical Inspection

- | | |
|-------------------|----------|
| 3. Meggar Reading | inf |
| 4. PI Check | (P) Pass |

Mechanical Inspection

- | | |
|----------------------|----------|
| 5. Shaft Rotations | 15 |
| 6. Bearing Condition | (P) Pass |
| 7. Bearing Grease | (P) Pass |

Inspection Complete

- | | |
|--------------|------------|
| 8. Signature | Billy Mays |
|--------------|------------|



Hi-Speed Industrial Service
7030 Ryburn Dr
Millington, Tn 38053
901-873-5300

Motor Storage Inspection

KTG USA (0003468)

400 Mahannah Ave.
Memphis, TN 38107

FolderID: 1016
FormID: 6354932



Motor Storage

Completed by: Erich Sodam on 09/03/2019

Location: B211

Serial Number: DC MOTOR

Manufacturer: Reliance

Product Number: 01KAX0960-RR

HP / KW: 75

Amps: 119.5

RPM: 1750

Frame Size: LC3612ATZ

Voltage: 480

Enclosure: TEFC

Wire Leads : 4

Jbox Included: No

Driveshaft Coupling
Included: No

Date Received : 10/12/2017

Priorities Found: ● 4 - Good

General

- | | |
|---------------------|------------|
| 1. Inspection Date | 09/03/2019 |
| 2. Storage Location | b211 |

Electrical Inspection

- | | |
|-------------------|----------|
| 3. Meggar Reading | inf |
| ● 4. PI Check | (P) Pass |

Mechanical Inspection

- | | |
|------------------------|----------|
| ● 5. Shaft Rotations | 15 |
| ● 6. Bearing Condition | (P) Pass |
| ● 7. Bearing Grease | (P) Pass |

Inspection Complete

- | | |
|--------------|---------------|
| 8. Signature | Stone Hubbard |
|--------------|---------------|

Stone Hubbard



Hi-Speed Industrial Service
7030 Ryburn Dr
Millington, Tn 38053
901-873-5300

Motor Storage Inspection

KTG USA (0003468)

400 Mahannah Ave.
Memphis, TN 38107

FolderID: 1016
FormID: 6354928



Motor Storage

Completed by: Erich Sodam on 09/03/2019

Location: B212

Serial Number: DIRECT DRIVE

Manufacturer:	GE
Product Number:	5KS445S5118A
HP / KW:	150
Phase:	3
HZ:	60
Amps:	158
RPM:	3575
Frame Size:	445TS
Voltage:	460
Enclosure:	TEFC
Wire Leads :	6
Jbox Included:	No
Driveshaft Coupling Included:	No
Date Received :	10/12/2017

Priorities Found: ● 4 - Good

General

- | | |
|---------------------|------------|
| 1. Inspection Date | 09/03/2019 |
| 2. Storage Location | b212 |

Electrical Inspection

- | | |
|--|----------|
| 3. Meggar Reading | inf |
| ● 4. PI Check | (P) Pass |

Mechanical Inspection

- | | |
|---|----------|
| ● 5. Shaft Rotations | 15 |
| ● 6. Bearing Condition | (P) Pass |
| ● 7. Bearing Grease | (P) Pass |

Inspection Complete

- | | |
|--------------|---------------|
| 8. Signature | Stone Hubbard |
|--------------|---------------|

Stone Hubbard



Hi-Speed Industrial Service
7030 Ryburn Dr
Millington, Tn 38053
901-873-5300

Motor Storage Inspection

KTG USA (0003468)

400 Mahannah Ave.
Memphis, TN 38107

FolderID: 1016
FormID: 6354931



Motor Storage

Completed by: Erich Sodam on 09/03/2019

Location: B221

Serial Number: DIRECT DRIVE

Manufacturer:	Reliance
Product Number:	N0801160007
HP / KW:	250
Phase:	3
HZ:	60
Amps:	60
RPM:	1780
Frame Size:	449LL
Voltage:	2300
Enclosure:	TEFC
Wire Leads :	3
Jbox Included:	No
Driveshaft Coupling Included:	No
Date Received :	10/12/2017

Priorities Found: ● 4 - Good

General

- | | |
|---------------------|------------|
| 1. Inspection Date | 09/03/2019 |
| 2. Storage Location | b221 |

Electrical Inspection

- | | |
|-------------------|----------|
| 3. Meggar Reading | inf |
| ● 4. PI Check | (P) Pass |

Mechanical Inspection

- | | |
|------------------------|----------|
| ● 5. Shaft Rotations | 15 |
| ● 6. Bearing Condition | (P) Pass |
| ● 7. Bearing Grease | (P) Pass |

Inspection Complete

- | | |
|--------------|---------------|
| 8. Signature | Stone Hubbard |
|--------------|---------------|

Stone Hubbard



Hi-Speed Industrial Service
7030 Ryburn Dr
Millington, Tn 38053
901-873-5300

Motor Storage Inspection

KTG USA (0003468)

400 Mahannah Ave.

Memphis, TN 38107

FolderID: 1016

FormID: 6354924



Motor Storage

Completed by: Erich Sodam on 09/03/2019

Location: B231

Serial Number: DIRECT DRIVE

Manufacturer: TECO Westinghouse

Product Number: EPO504

HP / KW: 50

Phase: 3

HZ: 60

RPM: 1800

Frame Size: 326T

Voltage: 230 / 460

Enclosure: TEFC

Priorities Found: ● 4 - Good

General

- | | |
|---------------------|------------|
| 1. Inspection Date | 09/03/2019 |
| 2. Storage Location | b231 |

Electrical Inspection

- | | |
|--|----------|
| 3. Meggar Reading | inf |
| ● 4. PI Check | (P) Pass |

Mechanical Inspection

- | | |
|---|----------|
| ● 5. Shaft Rotations | 15 |
| ● 6. Bearing Condition | (P) Pass |
| ● 7. Bearing Grease | (P) Pass |

Inspection Complete

- | | |
|--------------|---------------|
| 8. Signature | Stone Hubbard |
|--------------|---------------|

Stone Hubbard



Hi-Speed Industrial Service
7030 Ryburn Dr
Millington, Tn 38053
901-873-5300

Motor Storage Inspection

KTG USA (0003468)

400 Mahannah Ave.
Memphis, TN 38107

FolderID: 1016
FormID: 6354918



Motor Storage

Completed by: Erich Sodam on 09/03/2019

Location: B232

Serial Number: DIRECT DRIVE

Manufacturer: TECO Westinghouse

Product Number: EPO506

HP / KW: 6

Phase: 3

HZ: 50

Amps: 116/57.8

RPM: 1180

Frame Size: 365T

Voltage: 230 / 460

Enclosure: TEFC

Wire Leads : 12

Jbox Included: Yes

Driveshaft Coupling
Included: No

Date Received : 08/06/2019

Priorities Found: ● 4 - Good

General

- | | |
|---------------------|------------|
| 1. Inspection Date | 09/03/2019 |
| 2. Storage Location | b232 |

Electrical Inspection

- | | |
|-------------------|----------|
| 3. Meggar Reading | inf |
| ● 4. PI Check | (P) Pass |

Mechanical Inspection

- | | |
|------------------------|----------|
| ● 5. Shaft Rotations | 15 |
| ● 6. Bearing Condition | (P) Pass |
| ● 7. Bearing Grease | (P) Pass |

Inspection Complete

- | | |
|--------------|---------------|
| 8. Signature | Stone Hubbard |
|--------------|---------------|

Stone
Hubbard



Hi-Speed Industrial Service
7030 Ryburn Dr
Millington, Tn 38053
901-873-5300

Motor Storage Inspection

KTG USA (0003468)

400 Mahannah Ave.
Memphis, TN 38107

FolderID: 1016
FormID: 6354919



Motor Storage

Completed by: Erich Sodam on 09/03/2019

Location: B241

Serial Number: DIRECT DRIVE

Manufacturer: TECO Westinghouse

HP / KW: 50/37

Phase: 3

HZ: 60

Amps: 56,9

RPM: 1770

Frame Size: 326T

Voltage: 460

Enclosure: TEFC

Wire Leads : 3

Jbox Included: Yes

Driveshaft Coupling
Included: No

Date Received : 04/25/2018

Priorities Found: ● 4 - Good

General

- | | |
|---------------------|------------|
| 1. Inspection Date | 09/03/2019 |
| 2. Storage Location | b241 |

Electrical Inspection

- | | |
|-------------------|----------|
| 3. Meggar Reading | inf |
| ● 4. PI Check | (P) Pass |

Mechanical Inspection

- | | |
|------------------------|----------|
| ● 5. Shaft Rotations | 15 |
| ● 6. Bearing Condition | (P) Pass |
| ● 7. Bearing Grease | (P) Pass |

Inspection Complete

- | | |
|--------------|---------------|
| 8. Signature | Stone Hubbard |
|--------------|---------------|

Stone Hubbard



Hi-Speed Industrial Service
7030 Ryburn Dr
Millington, Tn 38053
901-873-5300

Motor Storage Inspection

KTG USA (0003468)

400 Mahannah Ave.
Memphis, TN 38107

FolderID: 1016
FormID: 6354929



Motor Storage

Completed by: Erich Sodam on 09/03/2019

Location: B311

Serial Number: DIRECT DRIVE

Manufacturer: GE

Product Number: 2100Y1-LED

HP / KW: 150

RPM: 1150

Wire Leads : 0

Driveshaft Coupling
Included: No

Date Received : 10/12/2017

Priorities Found: ● 4 - Good

General

- | | |
|---------------------|------------|
| 1. Inspection Date | 09/03/2019 |
| 2. Storage Location | b311 |

Electrical Inspection

- | | |
|-------------------|----------|
| 3. Meggar Reading | inf |
| ● 4. PI Check | (P) Pass |

Mechanical Inspection

- | | |
|------------------------|----------|
| ● 5. Shaft Rotations | 15 |
| ● 6. Bearing Condition | (P) Pass |
| ● 7. Bearing Grease | (P) Pass |

Inspection Complete

- | | |
|--------------|---------------|
| 8. Signature | Stone Hubbard |
|--------------|---------------|

Stone
Hubbard



Hi-Speed Industrial Service
7030 Ryburn Dr
Millington, Tn 38053
901-873-5300

Motor Storage Inspection

KTG USA (0003468)

400 Mahannah Ave.
Memphis, TN 38107

FolderID: 1016
FormID: 6354925



Motor Storage

Completed by: Erich Sodam on 09/03/2019

Location: B312

Serial Number: DIRECT DRIVE

Manufacturer: ABB

Product Number: M3BP355SMC8B3

HP / KW: 308

Phase: 3

HZ: 60

Amps: 368

RPM: 893

Frame Size: 355SMC

Voltage: 480

Enclosure: TEFC

Wire Leads : 6

Jbox Included: Yes

Driveshaft Coupling
Included: No

Date Received : 10/12/2017

Priorities Found: ● 4 - Good

General

- | | |
|---------------------|------------|
| 1. Inspection Date | 09/03/2019 |
| 2. Storage Location | b312 |

Electrical Inspection

- | | |
|-------------------|----------|
| 3. Meggar Reading | inf |
| ● 4. PI Check | (P) Pass |

Mechanical Inspection

- | | |
|------------------------|----------|
| ● 5. Shaft Rotations | 15 |
| ● 6. Bearing Condition | (P) Pass |
| ● 7. Bearing Grease | (P) Pass |

Inspection Complete

- | | |
|--------------|---------------|
| 8. Signature | Stone Hubbard |
|--------------|---------------|

Stone Hubbard



Hi-Speed Industrial Service
7030 Ryburn Dr
Millington, Tn 38053
901-873-5300

Motor Storage Inspection

KTG USA (0003468)

400 Mahannah Ave.
Memphis, TN 38107

FolderID: 1016
FormID: 6354927



Motor Storage

Completed by: Erich Sodam on 09/03/2019

Location: B321

Serial Number: DIRECT DRIVE

Manufacturer: GE

HP / KW: 125

Phase: 3

HZ: 60

RPM: 1190

Frame Size: 445T

Voltage: 460

Enclosure: TEFC

Wire Leads : 6

Jbox Included: No

Driveshaft Coupling
Included: No

Date Received : 10/12/2017

Priorities Found: ● 4 - Good

General

- | | |
|---------------------|------------|
| 1. Inspection Date | 09/03/2019 |
| 2. Storage Location | b321 |

Electrical Inspection

- | | |
|--|----------|
| 3. Meggar Reading | inf |
| ● 4. PI Check | (P) Pass |

Mechanical Inspection

- | | |
|---|----------|
| ● 5. Shaft Rotations | 15 |
| ● 6. Bearing Condition | (P) Pass |
| ● 7. Bearing Grease | (P) Pass |

Inspection Complete

- | | |
|--------------|---------------|
| 8. Signature | Stone Hubbard |
|--------------|---------------|

Stone Hubbard



Hi-Speed Industrial Service
7030 Ryburn Dr
Millington, Tn 38053
901-873-5300

Motor Storage Inspection

KTG USA (0003468)

400 Mahannah Ave.
Memphis, TN 38107

FolderID: 1016
FormID: 6354926



Motor Storage

Completed by: Erich Sodam on 09/03/2019

Location: B322

Serial Number: DIRECT DRIVE

Manufacturer: TECO Westinghouse

HP / KW: 250

Phase: 3

HZ: 60

Amps: 60/35

RPM: 1775

Frame Size: 449T

Voltage: 2300 / 4160

Enclosure: DP

Wire Leads : 6

Jbox Included: No

Driveshaft Coupling
Included: No

Date Received : 10/12/2017

Priorities Found: ● 4 - Good

General

- | | |
|---------------------|------------|
| 1. Inspection Date | 09/03/2019 |
| 2. Storage Location | b322 |

Electrical Inspection

- | | |
|--|----------|
| 3. Meggar Reading | inf |
| ● 4. PI Check | (P) Pass |

Mechanical Inspection

- | | |
|---|----------|
| ● 5. Shaft Rotations | 15 |
| ● 6. Bearing Condition | (P) Pass |
| ● 7. Bearing Grease | (P) Pass |

Inspection Complete

- | | |
|--------------|---------------|
| 8. Signature | Stone Hubbard |
|--------------|---------------|

Stone
Hubbard



Hi-Speed Industrial Service
7030 Ryburn Dr
Millington, Tn 38053
901-873-5300

Motor Storage Inspection

KTG USA (0003468)

400 Mahannah Ave.
Memphis, TN 38107

FolderID: 1016
FormID: 6354917



Motor Storage

Completed by: Erich Sodam on 09/03/2019

Location: B341

Serial Number: DIRECT DRIVE

Manufacturer: Baldor

HP / KW: 75

Phase: 3

HZ: 60

RPM: 1780

Frame Size: 365T

Voltage: 460

Enclosure: TEFC

Date Received : 06/17/2017

Priorities Found: ● 4 - Good

General

- | | |
|---------------------|------------|
| 1. Inspection Date | 09/03/2019 |
| 2. Storage Location | b341 |

Electrical Inspection

- | | |
|--|----------|
| 3. Meggar Reading | inf |
| ● 4. PI Check | (P) Pass |

Mechanical Inspection

- | | |
|---|----------|
| ● 5. Shaft Rotations | 15 |
| ● 6. Bearing Condition | (P) Pass |
| ● 7. Bearing Grease | (P) Pass |

Inspection Complete

- | | |
|--------------|---------------|
| 8. Signature | Stone Hubbard |
|--------------|---------------|

Stone Hubbard



Hi-Speed Industrial Service
7030 Ryburn Dr
Millington, Tn 38053
901-873-5300

Motor Storage Inspection

KTG USA (0003468)

400 Mahannah Ave.

Memphis, TN 38107

FolderID: 1016

FormID: 6354916



Motor Storage

Completed by: Erich Sodam on 09/03/2019

Location: B342

Serial Number: DIRECT DRIVE

Manufacturer: Baldor

HP / KW: 60

Phase: 3

HZ: 60

RPM: 1780

Frame Size: 364T

Voltage: 460

Enclosure: TEFC

Date Received : 06/18/2019

Priorities Found: ● 4 - Good

General

1. Inspection Date 09/03/2019

2. Storage Location b342

Electrical Inspection

3. Meggar Reading inf

● 4. PI Check (P) Pass

Mechanical Inspection

● 5. Shaft Rotations 15

● 6. Bearing Condition (P) Pass

● 7. Bearing Grease (P) Pass

Inspection Complete

8. Signature Stone Hubbard



Hi-Speed Industrial Service
7030 Ryburn Dr
Millington, Tn 38053
901-873-5300

Motor Storage Inspection

KTG USA (0003468)

400 Mahannah Ave.
Memphis, TN 38107

FolderID: 1016
FormID: 6354952



Motor Storage

Completed by: Erich Sodam on 09/03/2019

Location: C111

Serial Number: DIRECT DRIVE

Manufacturer: Allis Chalmers

Product Number: 8028553

HP / KW: 100

Phase: 3

HZ: 60

Amps: 115

RPM: 1770

Frame Size: 405T

Voltage: 460

Enclosure: TEFC

Wire Leads : 3

Jbox Included: Yes

Driveshaft Coupling
Included: No

Date Received : 10/12/2017

Priorities Found: ● 4 - Good

General

- | | |
|---------------------|------------|
| 1. Inspection Date | 09/03/2019 |
| 2. Storage Location | c111 |

Electrical Inspection

- | | |
|--|----------|
| 3. Meggar Reading | inf |
| ● 4. PI Check | (P) Pass |

Mechanical Inspection

- | | |
|---|----------|
| ● 5. Shaft Rotations | 15 |
| ● 6. Bearing Condition | (P) Pass |
| ● 7. Bearing Grease | (P) Pass |

Inspection Complete

- | | |
|--------------|---------------|
| 8. Signature | Stone Hubbard |
|--------------|---------------|

Stone Hubbard

Hi-Speed Industrial Service disclaims all warranties, both express and implied, relating to the information, reports, opinions and analysis disclosed to the Customer by Hi-Speed. Hi-Speed shall not be liable for any errors or omissions, or any losses, injury or damages arising from the use of such information, reports, opinions and analysis by the Customer.

Printed on 09/05/2019

Powered by [INSPECTALL](#)

45.0



Hi-Speed Industrial Service
7030 Ryburn Dr
Millington, Tn 38053
901-873-5300

Motor Storage Inspection

KTG USA (0003468)

400 Mahannah Ave.
Memphis, TN 38107

FolderID: 1016
FormID: 6354954



Motor Storage

Completed by: Erich Sodam on 09/03/2019

Location: C112

Serial Number: DIRECT DRIVE

Manufacturer: GE

Product Number: 5013463

HP / KW: 150

Phase: 3

HZ: 60

RPM: 1800

Frame Size: 445T

Voltage: 460

Enclosure: TEFC

Wire Leads : 6

Jbox Included: Yes

Driveshaft Coupling
Included: No

Date Received : 10/12/2017

Priorities Found: ● 4 - Good

General

- | | |
|---------------------|------------|
| 1. Inspection Date | 09/03/2019 |
| 2. Storage Location | c112 |

Electrical Inspection

- | | |
|--|----------|
| 3. Meggar Reading | inf |
| ● 4. PI Check | (P) Pass |

Mechanical Inspection

- | | |
|---|----------|
| ● 5. Shaft Rotations | 15 |
| ● 6. Bearing Condition | (P) Pass |
| ● 7. Bearing Grease | (P) Pass |

Inspection Complete

- | | |
|--------------|---------------|
| 8. Signature | Stone Hubbard |
|--------------|---------------|



Hi-Speed Industrial Service
7030 Ryburn Dr
Millington, Tn 38053
901-873-5300

Motor Storage Inspection

KTG USA (0003468)

400 Mahannah Ave.
Memphis, TN 38107

FolderID: 1016
FormID: 6354972



Motor Storage

Completed by: Erich Sodam on 09/03/2019

Location: C122

Serial Number: DIRECT DRIVE

Manufacturer: US Motors

Product Number: 7046-00-654

HP / KW: 150

Phase: 3

HZ: 60

Amps: 170

RPM: 3600

Frame Size: 445TS

Voltage: 460


Enclosure: TEFC

Wire Leads : 3

Jbox Included: Yes

Driveshaft Coupling
Included: No

Date Received : 10/12/2017

Priorities Found:  4 - Good




General

- | | |
|---------------------|------------|
| 1. Inspection Date | 09/03/2019 |
| 2. Storage Location | c22 |

Electrical Inspection

- | | |
|---|----------|
| 3. Meggar Reading | inf |
|  4. PI Check | (P) Pass |

Mechanical Inspection

- | | |
|--|----------|
|  5. Shaft Rotations | 15 |
|  6. Bearing Condition | (P) Pass |
|  7. Bearing Grease | (P) Pass |

Inspection Complete

- | | |
|--------------|---------------|
| 8. Signature | Stone Hubbard |
|--------------|---------------|



Hi-Speed Industrial Service
7030 Ryburn Dr
Millington, Tn 38053
901-873-5300

Motor Storage Inspection

KTG USA (0003468)

400 Mahannah Ave.
Memphis, TN 38107

FolderID: 1016
FormID: 6354958



Motor Storage

Completed by: Erich Sodam on 09/03/2019

Location: C211

Serial Number: DIRECT DRIVE

Manufacturer:	ABB
Product Number:	8028604
HP / KW:	115
Phase:	3
HZ:	60
Amps:	138
RPM:	1189
Frame Size:	280MSC
Voltage:	480
Enclosure:	TEFC
Wire Leads :	6
Jbox Included:	Yes
Driveshaft Coupling Included:	No
Date Received :	10/12/2017

Priorities Found: ● 4 - Good

General

1. Inspection Date	09/03/2019
2. Storage Location	c211

Electrical Inspection

3. Meggar Reading	inf
● 4. PI Check	(P) Pass

Mechanical Inspection

● 5. Shaft Rotations	15
● 6. Bearing Condition	(P) Pass
● 7. Bearing Grease	(P) Pass

Inspection Complete

8. Signature	Stone Hubbard
--------------	---------------



Hi-Speed Industrial Service
7030 Ryburn Dr
Millington, Tn 38053
901-873-5300

Motor Storage Inspection

KTG USA (0003468)

400 Mahannah Ave.

Memphis, TN 38107

FolderID: 1016

FormID: 6354949



Motor Storage

Completed by: Erich Sodam on 09/03/2019

Location: C211A

Serial Number: DIRECT DRIVE

Manufacturer: ABB

Product Number: 0626010651735

HP / KW: 74

Phase: 3

HZ: 60

Amps: 91

RPM: 891

Frame Size: IP55

Voltage: 480

Enclosure: TEFC

Wire Leads : 6

Jbox Included: Yes

Driveshaft Coupling
Included: No

Date Received : 10/12/2017

Priorities Found: 4 - Good

General

- | | |
|---------------------|------------|
| 1. Inspection Date | 09/03/2019 |
| 2. Storage Location | c211a |

Electrical Inspection

- | | |
|-------------------|----------|
| 3. Meggar Reading | inf |
| 4. PI Check | (P) Pass |

Mechanical Inspection

- | | |
|----------------------|----------|
| 5. Shaft Rotations | 15 |
| 6. Bearing Condition | (P) Pass |
| 7. Bearing Grease | (P) Pass |

Inspection Complete

- | | |
|--------------|---------------|
| 8. Signature | Stone Hubbard |
|--------------|---------------|



Hi-Speed Industrial Service
7030 Ryburn Dr
Millington, Tn 38053
901-873-5300

Motor Storage Inspection

KTG USA (0003468)

400 Mahannah Ave.
Memphis, TN 38107

FolderID: 1016
FormID: 6354956



Motor Storage

Completed by: Erich Sodam on 09/03/2019

Location: C212

Serial Number: DIRECT DRIVE

Manufacturer: ABB

Product Number: M3BP315SMC6B3

HP / KW: 125

Phase: 3

HZ: 60

RPM: 1192

Frame Size: 315SMC

Voltage: 480

Enclosure: TEFC

Wire Leads : 6

Jbox Included: Yes

Driveshaft Coupling
Included: No

Date Received : 10/12/2017

Priorities Found: ● 4 - Good

General

- | | |
|---------------------|------------|
| 1. Inspection Date | 09/03/2019 |
| 2. Storage Location | c212 |

Electrical Inspection

- | | |
|--|----------|
| 3. Meggar Reading | inf |
| ● 4. PI Check | (P) Pass |

Mechanical Inspection

- | | |
|---|----------|
| ● 5. Shaft Rotations | 15 |
| ● 6. Bearing Condition | (P) Pass |
| ● 7. Bearing Grease | (P) Pass |

Inspection Complete

- | | |
|--------------|---------------|
| 8. Signature | Stone Hubbard |
|--------------|---------------|



Hi-Speed Industrial Service
7030 Ryburn Dr
Millington, Tn 38053
901-873-5300

Motor Storage Inspection

KTG USA (0003468)

400 Mahannah Ave.
Memphis, TN 38107

FolderID: 1016
FormID: 6354961



Motor Storage

Completed by: Erich Sodam on 09/03/2019

Location: C312

Serial Number: DIRECT DRIVE

Manufacturer: ABB

Product Number: M3BP315MSC6B3

HP / KW: 246

Phase: 3

HZ: 60

Amps: 191

RPM: 1194

Frame Size: 315SMC

Voltage: 480

Enclosure: TEFC

Wire Leads : 6

Jbox Included: Yes

Driveshaft Coupling
Included: No

Date Received : 10/12/2017

Priorities Found: ● 4 - Good

General

- | | |
|---------------------|------------|
| 1. Inspection Date | 09/03/2019 |
| 2. Storage Location | c312 |

Electrical Inspection

- | | |
|--|----------|
| 3. Meggar Reading | inf |
| ● 4. PI Check | (P) Pass |

Mechanical Inspection

- | | |
|---|----------|
| ● 5. Shaft Rotations | 15 |
| ● 6. Bearing Condition | (P) Pass |
| ● 7. Bearing Grease | (P) Pass |

Inspection Complete

- | | |
|--------------|---------------|
| 8. Signature | Stone Hubbard |
|--------------|---------------|

Stone Hubbard

Hi-Speed Industrial Service disclaims all warranties, both express and implied, relating to the information, reports, opinions and analysis disclosed to the Customer by Hi-Speed. Hi-Speed shall not be liable for any errors or omissions, or any losses, injury or damages arising from the use of such information, reports, opinions and analysis by the Customer.

Printed on 09/05/2019

Powered by [INSPECTALL](#)

51.0



Hi-Speed Industrial Service
7030 Ryburn Dr
Millington, Tn 38053
901-873-5300

Motor Storage Inspection

KTG USA (0003468)

400 Mahannah Ave.
Memphis, TN 38107

FolderID: 1016
FormID: 6354944



Motor Storage

Completed by: Erich Sodam on 09/03/2019

Location: D111

Serial Number: DIRECT DRIVE

Manufacturer:	ABB
Product Number:	M3BP355SMC8B3
HP / KW:	308
Phase:	3
HZ:	60
Amps:	368
RPM:	893
Frame Size:	355SMC
Voltage:	480
Enclosure:	TEFC
Wire Leads :	6
Jbox Included:	Yes
Driveshaft Coupling Included:	No
Date Received :	10/12/2017

Priorities Found: ● 4 - Good

General

- | | |
|---------------------|------------|
| 1. Inspection Date | 09/03/2019 |
| 2. Storage Location | d111 |

Electrical Inspection

- | | |
|--|----------|
| 3. Meggar Reading | inf |
| ● 4. PI Check | (P) Pass |

Mechanical Inspection

- | | |
|---|----------|
| ● 5. Shaft Rotations | 15 |
| ● 6. Bearing Condition | (P) Pass |
| ● 7. Bearing Grease | (P) Pass |

Inspection Complete

- | | |
|--------------|---------------|
| 8. Signature | Stone Hubbard |
|--------------|---------------|

Stone Hubbard



Hi-Speed Industrial Service
7030 Ryburn Dr
Millington, Tn 38053
901-873-5300

Motor Storage Inspection

KTG USA (0003468)

400 Mahannah Ave.
Memphis, TN 38107

FolderID: 1016
FormID: 6354942



Motor Storage

Completed by: Erich Sodam on 09/03/2019

Location: D211

Serial Number: DIRECT DRIVE

Manufacturer: ABB

Product Number: M3BP355SMC8B3

HP / KW: 308

Phase: 3

HZ: 60

Amps: 368

RPM: 893

Frame Size: 355SMC

Voltage: 480

Enclosure: TEFC

Wire Leads : 6

Jbox Included: Yes

Driveshaft Coupling
Included: Yes

Date Received : 10/12/2017

Priorities Found: ● 4 - Good

General

- | | |
|---------------------|------------|
| 1. Inspection Date | 09/03/2019 |
| 2. Storage Location | b211 |

Electrical Inspection

- | | |
|--|----------|
| 3. Meggar Reading | inf |
| ● 4. PI Check | (P) Pass |

Mechanical Inspection

- | | |
|---|----------|
| ● 5. Shaft Rotations | 15 |
| ● 6. Bearing Condition | (P) Pass |
| ● 7. Bearing Grease | (P) Pass |

Inspection Complete

- | | |
|--------------|---------------|
| 8. Signature | Stone Hubbard |
|--------------|---------------|

Stone Hubbard



Hi-Speed Industrial Service
7030 Ryburn Dr
Millington, Tn 38053
901-873-5300

Motor Storage Inspection

KTG USA (0003468)

400 Mahannah Ave.
Memphis, TN 38107

FolderID: 1016
FormID: 6354946



Motor Storage

Completed by: Erich Sodam on 09/03/2019

Location: Default

Serial Number: DIRECT DRIVE

Manufacturer: ABB

HP / KW: 683

Phase: 3

HZ: 60

Amps: 780

RPM: 1800

Voltage: 480

Enclosure: TEFC

Wire Leads : 6

Jbox Included: Yes

Driveshaft Coupling
Included: No

Date Received : 10/12/2017

Priorities Found: ● 4 - Good

General

- | | |
|---------------------|------------|
| 1. Inspection Date | 09/03/2019 |
| 2. Storage Location | floor |

Electrical Inspection

- | | |
|-------------------|----------|
| 3. Meggar Reading | inf |
| ● 4. PI Check | (P) Pass |

Mechanical Inspection

- | | |
|------------------------|----------|
| ● 5. Shaft Rotations | 15 |
| ● 6. Bearing Condition | (P) Pass |
| ● 7. Bearing Grease | (P) Pass |

Inspection Complete

- | | |
|--------------|---------------|
| 8. Signature | Stone Hubbard |
|--------------|---------------|



Hi-Speed Industrial Service
7030 Ryburn Dr
Millington, Tn 38053
901-873-5300

Motor Storage Inspection

KTG USA (0003468)

400 Mahannah Ave.
Memphis, TN 38107

FolderID: 1016
FormID: 6354930



Motor Storage

Completed by: Erich Sodam on 09/03/2019

Location: E122a

Serial Number: DIRECT DRIVE

Manufacturer: TECO Westinghouse

Product Number: 135417

HP / KW: 75

Phase: 3

HZ: 60

Amps: 179.8/89.9

RPM: 890

Frame Size: 444T

Voltage: 230 / 460

Enclosure: TEFC

Wire Leads : 6

Jbox Included: No

Driveshaft Coupling
Included: No

Date Received : 10/12/2017

Priorities Found: ● 4 - Good

General

- | | |
|---------------------|------------|
| 1. Inspection Date | 09/03/2019 |
| 2. Storage Location | e122a |

Electrical Inspection

- | | |
|-------------------|----------|
| 3. Meggar Reading | inf |
| ● 4. PI Check | (P) Pass |

Mechanical Inspection

- | | |
|------------------------|----------|
| ● 5. Shaft Rotations | 15 |
| ● 6. Bearing Condition | (P) Pass |
| ● 7. Bearing Grease | (P) Pass |

Inspection Complete

- | | |
|--------------|---------------|
| 8. Signature | Stone Hubbard |
|--------------|---------------|



Hi-Speed Industrial Service
7030 Ryburn Dr
Millington, Tn 38053
901-873-5300

Motor Storage Inspection

KTG USA (0003468)

400 Mahannah Ave.
Memphis, TN 38107

FolderID: 1016
FormID: 6354933



Motor Storage

Completed by: Erich Sodam on 09/03/2019

Location: E122b

Serial Number: DIRECT DRIVE

Manufacturer: US Motors

Product Number: 802913

HP / KW: 75

Phase: 3

HZ: 60

Amps: 168/84

RPM: 3560

Frame Size: 365TS

Voltage: 230 / 460

Enclosure: TEFC

Wire Leads : 9

Jbox Included: Yes

Driveshaft Coupling
Included: No

Date Received : 10/12/2017

Priorities Found: 4 - Good

General

- | | |
|---------------------|------------|
| 1. Inspection Date | 09/03/2019 |
| 2. Storage Location | e122b |

Electrical Inspection

- | | |
|-------------------|----------|
| 3. Meggar Reading | inf |
| 4. PI Check | (P) Pass |

Mechanical Inspection

- | | |
|----------------------|----------|
| 5. Shaft Rotations | 15 |
| 6. Bearing Condition | (P) Pass |
| 7. Bearing Grease | (P) Pass |

Inspection Complete

- | | |
|--------------|---------------|
| 8. Signature | Stone Hubbard |
|--------------|---------------|



Hi-Speed Industrial Service
7030 Ryburn Dr
Millington, Tn 38053
901-873-5300

Motor Storage Inspection

KTG USA (0003468)

400 Mahannah Ave.
Memphis, TN 38107

FolderID: 1016
FormID: 6354938



Motor Storage

Completed by: Erich Sodam on 09/03/2019

Location: Floor A7

Serial Number: DIRECT DRIVE

Manufacturer: ABB

Product Number: 4624124

HP / KW: 747

Phase: 3

HZ: 60

Amps: 1063

RPM: 1200

Voltage: 480

Wire Leads : 12

Jbox Included: Yes

Driveshaft Coupling
Included: No

Date Received : 10/12/2017

Priorities Found: ● 4 - Good

General

- | | |
|---------------------|------------|
| 1. Inspection Date | 09/03/2019 |
| 2. Storage Location | floor a7 |

Electrical Inspection

- | | |
|-------------------|----------|
| 3. Meggar Reading | inf |
| ● 4. PI Check | (P) Pass |

Mechanical Inspection

- | | |
|------------------------|----------|
| ● 5. Shaft Rotations | 15 |
| ● 6. Bearing Condition | (P) Pass |
| ● 7. Bearing Grease | (P) Pass |

Inspection Complete

- | | |
|--------------|---------------|
| 8. Signature | Stone Hubbard |
|--------------|---------------|



Hi-Speed Industrial Service
7030 Ryburn Dr
Millington, Tn 38053
901-873-5300

Motor Storage Inspection

KTG USA (0003468)

400 Mahannah Ave.
Memphis, TN 38107

FolderID: 1016
FormID: 6354974



Motor Storage

Completed by: Erich Sodam on 09/03/2019

Location: E112

Serial Number: DIRECT DRIVE

Manufacturer: TECO Westinghouse

Product Number: EP1008

HP / KW: 100

Phase: 3

HZ: 60

Amps: 312/156

RPM: 900

Frame Size: 445T

Voltage: 230 / 460

Enclosure: TEFC

Wire Leads : 9

Jbox Included: Yes

Driveshaft Coupling
Included: No

Date Received : 10/12/2017

Priorities Found: 4 - Good

General

- | | |
|---------------------|------------|
| 1. Inspection Date | 09/03/2019 |
| 2. Storage Location | e112 |

Electrical Inspection

- | | |
|-------------------|----------|
| 3. Meggar Reading | inf |
| 4. PI Check | (P) Pass |

Mechanical Inspection

- | | |
|----------------------|----------|
| 5. Shaft Rotations | 15 |
| 6. Bearing Condition | (P) Pass |
| 7. Bearing Grease | (P) Pass |

Inspection Complete

- | | |
|--------------|---------------|
| 8. Signature | Stone Hubbard |
|--------------|---------------|

Hi-Speed Industrial Service disclaims all warranties, both express and implied, relating to the information, reports, opinions and analysis disclosed to the Customer by Hi-Speed. Hi-Speed shall not be liable for any errors or omissions, or any losses, injury or damages arising from the use of such information, reports, opinions and analysis by the Customer.

Printed on 09/05/2019

Powered by [INSPECTALL](#)

58.0



Hi-Speed Industrial Service
7030 Ryburn Dr
Millington, Tn 38053
901-873-5300

Motor Storage Inspection

KTG USA (0003468)

400 Mahannah Ave.
Memphis, TN 38107

FolderID: 1016
FormID: 6354970



Motor Storage

Completed by: Erich Sodam on 09/03/2019

Location: F111

Serial Number: DIRECT DRIVE

Manufacturer:	ABB
Product Number:	8028899
HP / KW:	74
Phase:	3
HZ:	60
Amps:	91
RPM:	1000
Frame Size:	280
Voltage:	460
Enclosure:	TEFC
Wire Leads :	6
Jbox Included:	Yes
Driveshaft Coupling Included:	Yes
Date Received :	10/12/2017

Priorities Found: 4 - Good

General

1. Inspection Date	09/03/2019
2. Storage Location	f111

Electrical Inspection

3. Meggar Reading	inf
4. PI Check	(P) Pass

Mechanical Inspection

5. Shaft Rotations	15
6. Bearing Condition	(P) Pass
7. Bearing Grease	(P) Pass

Inspection Complete

8. Signature	Stone Hubbard
--------------	---------------



Hi-Speed Industrial Service
7030 Ryburn Dr
Millington, Tn 38053
901-873-5300

Motor Storage Inspection

KTG USA (0003468)

400 Mahannah Ave.
Memphis, TN 38107

FolderID: 1016
FormID: 6354973



Motor Storage

Completed by: Erich Sodam on 09/03/2019

Location: F112

Serial Number: DIRECT DRIVE

Manufacturer:	Reliance
Product Number:	01MAN76989 G001 MB
HP / KW:	200
Phase:	3
HZ:	60
Amps:	223
RPM:	1190
Frame Size:	449TS
Voltage:	460
Enclosure:	TEFC
Wire Leads :	6
Jbox Included:	Yes
Driveshaft Coupling Included:	No
Date Received :	10/12/2017

Priorities Found: ● 4 - Good

General

1. Inspection Date	09/03/2019
2. Storage Location	f112

Electrical Inspection

3. Meggar Reading	inf
● 4. PI Check	(P) Pass

Mechanical Inspection

● 5. Shaft Rotations	15
● 6. Bearing Condition	(P) Pass
● 7. Bearing Grease	(P) Pass

Inspection Complete

8. Signature	Stone Hubbard
--------------	---------------



Hi-Speed Industrial Service
7030 Ryburn Dr
Millington, Tn 38053
901-873-5300

Motor Storage Inspection

KTG USA (0003468)

400 Mahannah Ave.
Memphis, TN 38107

FolderID: 1016
FormID: 6354968



Motor Storage

Completed by: Erich Sodam on 09/03/2019

Location: F121

Serial Number: DIRECT DRIVE

Manufacturer: GE

Product Number: 8028558

HP / KW: 100

Phase: 3

HZ: 60

Amps: 115

RPM: 1790

Frame Size: 405TS

Voltage: 460

Enclosure: TEFC

Wire Leads : 3

Jbox Included: No

Driveshaft Coupling
Included: No

Date Received : 10/12/2017

Priorities Found: ● 4 - Good

General

- | | |
|---------------------|------------|
| 1. Inspection Date | 09/03/2019 |
| 2. Storage Location | f121 |

Electrical Inspection

- | | |
|--|----------|
| 3. Meggar Reading | inf |
| ● 4. PI Check | (P) Pass |

Mechanical Inspection

- | | |
|---|----------|
| ● 5. Shaft Rotations | 15 |
| ● 6. Bearing Condition | (P) Pass |
| ● 7. Bearing Grease | (P) Pass |

Inspection Complete

- | | |
|--------------|---------------|
| 8. Signature | Stone Hubbard |
|--------------|---------------|



Hi-Speed Industrial Service
7030 Ryburn Dr
Millington, Tn 38053
901-873-5300

Motor Storage Inspection

KTG USA (0003468)

400 Mahannah Ave.
Memphis, TN 38107

FolderID: 1016
FormID: 6354971



Motor Storage

Completed by: Erich Sodam on 09/03/2019

Location: F122

Serial Number: DIRECT DRIVE

Manufacturer: GE

Product Number: 8028557

HP / KW: 100

Phase: 3

HZ: 60

Amps: 115

RPM: 1790

Frame Size: 405T

Voltage: 460

Enclosure: TEFC

Wire Leads : 3

Jbox Included: Yes

Driveshaft Coupling
Included: No

Date Received : 10/12/2017

Priorities Found: ● 4 - Good

General

- | | |
|---------------------|------------|
| 1. Inspection Date | 09/03/2019 |
| 2. Storage Location | f122 |

Electrical Inspection

- | | |
|--|----------|
| 3. Meggar Reading | inf |
| ● 4. PI Check | (P) Pass |

Mechanical Inspection

- | | |
|---|----------|
| ● 5. Shaft Rotations | 15 |
| ● 6. Bearing Condition | (P) Pass |
| ● 7. Bearing Grease | (P) Pass |

Inspection Complete

- | | |
|--------------|---------------|
| 8. Signature | Stone Hubbard |
|--------------|---------------|



Hi-Speed Industrial Service
7030 Ryburn Dr
Millington, Tn 38053
901-873-5300

Motor Storage Inspection

KTG USA (0003468)

400 Mahannah Ave.
Memphis, TN 38107

FolderID: 1016
FormID: 6354965



Motor Storage

Completed by: Erich Sodam on 09/03/2019

Location: Floor

Serial Number: DIRECT DRIVE

Manufacturer: TECO Westinghouse

Product Number: CCS000041

HP / KW: 600

Phase: 3

HZ: 60

Amps: 720

RPM: 600

Frame Size: 6811

Voltage: 460

Enclosure: TEFC

Wire Leads : 6

Jbox Included: Yes

Driveshaft Coupling
Included: No

Date Received : 10/12/2017

Priorities Found: ● 4 - Good

General

- | | |
|---------------------|------------|
| 1. Inspection Date | 09/03/2019 |
| 2. Storage Location | floor |

Electrical Inspection

- | | |
|-------------------|----------|
| 3. Meggar Reading | inf |
| ● 4. PI Check | (P) Pass |

Mechanical Inspection

- | | |
|------------------------|----------|
| ● 5. Shaft Rotations | 15 |
| ● 6. Bearing Condition | (P) Pass |
| ● 7. Bearing Grease | (P) Pass |

Inspection Complete

- | | |
|--------------|---------------|
| 8. Signature | Stone Hubbard |
|--------------|---------------|

Stone Hubbard



Hi-Speed Industrial Service
7030 Ryburn Dr
Millington, Tn 38053
901-873-5300

Motor Storage Inspection

KTG USA (0003468)

400 Mahannah Ave.
Memphis, TN 38107

FolderID: 1016
FormID: 6354943



Motor Storage

Completed by: Erich Sodam on 09/03/2019

Location: Floor2

Serial Number: DIRECT DRIVE

Manufacturer: GE

Product Number: 5K51AN3000M

HP / KW: 500

Phase: 3

HZ: 60

Amps: 109

RPM: 1185

Frame Size: 5011LL

Voltage: 2300

Enclosure: DP

Wire Leads : 6

Driveshaft Coupling
Included: No

Date Received : 10/12/2017

Priorities Found: ● 4 - Good

General

- | | |
|---------------------|------------|
| 1. Inspection Date | 09/03/2019 |
| 2. Storage Location | floor 2 |

Electrical Inspection

- | | |
|-------------------|----------|
| 3. Meggar Reading | inf |
| ● 4. PI Check | (P) Pass |

Mechanical Inspection

- | | |
|------------------------|----------|
| ● 5. Shaft Rotations | 15 |
| ● 6. Bearing Condition | (P) Pass |
| ● 7. Bearing Grease | (P) Pass |

Inspection Complete

- | | |
|--------------|---------------|
| 8. Signature | Stone Hubbard |
|--------------|---------------|

Stone Hubbard



Hi-Speed Industrial Service
7030 Ryburn Dr
Millington, Tn 38053
901-873-5300

Motor Storage Inspection

KTG USA (0003468)

400 Mahannah Ave.
Memphis, TN 38107

FolderID: 1016
FormID: 6354960



Motor Storage

Completed by: Erich Sodam on 09/03/2019

Location: Floor3

Serial Number: DIRECT DRIVE

Manufacturer: TECO Westinghouse

Product Number: KG2006T

HP / KW: 200

Phase: 3

HZ: 60

Amps: 45.7/26.9

RPM: 1188

Frame Size: 449T

Voltage: 2300 / 4160

Enclosure: TEFC

Wire Leads : 6

Jbox Included: Yes

Driveshaft Coupling
Included: No

Date Received : 10/12/2017

Priorities Found: ● 4 - Good

General

- | | |
|---------------------|------------|
| 1. Inspection Date | 09/03/2019 |
| 2. Storage Location | floor 3 |

Electrical Inspection

- | | |
|--|----------|
| 3. Meggar Reading | inf |
| ● 4. PI Check | (P) Pass |

Mechanical Inspection

- | | |
|---|----------|
| ● 5. Shaft Rotations | 15 |
| ● 6. Bearing Condition | (P) Pass |
| ● 7. Bearing Grease | (P) Pass |

Inspection Complete

- | | |
|--------------|---------------|
| 8. Signature | Stone Hubbard |
|--------------|---------------|

Stone Hubbard



Hi-Speed Industrial Service
7030 Ryburn Dr
Millington, Tn 38053
901-873-5300

Motor Storage Inspection

KTG USA (0003468)

400 Mahannah Ave.
Memphis, TN 38107

FolderID: 1016
FormID: 6354963



Motor Storage

Completed by: Erich Sodam on 09/03/2019

Location: Floor4

Serial Number: DIRECT DRIVE

Manufacturer: ABB

Product Number: 5013476

HP / KW: 246

Phase: 3

HZ: 60

Amps: 369

RPM: 1194

Frame Size: 355SMC

Voltage: 480

Enclosure: TEFC

Wire Leads : 6

Jbox Included: Yes

Driveshaft Coupling
Included: Yes

Date Received : 10/12/2017

Priorities Found: ● 4 - Good

General

- | | |
|---------------------|------------|
| 1. Inspection Date | 09/03/2019 |
| 2. Storage Location | floor 4 |

Electrical Inspection

- | | |
|--|----------|
| 3. Meggar Reading | inf |
| ● 4. PI Check | (P) Pass |

Mechanical Inspection

- | | |
|---|----------|
| ● 5. Shaft Rotations | 15 |
| ● 6. Bearing Condition | (P) Pass |
| ● 7. Bearing Grease | (P) Pass |

Inspection Complete

- | | |
|--------------|---------------|
| 8. Signature | Stone Hubbard |
|--------------|---------------|

Stone Hubbard



Hi-Speed Industrial Service
7030 Ryburn Dr
Millington, Tn 38053
901-873-5300

Motor Storage Inspection

KTG USA (0003468)

400 Mahannah Ave.
Memphis, TN 38107

FolderID: 1016
FormID: 6354950



Motor Storage

Completed by: Erich Sodam on 09/03/2019

Location: Floor5

Serial Number: DIRECT DRIVE

Manufacturer: GE

Product Number: 139825

HP / KW: 400

Phase: 3

HZ: 60

Amps: 100

RPM: 720

Frame Size: 8307S

Voltage: 2300

Enclosure: WPI

Wire Leads : 3

Jbox Included: No

Driveshaft Coupling
Included: No

Date Received : 10/12/2017

Priorities Found: ● 4 - Good

General

- | | |
|---------------------|------------|
| 1. Inspection Date | 09/03/2019 |
| 2. Storage Location | floor5 |

Electrical Inspection

- | | |
|--|----------|
| 3. Meggar Reading | inf |
| ● 4. PI Check | (P) Pass |

Mechanical Inspection

- | | |
|---|----------|
| ● 5. Shaft Rotations | 15 |
| ● 6. Bearing Condition | (P) Pass |
| ● 7. Bearing Grease | (P) Pass |

Inspection Complete

- | | |
|--------------|---------------|
| 8. Signature | Stone Hubbard |
|--------------|---------------|

Hi-Speed Industrial Service disclaims all warranties, both express and implied, relating to the information, reports, opinions and analysis disclosed to the Customer by Hi-Speed. Hi-Speed shall not be liable for any errors or omissions, or any losses, injury or damages arising from the use of such information, reports, opinions and analysis by the Customer.

Printed on 09/05/2019

Powered by [INSPECTALL](#)

67.0



Hi-Speed Industrial Service
7030 Ryburn Dr
Millington, Tn 38053
901-873-5300

Motor Storage Inspection

KTG USA (0003468)

400 Mahannah Ave.
Memphis, TN 38107

FolderID: 1016
FormID: 6354941



Motor Storage

Completed by: Erich Sodam on 09/03/2019

Location: Floor6

Serial Number: DIRECT DRIVE

Manufacturer:	GE
Product Number:	5K444SN2408
HP / KW:	125
Phase:	3
HZ:	60
Amps:	145
RPM:	1780
Frame Size:	444TS
Voltage:	460
Enclosure:	TEFC
Wire Leads :	3
Jbox Included:	Yes
Driveshaft Coupling Included:	No
Date Received :	10/12/2017

Priorities Found: ● 4 - Good

General

- | | |
|---------------------|------------|
| 1. Inspection Date | 09/03/2019 |
| 2. Storage Location | floor 6 |

Electrical Inspection

- | | |
|-------------------|----------|
| 3. Meggar Reading | inf |
| ● 4. PI Check | (P) Pass |

Mechanical Inspection

- | | |
|------------------------|----------|
| ● 5. Shaft Rotations | 15 |
| ● 6. Bearing Condition | (P) Pass |
| ● 7. Bearing Grease | (P) Pass |

Inspection Complete

- | | |
|--------------|---------------|
| 8. Signature | Stone Hubbard |
|--------------|---------------|



Hi-Speed Industrial Service
7030 Ryburn Dr
Millington, Tn 38053
901-873-5300

Motor Storage Inspection

KTG USA (0003468)

400 Mahannah Ave.
Memphis, TN 38107

FolderID: 1016
FormID: 6354966



Motor Storage

Completed by: Erich Sodam on 09/03/2019

Location: Floor7

Serial Number: DIRECT DRIVE

Manufacturer: GE

HP / KW: 125

Phase: 3

HZ: 60

RPM: 1200

Frame Size: 445T

Voltage: 460

Enclosure: TEFC

Wire Leads : 3

Jbox Included: No

Driveshaft Coupling
Included: No

Date Received : 10/12/2017

Priorities Found: ● 4 - Good

General

- | | |
|---------------------|------------|
| 1. Inspection Date | 09/03/2019 |
| 2. Storage Location | floor 7 |

Electrical Inspection

- | | |
|-------------------|----------|
| 3. Meggar Reading | inf |
| ● 4. PI Check | (P) Pass |

Mechanical Inspection

- | | |
|------------------------|----------|
| ● 5. Shaft Rotations | 15 |
| ● 6. Bearing Condition | (P) Pass |
| ● 7. Bearing Grease | (P) Pass |

Inspection Complete

- | | |
|--------------|---------------|
| 8. Signature | Stone Hubbard |
|--------------|---------------|



Hi-Speed Industrial Service
7030 Ryburn Dr
Millington, Tn 38053
901-873-5300

Motor Storage Inspection

KTG USA (0003468)

400 Mahannah Ave.
Memphis, TN 38107

FolderID: 1016
FormID: 6354955



Motor Storage

Completed by: Erich Sodam on 09/03/2019

Location: Floor8

Serial Number: DIRECT DRIVE

Manufacturer: TECO Westinghouse

Product Number: 5004341

HP / KW: 700

Phase: 3

HZ: 60

Amps: 98

RPM: 714

Frame Size: 4511

Voltage: 4160

Enclosure: WP2

Wire Leads : 6

Jbox Included: Yes

Driveshaft Coupling
Included: No

Date Received : 10/12/2017

Priorities Found: 4 - Good

General

- | | |
|---------------------|------------|
| 1. Inspection Date | 09/03/2019 |
| 2. Storage Location | floor 8 |

Electrical Inspection

- | | |
|-------------------|----------|
| 3. Meggar Reading | inf |
| 4. PI Check | (P) Pass |

Mechanical Inspection

- | | |
|----------------------|----------|
| 5. Shaft Rotations | 15 |
| 6. Bearing Condition | (P) Pass |
| 7. Bearing Grease | (P) Pass |

Inspection Complete

- | | |
|--------------|---------------|
| 8. Signature | Stone Hubbard |
|--------------|---------------|



Hi-Speed Industrial Service
7030 Ryburn Dr
Millington, Tn 38053
901-873-5300

Motor Storage Inspection

KTG USA (0003468)

400 Mahannah Ave.
Memphis, TN 38107

FolderID: 1016
FormID: 6354945



Motor Storage

Completed by: Erich Sodam on 09/03/2019

Location: Floor9

Serial Number: DIRECT DRIVE

Manufacturer:	Siemens
Product Number:	1LE2326A112AA3
HP / KW:	350
Phase:	3
HZ:	60
Amps:	370.0
RPM:	3570
Frame Size:	S449SS
Voltage:	460
Enclosure:	TEFC
Wire Leads :	6
Jbox Included:	Yes
Driveshaft Coupling Included:	No
Date Received :	10/12/2017

Priorities Found: ● 4 - Good

General

- | | |
|---------------------|------------|
| 1. Inspection Date | 09/03/2019 |
| 2. Storage Location | floor 9 |

Electrical Inspection

- | | |
|--|----------|
| 3. Meggar Reading | inf |
| ● 4. PI Check | (P) Pass |

Mechanical Inspection

- | | |
|---|----------|
| ● 5. Shaft Rotations | 15 |
| ● 6. Bearing Condition | (P) Pass |
| ● 7. Bearing Grease | (P) Pass |

Inspection Complete

- | | |
|--------------|---------------|
| 8. Signature | Stone Hubbard |
|--------------|---------------|



Hi-Speed Industrial Service
7030 Ryburn Dr
Millington, Tn 38053
901-873-5300

Motor Storage Inspection

KTG USA (0003468)

400 Mahannah Ave.
Memphis, TN 38107

FolderID: 1016
FormID: 6354953



Motor Storage

Completed by: Erich Sodam on 09/03/2019

Location: FloorA2

Serial Number: DIRECT DRIVE

Manufacturer:	ABB
Product Number:	M38P400LC12B3
HP / KW:	280
Phase:	3
HZ:	60
Amps:	530
RPM:	595
Frame Size:	400LB
Voltage:	460
Enclosure:	TEFC
Wire Leads :	6
Jbox Included:	Yes
Driveshaft Coupling Included:	Yes
Date Received :	10/12/2017

Priorities Found: 4 - Good

General

1. Inspection Date	09/03/2019
2. Storage Location	floor a2

Electrical Inspection

3. Meggar Reading	inf
4. PI Check	(P) Pass

Mechanical Inspection

5. Shaft Rotations	15
6. Bearing Condition	(P) Pass
7. Bearing Grease	(P) Pass

Inspection Complete

8. Signature	Stone Hubbard
--------------	---------------



Hi-Speed Industrial Service
7030 Ryburn Dr
Millington, Tn 38053
901-873-5300

Motor Storage Inspection

KTG USA (0003468)

400 Mahannah Ave.
Memphis, TN 38107

FolderID: 1016
FormID: 6354951



Motor Storage

Completed by: Erich Sodam on 09/03/2019

Location: FloorA3

Serial Number: DIRECT DRIVE

Manufacturer: GE

Product Number: 139825

HP / KW: 400

Phase: 3

HZ: 60

Amps: 100

RPM: 720

Frame Size: 8307S

Voltage: 2300

Enclosure: WPI

Wire Leads : 3

Jbox Included: No

Driveshaft Coupling
Included: No

Date Received : 10/12/2017

Priorities Found: ● 4 - Good

General

- | | |
|---------------------|------------|
| 1. Inspection Date | 09/03/2019 |
| 2. Storage Location | floor a3 |

Electrical Inspection

- | | |
|--|----------|
| 3. Meggar Reading | inf |
| ● 4. PI Check | (P) Pass |

Mechanical Inspection

- | | |
|---|----------|
| ● 5. Shaft Rotations | 15 |
| ● 6. Bearing Condition | (P) Pass |
| ● 7. Bearing Grease | (P) Pass |

Inspection Complete

- | | |
|--------------|---------------|
| 8. Signature | Stone Hubbard |
|--------------|---------------|



Hi-Speed Industrial Service
7030 Ryburn Dr
Millington, Tn 38053
901-873-5300

Motor Storage Inspection

KTG USA (0003468)

400 Mahannah Ave.
Memphis, TN 38107

FolderID: 1016
FormID: 6354948



Motor Storage

Completed by: Erich Sodam on 09/03/2019

Location: FloorA4

Serial Number: DIRECT DRIVE

Manufacturer: GE

HP / KW: 600

Phase: 3

HZ: 60

Amps: 739

RPM: 705

Frame Size: 8311S

Voltage: 460

Enclosure: WP2

Wire Leads : 6

Jbox Included: No

Driveshaft Coupling
Included: Yes

Date Received : 10/12/2017

Priorities Found: ● 4 - Good

General

- | | |
|---------------------|------------|
| 1. Inspection Date | 09/03/2019 |
| 2. Storage Location | floor a4 |

Electrical Inspection

- | | |
|--|----------|
| 3. Meggar Reading | inf |
| ● 4. PI Check | (P) Pass |

Mechanical Inspection

- | | |
|---|----------|
| ● 5. Shaft Rotations | 15 |
| ● 6. Bearing Condition | (P) Pass |
| ● 7. Bearing Grease | (P) Pass |

Inspection Complete

- | | |
|--------------|---------------|
| 8. Signature | Stone Hubbard |
|--------------|---------------|



Hi-Speed Industrial Service
7030 Ryburn Dr
Millington, Tn 38053
901-873-5300

Motor Storage Inspection

KTG USA (0003468)

400 Mahannah Ave.

Memphis, TN 38107

FolderID: 1016
FormID: 6354957



Motor Storage

Completed by: Erich Sodam on 09/03/2019

Location: FloorA5

Serial Number: DIRECT DRIVE

Manufacturer: TECO Westinghouse

Product Number: 5004343

HP / KW: 1750

Phase: 3

HZ: 60

Amps: 245

RPM: 1193

Frame Size: 5012

Voltage: 4160

Enclosure: WP2

Wire Leads : 6

Jbox Included: Yes

Driveshaft Coupling
Included: No

Date Received : 10/12/2017

Priorities Found: ● 4 - Good

General

- | | |
|---------------------|------------|
| 1. Inspection Date | 09/03/2019 |
| 2. Storage Location | floor a5 |

Electrical Inspection

- | | |
|--|----------|
| 3. Meggar Reading | inf |
| ● 4. PI Check | (P) Pass |

Mechanical Inspection

- | | |
|---|----------|
| ● 5. Shaft Rotations | 15 |
| ● 6. Bearing Condition | (P) Pass |
| ● 7. Bearing Grease | (P) Pass |

Inspection Complete

- | | |
|--------------|---------------|
| 8. Signature | Stone Hubbard |
|--------------|---------------|



Hi-Speed Industrial Service
7030 Ryburn Dr
Millington, Tn 38053
901-873-5300

Motor Storage Inspection

KTG USA (0003468)

400 Mahannah Ave.
Memphis, TN 38107

FolderID: 1016
FormID: 6354940



Motor Storage

Completed by: Erich Sodam on 09/03/2019

Location: FloorA6

Serial Number: DIRECT DRIVE

Manufacturer: ABB

Product Number: CCS000062

HP / KW: 560

Phase: 3

HZ: 60

Amps: 672

RPM: 716

Frame Size: 450LD

Voltage: 480

Enclosure: TEFC

Wire Leads : 6

Jbox Included: Yes

Driveshaft Coupling
Included: Yes

Date Received : 10/12/2017

Priorities Found: 4 - Good

General

- | | |
|---------------------|------------|
| 1. Inspection Date | 09/03/2019 |
| 2. Storage Location | floor a6 |

Electrical Inspection

- | | |
|-------------------|----------|
| 3. Meggar Reading | inf |
| 4. PI Check | (P) Pass |

Mechanical Inspection

- | | |
|----------------------|----------|
| 5. Shaft Rotations | 15 |
| 6. Bearing Condition | (P) Pass |
| 7. Bearing Grease | (P) Pass |

Inspection Complete

- | | |
|--------------|---------------|
| 8. Signature | Stone Hubbard |
|--------------|---------------|



Hi-Speed Industrial Service
7030 Ryburn Dr
Millington, Tn 38053
901-873-5300

Motor Storage Inspection

KTG USA (0003468)

400 Mahannah Ave.
Memphis, TN 38107

FolderID: 1016
FormID: 6354959



Motor Storage

Completed by: Erich Sodam on 09/03/2019

Location: FloorA1

Serial Number: DIRECT DRIVE

Manufacturer: TECO Westinghouse

Product Number: 5004340

HP / KW: 1000

Phase: 3

HZ: 60

Amps: 133

RPM: 1190

Frame Size: 4511

Voltage: 4160

Enclosure: WP2

Wire Leads : 3

Jbox Included: Yes

Driveshaft Coupling
Included: No

Date Received : 10/12/2017

Priorities Found: ● 4 - Good

General

- | | |
|---------------------|------------|
| 1. Inspection Date | 09/03/2019 |
| 2. Storage Location | floora1 |

Electrical Inspection

- | | |
|--|----------|
| 3. Meggar Reading | inf |
| ● 4. PI Check | (P) Pass |

Mechanical Inspection

- | | |
|---|----------|
| ● 5. Shaft Rotations | 15 |
| ● 6. Bearing Condition | (P) Pass |
| ● 7. Bearing Grease | (P) Pass |

Inspection Complete

- | | |
|--------------|---------------|
| 8. Signature | Stone Hubbard |
|--------------|---------------|

Stone
Hubbard



Hi-Speed Industrial Service
7030 Ryburn Dr
Millington, Tn 38053
901-873-5300

Motor Storage Inspection

KTG USA (0003468)

400 Mahannah Ave.
Memphis, TN 38107

FolderID: 1016
FormID: 6354935



Motor Storage

Completed by: Erich Sodam on 09/03/2019

Location: N.e. Floor

Serial Number: DIRECT DRIVE

Manufacturer: TECO Westinghouse

Product Number: 0A71DA-01

HP / KW: 2500

Phase: 3

HZ: 60

Amps: 330

RPM: 895

Frame Size: 5614

Voltage: 4160

Enclosure: WP2

Wire Leads : 3

Jbox Included: No

Driveshaft Coupling
Included: No

Date Received : 10/12/2017

Priorities Found: ● 4 - Good

General

- | | |
|---------------------|------------|
| 1. Inspection Date | 09/03/2019 |
| 2. Storage Location | N.E floor |

Electrical Inspection

- | | |
|-------------------|----------|
| 3. Meggar Reading | inf |
| ● 4. PI Check | (P) Pass |

Mechanical Inspection

- | | |
|------------------------|----------|
| ● 5. Shaft Rotations | 15 |
| ● 6. Bearing Condition | (P) Pass |
| ● 7. Bearing Grease | (P) Pass |

Inspection Complete

- | | |
|--------------|---------------|
| 8. Signature | Stone Hubbard |
|--------------|---------------|

Stone Hubbard



Hi-Speed Industrial Service
7030 Ryburn Dr
Millington, Tn 38053
901-873-5300

Motor Storage Inspection

KTG USA (0003468)

400 Mahannah Ave.
Memphis, TN 38107

FolderID: 1016
FormID: 6354967



Motor Storage

Completed by: Erich Sodam on 09/03/2019

Location: Ne Floor

Serial Number: DIRECT DRIVE

Manufacturer:	ABB
Product Number:	4586528
HP / KW:	1050
Phase:	3
HZ:	60
Amps:	1545
RPM:	999.9
Frame Size:	500L
Voltage:	480
Enclosure:	TEFC
Wire Leads :	12
Jbox Included:	Yes
Driveshaft Coupling Included:	No
Date Received :	10/12/2017

Priorities Found: ● 4 - Good

General

- | | |
|---------------------|------------|
| 1. Inspection Date | 09/03/2019 |
| 2. Storage Location | NE floor |

Electrical Inspection

- | | |
|--|----------|
| 3. Meggar Reading | inf |
| ● 4. PI Check | (P) Pass |

Mechanical Inspection

- | | |
|---|----------|
| ● 5. Shaft Rotations | 15 |
| ● 6. Bearing Condition | (P) Pass |
| ● 7. Bearing Grease | (P) Pass |

Inspection Complete

- | | |
|--------------|---------------|
| 8. Signature | Stone Hubbard |
|--------------|---------------|



Hi-Speed Industrial Service
7030 Ryburn Dr
Millington, Tn 38053
901-873-5300

Motor Storage Inspection

KTG USA (0003468)

400 Mahannah Ave.
Memphis, TN 38107

FolderID: 1016
FormID: 6354964



Motor Storage

Completed by: Erich Sodam on 09/03/2019

Location: Understairs
Serial Number: DIRECT DRIVE

Manufacturer: Baldor

Product Number: FCP643147R-4

HP / KW: 60

Phase: 3

HZ: 60

Amps: 68

RPM: 1780

Frame Size: 364T

Voltage: 460

Enclosure: TEFC

Wire Leads : 3

Jbox Included: Yes

Driveshaft Coupling
Included: No

Date Received : 10/12/2017

Priorities Found: ● 4 - Good

General

- | | |
|---------------------|--------------|
| 1. Inspection Date | 09/03/2019 |
| 2. Storage Location | under stairs |

Electrical Inspection

- | | |
|--|----------|
| 3. Meggar Reading | inf |
| ● 4. PI Check | (P) Pass |

Mechanical Inspection

- | | |
|---|----------|
| ● 5. Shaft Rotations | 15 |
| ● 6. Bearing Condition | (P) Pass |
| ● 7. Bearing Grease | (P) Pass |

Inspection Complete

- | | |
|--------------|---------------|
| 8. Signature | Stone Hubbard |
|--------------|---------------|

Stone Hubbard



Hi-Speed Industrial Service
7030 Ryburn Dr
Millington, Tn 38053
901-873-5300

Motor Storage Inspection

KTG USA (0003468)

400 Mahannah Ave.
Memphis, TN 38107

FolderID: 1016
FormID: 6354901



Motor Storage

Completed by: Erich Sodam on 09/03/2019

Location: West Floor

Serial Number: DIRECT CRIVE

Manufacturer: GE

HP / KW: 250

Phase: 3

HZ: 60

Amps: 57

RPM: 1195

Frame Size: 509LL

Voltage: 2300

Enclosure: WPI

Date Received : 08/06/2019

Priorities Found: ● 4 - Good

General

- | | |
|---------------------|------------|
| 1. Inspection Date | 09/03/2019 |
| 2. Storage Location | west floor |

Electrical Inspection

- | | |
|--|----------|
| 3. Meggar Reading | inf |
| ● 4. PI Check | (P) Pass |

Mechanical Inspection

- | | |
|---|----------|
| ● 5. Shaft Rotations | 15 |
| ● 6. Bearing Condition | (P) Pass |
| ● 7. Bearing Grease | (P) Pass |

Inspection Complete

- | | |
|--------------|---------------|
| 8. Signature | Stone Hubbard |
|--------------|---------------|

Stone Hubbard