Report Title
 2022 PDMA Motor MCE Test Report

 Submitted By
 Administrator

 Create Date
 08/12/22 11:24 AM


 Asset Name
 Low Vacuum pump fan

 Description
 USG Greenville, MS



Date: 08/06/22 10:41 AMDated Test Event

Test Date	08/01/20	07/20/21	08/06/22
Test Time	11:18 AM	2:17 PM	10:41 AM
Test Location	Of Fuses Local Disc	Bottom Fuses	Bottom Fuses
Tester Serial	5095	5095	5095
MTap ID			
	Baseline		
Frequency	1200	1200	1200
Charge Time	600	600	600
Voltage	500	1000	1000
Motor Temp	24	30	30
Measured Mohm	787.84	308.85	973.72
Corrected Mohm	260.00	154.00	487.00
pF Ph 1 to Ground	40400	42100	38800
ohm Ph 1 to 2	0.05780	0.05780	0.06040
ohm Ph 2 to 3	0.05790	0.05790	0.06060
ohm Ph 3 to 1	0.05770	0.05760	0.06030
mH Ph 1 to 2	3.209	3.208	3.261
mH Ph 2 to 3	2.699	3 089	2.874
mH Ph 3 to 1	3.018	2.665	2.796
Average Inductance	2.975	2.987	2.977
% Res. Imbalance	0.17	0.29	0.28
% Ind. Imbalance	9.29	10.82	9.52



Remarks: Everything appears to be ok at this time other than the motor may have some winding contamination. This will be monitored closely next survey.