



2/24/2001 6:08:34 PM



FLIR0187.... FLIR T420 62114638

2/24/2001 6:08:34 PM



FLIR0187.... FLIR T420 62114638

Measurements

Bx1	Max	117.2 °F
	Min	91.6 °F
	Average	103.4 °F
Bx2	Max	107.5 °F
	Min	96.9 °F
	Average	101.3 °F

Parameters

Emissivity	0.95
Refl. temp.	67 °F

Geolocation

Compass	350° N
---------	--------

Infrared data indicates that C phase is operating over 15* higher than B phase, check wire and terminal for corrosion clean if needed and tighten to correct torque spec.