





Client	Dell Power Plant AECI	Survey Date	10-17-19
Location	Dell AR	Report Date	10-22-19
Machine	Cooling Tower 9 Motor Shown (and 7, 8, 10)	QMS No.	140953
Component	Unit	Analyst	DWS

Defect Rating for this machine	CLASS II
Defect Rating System	
Class I: Defect is present, but effect on reliability is not clear; no immediate action is required. Continue normal monitoring.	Class III: Defect (s) present that may cause failure in short term (less than 2 mos.). Should be addressed as soon as practical, with a high maintenance priority. Increase monitoring frequency.
Class II: Defect (s) present that may cause problem in long term (2-6 mos.). Repair during normal maintenance scheduling. Continue to monitor.	Class IV: Defect (s) present that makes continued reliability unpredictable, and possibility of secondary damage is high. Repairs should be made ASAP. An unscheduled shutdown should be considered for repairs.








Discussion / Repair recommendations	Trend Data
<p>The data shows the motor vibrations are up for most of these units in the axial measurement at near or above 0.45"/sec velocity peak overall. They have mostly increased after the tower rebuild. Inspect the units for defects associated with the fan and drive train. Inspect the structure and fasteners. Have the alignments checked and documented.</p> <p>Rated a Class II Defect.</p>	 <p>CTW - Cooling Tower Fan 9 CTW9 - MIA Motor Inboard Axial</p> <p>Trend Display of Overall Value</p> <p>Baseline Value: .0976 Date: 17-Jun-11</p> <p>Date: 17-Oct-19 Time: 12:32:30 Amp: .494</p>



Client	Dell Power Plant AECI	Survey Date	10-17-19
Location	Dell AR	Report Date	10-22-19
Machine	Circulating Pump 1	QMS No.	140953
Component		Analyst	DWS

Defect Rating for this machine	CLASS IV
Defect Rating System	
Class I: Defect is present, but effect on reliability is not clear; no immediate action is required. Continue normal monitoring.	Class III: Defect (s) present that may cause failure in short term (less than 2 mos.). Should be addressed as soon as practical, with a high maintenance priority. Increase monitoring frequency.
Class II: Defect (s) present that may cause problem in long term (2-6 mos.). Repair during normal maintenance scheduling. Continue to monitor.	Class IV: Defect (s) present that makes continued reliability unpredictable, and possibility of secondary damage is high. Repairs should be made ASAP. An unscheduled shutdown should be considered for repairs.

Vibration Data	Analysis
<p>CTW - Circ Water Pump 1A 3CW-P-001-MOH Motor Outboard Horizontal</p>  <p>Route Spectrum 17-Oct-19 11:49:03 OVERALL=1.06 V-DG PK = 1.05 LOAD = 100.0 RPM = 507. (8.45 Hz)</p>  <p>Route Waveform 17-Oct-19 11:49:03 PK = 1.16 PK(+) = 1.25/1.26 CRESTF=1.53</p> <p>Freq: 8.625 Ord: 1.021 Spec: .928</p>	<p>Vibrations are above 1"/sec velocity peak as measured in the time waveform.</p>

Discussion / Repair recommendations	Trend Data
<p>The pump unit is back up to vibrating at higher levels at the unit fundamental speed. Vibrations are somewhat directional which is typical for vertical pumps generally due to stiffness from piping. We still suspect something has damaged the pump or is stuck in it. Vibrations at these amplitudes are damaging to the unit. Inspect the unit at the first opportunity. Rated a Class IV Defect.</p>	 <p>Trend Display Overall Value</p>  <p>Route Spectrum 17-Oct-19 11:49:03 OVERALL=1.06 V-DG PK = 1.05 LOAD = 100.0 RPM = 507. (8.45 Hz)</p>  <p>Route Waveform 17-Oct-19 11:49:03 PK = 1.16 PK(+) = 1.25/1.26 CRESTF=1.53</p> <p>Date: 17-Oct-19 Time: 11:49:13 Ampl: 1.066</p>



Client	Dell Power Plant AECI	Survey Date	10-17-19
Location	Dell AR	Report Date	10-22-19
Machine	STG Hydraulic Pump 1 (Left unit)	QMS No.	140953
Component	Pump	Analyst	DWS

Defect Rating for this machine	CLASS III
Defect Rating System	
Class I: Defect is present, but effect on reliability is not clear; no immediate action is required. Continue normal monitoring.	Class III: Defect (s) present that may cause failure in short term (less than 2 mos.). Should be addressed as soon as practical, with a high maintenance priority. Increase monitoring frequency.
Class II: Defect (s) present that may cause problem in long term (2-6 mos.). Repair during normal maintenance scheduling. Continue to monitor.	Class IV: Defect (s) present that makes continued reliability unpredictable, and possibility of secondary damage is high. Repairs should be made ASAP. An unscheduled shutdown should be considered for repairs.

