





Client	Penn-A-Kem	Survey Date	2-26-2020
Location	Memphis, TN	Report Date	3-2-2020
Machine	P24-63DEGN 63 Degree North Pump	QMS No.	141955
Component	Pump Unit	Analyst	DWS


Defect Rating for this machine	NR
Defect Rating System	
Class I: Defect is present, but effect on reliability is not clear; no immediate action is required. Continue normal monitoring.	Class III: Defect (s) present that may cause failure in short term (less than 2 mos.). Should be addressed as soon as practical, with a high maintenance priority. Increase monitoring frequency.
Class II: Defect (s) present that may cause problem in long term (2-6 mos.). Repair during normal maintenance scheduling. Continue to monitor.	Class IV: Defect (s) present that makes continued reliability unpredictable, and possibility of secondary damage is high. Repairs should be made ASAP. An unscheduled shutdown should be considered for repairs.






Client	Penn-A-Kem	Survey Date	2-26-2020
Location	Memphis, TN	Report Date	3-2-2020
Machine	P24-85DEGS 85 Deg S Water Circ Pump	QMS No.	141955
Component	Pump	Analyst	DWS

Defect Rating for this machine	Class II
Defect Rating System	
Class I: Defect is present, but effect on reliability is not clear; no immediate action is required. Continue normal monitoring.	Class III: Defect (s) present that may cause failure in short term (less than 2 mos.). Should be addressed as soon as practical, with a high maintenance priority. Increase monitoring frequency.
Class II: Defect (s) present that may cause problem in long term (2-6 mos.). Repair during normal maintenance scheduling. Continue to monitor.	Class IV: Defect (s) present that makes continued reliability unpredictable, and possibility of secondary damage is high. Repairs should be made ASAP. An unscheduled shutdown should be considered for repairs.





Discussion / Repair recommendations	Trend Data
<p>Vibrations associated with vane pass and harmonics have increased in the pump axial. We suspect wear in the pump impeller, housing and wear rings. Operating out of BOP could also be an issue. Check parameters and inspect unit as time allows. Rated a Class III Defect.</p>	 <p>NEW - 85 DEG S WATER CIRC PUMP 025 P24-85DEGS-73 PUMP CPLG END AXIAL</p> <p>PK Velocity in in/sec</p> <p>Days: 12-Sep-19 To 26-Feb-20</p> <p>Trend Display of Overall Value</p> <p>Baseline Value: .431 Date: 12-Sep-19</p> <p>WARNING</p> <p>Date: 26-Feb-20 Time: 13:05:14 Ampl: .320</p>



Client	Penn-A-Kem	Survey Date	2-26-2020
Location	Memphis, TN	Report Date	3-2-2020
Machine	Axial Twin Screw Compressor C67-51	QMS No.	141955
Component	Bearings	Analyst	DWS

Defect Rating for this machine	Class IV
Defect Rating System	
Class I: Defect is present, but effect on reliability is not clear; no immediate action is required. Continue normal monitoring.	Class III: Defect (s) present that may cause failure in short term (less than 2 mos.). Should be addressed as soon as practical, with a high maintenance priority. Increase monitoring frequency.
Class II: Defect (s) present that may cause problem in long term (2-6 mos.). Repair during normal maintenance scheduling. Continue to monitor.	Class IV: Defect (s) present that makes continued reliability unpredictable, and possibility of secondary damage is high. Repairs should be made ASAP. An unscheduled shutdown should be considered for repairs.



Discussion / Repair recommendations	Trend Data
<p>Marked vibration peaks look to be modulated by side bands of cage frequency. This units' bearings are most likely in extreme distress. Shut down and inspect as soon as possible to avoid secondary damage. Rated a Class IV Defect.</p>	 <p>Trend Display of Overall Value Baseline Value: .118 Date: 19-Oct-19</p> <p>WARNING</p> <p>Days: 19-Oct-19 To 26-Feb-20</p> <p>Date: 26-Feb-20 Time: 08:44:25 Ampl: .358</p>