






Client	Lucite	Survey Date	3-17-20
Location	Memphis, TN	Report Date	3-18-20
Machine	Amide Reactor Circulation Primary MON65	QMS No.	142104
Component	Motor	Analyst	DWS

Defect Rating for this machine	<b>Class III</b>
Defect Rating System	
<b>Class I:</b> Defect is present, but effect on reliability is not clear; no immediate action is required. Continue normal monitoring.	<b>Class III:</b> Defect (s) present that may cause failure in short term (less than 2 mos.). Should be addressed as soon as practical, with a high maintenance priority. Increase monitoring frequency.
<b>Class II:</b> Defect (s) present that may cause problem in long term (2-6 mos.). Repair during normal maintenance scheduling. Continue to monitor.	<b>Class IV:</b> Defect (s) present that makes continued reliability unpredictable, and possibility of secondary damage is high. <b>Repairs should be made ASAP. An unscheduled shutdown should be considered for repairs.</b>


Vibration Data	Analysis
<p>Route Spectrum 17-Mar-20 12:47:48 OVERALL= 7.445 V-DG PK = 7.424 LOAD = 100.0 RPM = 1192 (19.86 Hz)</p>  <p>Route Waveform 17-Mar-20 12:47:48 RMS = 2.083 PK (4/3) = 4.964/5.949 CRE STR= 2.86</p>  <p>Freq: 19.86 Ordr: 1.000 Spec: .727 Cfrq: .263</p>	<p>Dominant shaft speed vibration with high frequency modulation.</p>


Discussion / Repair recommendations	Trend Data
<p>The motor has a large directional or torsional vibration indicating excessive vertical movement. Inspect all fasteners for tightness and the unit base for weakness/flexing. Check the coupling and alignment also. <b>Rated a Class III Defect.</b></p>	 <p>Trend Display of Overall Value Baseline Value: .86 Date: 12-Dec-16</p> <p>Date: 17-Mar-20 Time: 12:47:48 Ampl: .745</p>



Client	Lucite	Survey Date	3-17-20
Location	Memphis, TN	Report Date	3-18-20
Machine	Process Air Fan E SAR 10	QMS No.	142104
Component	Fan Bearings	Analyst	DWS

Defect Rating for this machine	<b>Class IV</b>
Defect Rating System	
<b>Class I:</b> Defect is present, but effect on reliability is not clear; no immediate action is required. Continue normal monitoring.	<b>Class III:</b> Defect (s) present that may cause failure in short term (less than 2 mos.). Should be addressed as soon as practical, with a high maintenance priority. Increase monitoring frequency.
<b>Class II:</b> Defect (s) present that may cause problem in long term (2-6 mos.). Repair during normal maintenance scheduling. Continue to monitor.	<b>Class IV:</b> Defect (s) present that makes continued reliability unpredictable, and possibility of secondary damage is high. <b>Repairs should be made ASAP. An unscheduled shutdown should be considered for repairs.</b>


Vibration Data	Analysis
<p>MM - Process Air Fan E SAR10 - FOM Fan Outboard Horizontal</p>  <p>Route Spectrum 17-Mar-20 09:46:39 OVERALL = 3233 V-DG PK = 3224 LOAD = 100.0 RPM = 1795 (29.91 Hz)</p> <p>Route Waveform 17-Mar-20 09:46:39 RMS = 6.42 PK(H) = 23.55/22.99 CRE STF = 3.67</p> <p>Time in mSecs</p> <p>Freq: 38.38 Ordr: 1.316 Spec: .162</p>	<p>Pulsing in the time domain of the outboard bearing at shaft speed.</p>

Discussion / Repair recommendations	Trend Data
<p>The fan bearings are most likely in distress. Pulsing at shaft speed can indicate at least one bad area on the bearing race. Suspect an issue during repairs at big shutdown. Make sure fan wheel is not rubbing on the housing. Did you float one of the bearings? Normally we float the outboard bearing (the one closest to the fan wheel, opposite the pulley or coupling). <b>Rated a Class IV Defect due to the high acceleration.</b></p>	 <p>Trend Display at 1K200Hz - Baseline - Value: 4.82 Date: 05-Dec-16</p> <p>Days: 05-Dec-16 to 17-Mar-20</p> <p>Date: 17-Mar-20 Time: 09:46:38 Ampl: 6.406</p>



Client	Lucite	Survey Date	3-17-20
Location	Memphis, TN	Report Date	3-18-20
Machine	Vertical Cooling Tower Pump 5 SAR66E	QMS No.	142104
Component		Analyst	DWS



Defect Rating for this machine	NA
Defect Rating System	
<b>Class I:</b> Defect is present, but effect on reliability is not clear; no immediate action is required. Continue normal monitoring.	<b>Class III:</b> Defect (s) present that may cause failure in short term (less than 2 mos.). Should be addressed as soon as practical, with a high maintenance priority. Increase monitoring frequency.
<b>Class II:</b> Defect (s) present that may cause problem in long term (2-6 mos.). Repair during normal maintenance scheduling. Continue to monitor.	<b>Class IV:</b> Defect (s) present that makes continued reliability unpredictable, and possibility of secondary damage is high. <b>Repairs should be made ASAP. An unscheduled shutdown should be considered for repairs.</b>

Vibration Data	Analysis
<p>MMR - Vertical Cool Twr Pump 05 SAR66E - MDA Motor Onboard Axial</p>  <p>Trend Display Overall Value</p> <p>Route Spectrum 17-Mar-20 08:26:44 OVERALL= 4805 V-DG PK = .4788 LOAD = 100.0 RPM = 1195 (19.91 Hz)</p> <p>Route Waveform 17-Mar-20 08:26:44 PK = .0775 PK(H) = .1390/.1409 CRE STF= 2.57</p> <p>Freq: 19.99 Ordr: .984 Spec: .05592</p>	Bad reading.
Discussion / Repair recommendations	Trend Data
<p>The ski slope on the left side of the spectrum is almost always an indicator of a bad reading. Overwrite the data when this happens. Note the trend is high without strong vibrations in the time domain.</p> <p>Information only</p>	See above



Client	Lucite	Survey Date	3-4-20
Location	Memphis, TN	Report Date	3-18-20
Machine	Oleum Tower Circulation Pump B SAR57B	QMS No.	142104
Component	Motor Bearings	Analyst	DWS


Defect Rating for this machine	<b>Class II</b>
Defect Rating System	
<b>Class I:</b> Defect is present, but effect on reliability is not clear; no immediate action is required. Continue normal monitoring.	<b>Class III:</b> Defect (s) present that may cause failure in short term (less than 2 mos.). Should be addressed as soon as practical, with a high maintenance priority. Increase monitoring frequency.
<b>Class II:</b> Defect (s) present that may cause problem in long term (2-6 mos.). Repair during normal maintenance scheduling. Continue to monitor.	<b>Class IV:</b> Defect (s) present that makes continued reliability unpredictable, and possibility of secondary damage is high. <b>Repairs should be made ASAP. An unscheduled shutdown should be considered for repairs.</b>





Client	Lucite	Survey Date	3-17-20
Location	Memphis, TN	Report Date	3-18-20
Machine	ACN29B ACN Cooling Tower Pump M	QMS No.	142104
Component	Motor	Analyst	DWS

Defect Rating for this machine	<b>Class II</b>
Defect Rating System	
<b>Class I:</b> Defect is present, but effect on reliability is not clear; no immediate action is required. Continue normal monitoring.	<b>Class III:</b> Defect (s) present that may cause failure in short term (less than 2 mos.). Should be addressed as soon as practical, with a high maintenance priority. Increase monitoring frequency.
<b>Class II:</b> Defect (s) present that may cause problem in long term (2-6 mos.). Repair during normal maintenance scheduling. Continue to monitor.	<b>Class IV:</b> Defect (s) present that makes continued reliability unpredictable, and possibility of secondary damage is high. <b>Repairs should be made ASAP. An unscheduled shutdown should be considered for repairs.</b>

Vibration Data	Analysis
	Sidebands and pulsing at near 120 HZ. Modulation frequency is above our F max at near 3KHz.

Discussion / Repair recommendations	Trend Data
There appears to be electrical, rotor bar and possibly bearing issues in the motor. The main vibration is above the Spectrum F max. Check the electrical connections, current and voltage and all fasteners as time allows. We will have to raise the F max to help better understand what is going on here. <b>Rated a Class II Defect for now.</b>	