





Client	Lucite	Survey Date	5-14-20
Location	Memphis, TN	Report Date	5-21-20
Machine	SAR 03 Turbine Compressor Main Blower	QMS No.	142511
Component	Unit	Analyst	DWS

Defect Rating for this machine	Class I
Defect Rating System	
Class I: Defect is present, but effect on reliability is not clear; no immediate action is required. Continue normal monitoring.	Class III: Defect (s) present that may cause failure in short term (less than 2 mos.). Should be addressed as soon as practical, with a high maintenance priority. Increase monitoring frequency.
Class II: Defect (s) present that may cause problem in long term (2-6 mos.). Repair during normal maintenance scheduling. Continue to monitor.	Class IV: Defect (s) present that makes continued reliability unpredictable, and possibility of secondary damage is high. Repairs should be made ASAP. An unscheduled shutdown should be considered for repairs.





Discussion / Repair recommendations	Trend Data
<p>The data seems to indicate the proximity probes have been switched most likely on the rack. This will help to better identify actual location of anomalies. The vibrations are also mostly down for the compressor readings after service; however, we are going to keep this unit under surveillance due to the harmonics still seen in the data and Rate this a Class I for now.</p>	 <p>MMA - Turb Comp Main Blower TREND DISPLAY OF Overall Value Days: 07-Jun-17 To 14-May-20</p>



Client	Lucite	Survey Date	5-14-20
Location	Memphis, TN	Report Date	5-21-20
Machine	SAR78B Cooling Tower Fan #2	QMS No.	142511
Component	Motor	Analyst	DWS


Defect Rating for this machine	NA
Defect Rating System	
Class I: Defect is present, but effect on reliability is not clear; no immediate action is required. Continue normal monitoring.	Class III: Defect (s) present that may cause failure in short term (less than 2 mos.). Should be addressed as soon as practical, with a high maintenance priority. Increase monitoring frequency.
Class II: Defect (s) present that may cause problem in long term (2-6 mos.). Repair during normal maintenance scheduling. Continue to monitor.	Class IV: Defect (s) present that makes continued reliability unpredictable, and possibility of secondary damage is high. Repairs should be made ASAP. An unscheduled shutdown should be considered for repairs.






Client	Lucite	Survey Date	5-14-20
Location	Memphis, TN	Report Date	5-21-20
Machine	MON132 Decanter Feed Pump Spare	QMS No.	142511
Component		Analyst	DWS

Defect Rating for this machine	Class II
Defect Rating System	
Class I: Defect is present, but effect on reliability is not clear; no immediate action is required. Continue normal monitoring.	Class III: Defect (s) present that may cause failure in short term (less than 2 mos.). Should be addressed as soon as practical, with a high maintenance priority. Increase monitoring frequency.
Class II: Defect (s) present that may cause problem in long term (2-6 mos.). Repair during normal maintenance scheduling. Continue to monitor.	Class IV: Defect (s) present that makes continued reliability unpredictable, and possibility of secondary damage is high. Repairs should be made ASAP. An unscheduled shutdown should be considered for repairs.






Discussion / Repair recommendations	Trend Data
<p>A high 1xRPM vibration still appears to be in both the pump and motor bearings in the vertical. Inspect the unit for loose fasteners and structural issues. Check the coupling for wear and perform an alignment check and a shaft run out check. Rated a Class II Defect.</p>	 <p>MON132 - P/V</p> <p>MON132 - M/V</p> <p>Date: 14-May-20 Time: 12:27:53 Amp2: 465</p>



Client	Lucite	Survey Date	5-14-20
Location	Memphis, TN	Report Date	5-21-20
Machine	ACN 13B #2 Kettle Transfer Pump	QMS No.	142511
Component	Motor Bearings	Analyst	DWS

Defect Rating for this machine	Class II
Defect Rating System	
Class I: Defect is present, but effect on reliability is not clear; no immediate action is required. Continue normal monitoring.	Class III: Defect (s) present that may cause failure in short term (less than 2 mos.). Should be addressed as soon as practical, with a high maintenance priority. Increase monitoring frequency.
Class II: Defect (s) present that may cause problem in long term (2-6 mos.). Repair during normal maintenance scheduling. Continue to monitor.	Class IV: Defect (s) present that makes continued reliability unpredictable, and possibility of secondary damage is high. Repairs should be made ASAP. An unscheduled shutdown should be considered for repairs.


Vibration Data	Analysis
<p>MMN - #2 Kettle Xfer Pump S ACN13B - 500 Motor Inboard Horizontal</p>  <p>Route Spectrum 14-Feb-19 14:56:53 OVERALL= .1033 V-DG RMS = 2.89 LOAD = 100.0 RPM = 3599, (59.98 Hz)</p>  <p>Route Waveform 14-Feb-19 14:56:53 RMS = 3.64 PK(Hz) = 10.25/10.09 CRESTF= 2.82</p> <p>Freq: 215.16 Ord: 3.587 Spec: .00510</p>	Multiple non-synchronous vibration peaks are marked.


Discussion / Repair recommendations	Trend Data
<p>The inboard motor bearing is showing signs of distress. Non-synchronous vibration harmonic peaks are evident in the data; however, the overall level has not changed much lately. We suggest replacing the motor this year.</p> <p>Rated a Class II Defect.</p>	 <p>Trend Display of 1K20Hz</p> <p>- Baseline - Value: .765 Date: 11-Apr-17</p> <p>Date: 14-May-20 Time: 15:00:12 Ampl: 3.420</p>



Client	Lucite	Survey Date	5-14-20
Location	Memphis, TN	Report Date	5-21-20
Machine	SAR55A Neutralization Pump North	QMS No.	142511
Component	Motor bearings	Analyst	DWS

Defect Rating for this machine	Class II
Defect Rating System	
Class I: Defect is present, but effect on reliability is not clear; no immediate action is required. Continue normal monitoring.	Class III: Defect (s) present that may cause failure in short term (less than 2 mos.). Should be addressed as soon as practical, with a high maintenance priority. Increase monitoring frequency.
Class II: Defect (s) present that may cause problem in long term (2-6 mos.). Repair during normal maintenance scheduling. Continue to monitor.	Class IV: Defect (s) present that makes continued reliability unpredictable, and possibility of secondary damage is high. Repairs should be made ASAP. An unscheduled shutdown should be considered for repairs.

Vibration Data	Analysis
 <p>Route Spectrum 14-May-20 09:47:30 (PKVue-HP 5000 Hz) OVERALL= 3.21 A-DG RMS = 3.21 LOAD = 100.0 RPM = 359.4 (59.90 Hz)</p> <p>Route Waveform 14-May-20 09:47:30 (PKVue-HP 5000 Hz) RMS = 4.86 PK(H) = 22.55 CRESTF=4.64 DCoff = .3877</p> <p>Freq: 119.78 Ordr: 2.000 Spec: 1.322</p>	Large jump in amplitude of spectral peaks.

Discussion / Repair recommendations	Trend Data
Data indicates a sudden change in the motor bearings since the last survey. We believe they are in distress. Recommend replacing the motor in the next few months or possibly sooner. Rated a Class II Defect for now.	 <p>Trend Display of Overall Value</p> <p>Baseline Value: .073 Date: 30-Nov-16</p> <p>Date: 14-May-20 Time: 09:47:34 Ampl: 3.215</p>