





Client	Penn A Kem	Survey Date	6-25-20
Location	Memphis, TN	Report Date	6-30-20
Machine	R55-106 Reactor Agitator Motor Gearbox	QMS No.	142734
Component		Analyst	DWS



Defect Rating for this machine	Class III
Defect Rating System	
Class I: Defect is present, but effect on reliability is not clear; no immediate action is required. Continue normal monitoring.	Class III: Defect (s) present that may cause failure in short term (less than 2 mos.). Should be addressed as soon as practical, with a high maintenance priority. Increase monitoring frequency.
Class II: Defect (s) present that may cause problem in long term (2-6 mos.). Repair during normal maintenance scheduling. Continue to monitor.	Class IV: Defect (s) present that makes continued reliability unpredictable, and possibility of secondary damage is high. Repairs should be made ASAP. An unscheduled shutdown should be considered for repairs.


Vibration Data	Analysis
<p>NEW - REACTOR AGIT-R-106 R55-106 - 42 MOTOR OUTBOARD VERT</p>  <p>25-Jun-20 12:57:36 22-Apr-20 12:28:09 25-Mar-20 12:26:24 06-Jun-20 12:28:28 18-Oct-19 11:08:12</p> <p>25-Jun-20 12:57:36 RPM= 1791. Freq: 26.44 Ordr: .885 Sp 6: .657 Dfrq: .00000</p> <p>PK Velocity in in/sec</p> <p>Frequency in Hz</p> <p>Max Amp .66 Plot Scale 1.4</p>	<p>Large 1x RPM increase in the outboard motor vertical vibration.</p>
Discussion / Repair recommendations	Trend Data
<p>Large increase in 1x RPM sinusoidal vibration for the outboard vertical of the motor over time. Inspect the motor and coupling for defects that could cause imbalance. Check the motor cooling fan. Loose fasteners can cause similar vibrations as well as shaft run out or eccentricity. Rated a Class III Defect.</p>	 <p>NEW - REACTOR AGIT-R-106 R55-106 - 42 MOTOR OUTBOARD VERT</p> <p>PK Velocity in in/sec</p> <p>Days: 20-Jan-16 To 25-Jun-20</p> <p>Trend Display of Overall Value Deviation - Value: .0828 Date: 22-Apr-20</p> <p>FAULT ALERT WARNING</p> <p>Date: 25-Jun-20 Time: 12:57:39 Ampl: 714</p>



Client	Penn A Kem	Survey Date	6-25-20
Location	Memphis, TN	Report Date	6-30-20
Machine	P4C-102A Boiler Feed Water Pump	QMS No.	142734
Component	Pump Bearings	Analyst	DWS

Defect Rating for this machine	Class IV
Defect Rating System	
Class I: Defect is present, but effect on reliability is not clear; no immediate action is required. Continue normal monitoring.	Class III: Defect (s) present that may cause failure in short term (less than 2 mos.). Should be addressed as soon as practical, with a high maintenance priority. Increase monitoring frequency.
Class II: Defect (s) present that may cause problem in long term (2-6 mos.). Repair during normal maintenance scheduling. Continue to monitor.	Class IV: Defect (s) present that makes continued reliability unpredictable, and possibility of secondary damage is high. Repairs should be made ASAP. An unscheduled shutdown should be considered for repairs.

Vibration Data	Analysis
<p>NEW - BOILER FEEDWATER PUMP P4C-102A -73 PUMP CPGS END AXIAL</p>  <p>Route Spectrum 25-Jun-20 11:44:29 OVERALL= 1.21 V-DG PK = 1.20 LOAD = 100.0 RPM = 3570. (59.50 Hz)</p>  <p>Route Waveform 25-Jun-20 11:44:29 PK = 19.77 PK(4/3) = 41.51/31.40 CRE STF= 2.97</p> <p>Freq: 320.63 Ord: 5.389 Spec: .02883</p>	<p>Multiple non-synchronous peaks in the acceleration spectrum and impacting in the time domain.</p>

Discussion / Repair recommendations	Trend Data
<p>The outboard pump bearings are in so much distress that data could not be taken due to over saturation of the accelerometer. Only data from the inboard bearing could be taken. The outboard pump bearings are shot. Inspect the pump and replace any worn or damaged parts.</p> <p>Rated a Class IV Defect</p>	 <p>Trend Display of Overall Value - Bearing -- Value: .0835 Date: 25-May-20</p> <p>Date: 25-Jun-20 Time: 11:44:28 Ampl: 1.206</p>



Client	Penn A Kem	Survey Date	6-25-20
Location	Memphis, TN	Report Date	6-30-20
Machine	P48-7B Roto Jet High Pressure Pump	QMS No.	142734
Component		Analyst	DWS

Defect Rating for this machine	NA
Defect Rating System	
Class I: Defect is present, but effect on reliability is not clear; no immediate action is required. Continue normal monitoring.	Class III: Defect (s) present that may cause failure in short term (less than 2 mos.). Should be addressed as soon as practical, with a high maintenance priority. Increase monitoring frequency.
Class II: Defect (s) present that may cause problem in long term (2-6 mos.). Repair during normal maintenance scheduling. Continue to monitor.	Class IV: Defect (s) present that makes continued reliability unpredictable, and possibility of secondary damage is high. Repairs should be made ASAP. An unscheduled shutdown should be considered for repairs.

