





Client	PennAKem	Survey Date	10-21-20
Location	Memphis, TN	Report Date	10-23-20
Machine	C53-1A Hydrogen Compressor	QMS No.	143630
Component	Outboard bearing	Analyst	DWS



Defect Rating for this machine	CLASS I
Defect Rating System	
Class I: Defect is present, but effect on reliability is not clear; no immediate action is required. Continue normal monitoring.	Class III: Defect (s) present that may cause failure in short term (less than 2 mos.). Should be addressed as soon as practical, with a high maintenance priority. Increase monitoring frequency.
Class II: Defect (s) present that may cause problem in long term (2-6 mos.). Repair during normal maintenance scheduling. Continue to monitor.	Class IV: Defect (s) present that makes continued reliability unpredictable, and possibility of secondary damage is high. Repairs should be made ASAP. An unscheduled shutdown should be considered for repairs.






Client	PennAKem	Survey Date	10-21-20
Location	Memphis, TN	Report Date	10-23-20
Machine	R80-10 Reactor Agitator Motor/Gearbox	QMS No.	143630
Component	Motor Bearings	Analyst	DWS

Defect Rating for this machine	CLASS III
Defect Rating System	
Class I: Defect is present, but effect on reliability is not clear; no immediate action is required. Continue normal monitoring.	Class III: Defect (s) present that may cause failure in short term (less than 2 mos.). Should be addressed as soon as practical, with a high maintenance priority. Increase monitoring frequency.
Class II: Defect (s) present that may cause problem in long term (2-6 mos.). Repair during normal maintenance scheduling. Continue to monitor.	Class IV: Defect (s) present that makes continued reliability unpredictable, and possibility of secondary damage is high. Repairs should be made ASAP. An unscheduled shutdown should be considered for repairs.



Vibration Data	Analysis
<p>NEW - AGITATOR GSK R80-10 -12 MOTOR OUTBOARD VERT</p>  	<p>Crest factor over 7 now.</p>


Discussion / Repair recommendations	Trend Data
<p>The unit motor vibrations are relatively low, but we believe the bearings are in distress due to the elevated crest factor of 7.4 for the outboard bearing. We recommend replacing the motor before years' end.</p> <p>Rated a Class III Defect.</p>	



Client	PennAKem	Survey Date	10-21-20
Location	Memphis, TN	Report Date	10-23-20
Machine	P81101B West Fire Pump	QMS No.	143630
Component	Pump Bearings	Analyst	DWS

Defect Rating for this machine	CLASS III
Defect Rating System	
Class I: Defect is present, but effect on reliability is not clear; no immediate action is required. Continue normal monitoring.	Class III: Defect (s) present that may cause failure in short term (less than 2 mos.). Should be addressed as soon as practical, with a high maintenance priority. Increase monitoring frequency.
Class II: Defect (s) present that may cause problem in long term (2-6 mos.). Repair during normal maintenance scheduling. Continue to monitor.	Class IV: Defect (s) present that makes continued reliability unpredictable, and possibility of secondary damage is high. Repairs should be made ASAP. An unscheduled shutdown should be considered for repairs.

Vibration Data	Analysis
<p>NEW - Fire Pump - West P81-101B -71 PUMP CPLG END HORIZ</p>  <p>Route Spectrum 21-Oct-20 10:03:12 OVERALL= .3636 V-DG PK = 1.56 LOAD = 100.0 RPM = 1790, (29.83 Hz)</p>  <p>Route Waveform 21-Oct-20 10:03:12 PK = 1.70 PK[4/3] = 7.05/11.03 CRE STF= 9.18</p> <p>CF ALARM PK ALARM CF ALARM PK ALARM</p> <p>Freq: 291.38 Ord: 9.769 Spec: .481</p>	<p>Crest Factor over 9.76. Sharp impacting.</p>

Discussion / Repair recommendations	Trend Data
<p>The Pump Bearings are in distress. Impacting is easily Identified with a Crest factor over 9. Recommend replacing the pump bearings and a complete internal inspection of wear parts and rotating elements. Have the motor inspected and serviced also. Rated a Class III Defect.</p>	 <p>NEW - Fire Pump - West WINDUP/PLAY OF Overall Value</p> <p>PK Velocity in in/sec</p> <p>Days: 13Feb-09 To 21-Oct-20</p> <p>Date: 21Oct-20 Time: 10:03:43 Amp: .364</p>