

**Report Title**  
**Submitted By** Chris Senter  
**Create Date** 07/24/21 8:12 AM  
**Asset Name** TAD # 1 AREA SUMP PUMP  
**Description** OFF LINE AND ON LINE POWER RESULTS



KEEPING YOUR FACILITY UP TO SPEED  
 — EVERY DAY SINCE 1946 —

**Date:** 07/16/21 1:18 PM **Test:** Power Results

VOLTAGE					EFFICIENCY	
	Fund RMS	Tot RMS	C.F.	THD		kW
Voltage 1-2	145.70	254.23	2.31	14.45	Efficiency	0.00
Voltage 2-3	139.32	252.52	2.24	14.59	HP Output	0.00
Voltage 1-3	143.77	255.09	2.24	16.83	kW Output	0.00
Average	142.93	253.94			Torque Output (ft.-lb.)	0.00
% Imbalance	2.53	0.56	HVF	0.02		
% NEMA Derating	92.32	100.00				
Voltage 1	80.65	147.44	2.40	20.79	IMPEDANCE	
Voltage 2	83.47	145.95	2.40	15.75		Real
Voltage 3	83.69	146.45	2.32	17.25	% Imbalance	298.50
Average	82.60	146.62				
% Imbalance	2.37	0.56				
CURRENT						
	Fund RMS	Tot RMS	C.F.	THD		
Current 1	17.01	25.45	1.61	12.58		
Current 2	17.07	25.46	1.55	17.02		
Current 3	16.51	25.86	1.57	13.36		
Average	16.86	25.59				
% Imbalance	2.09	1.06				
% FLA	24.80	37.64				
POWER						
	kW	kVAR	kVA	Pf		
Phase 1	0.83	3.66	3.75	0.60		
Phase 2	-0.67	3.66	3.72	-0.47		
Phase 3	0.90	3.70	3.79	0.58		
Total	0.96	11.02	11.26	0.24		

**Test:** AC Standard  
**Section:** Stator

Test Date	07/16/21
Test Time	11:24 AM
Test Location	Drive Output
Tester Serial	5095
MTap ID	
	Baseline
Frequency	1200
Charge Time	600
Voltage	1000
Motor Temp	50
Measured Mohm	21136.66
Corrected Mohm	42300.00
pF Ph 1 to Ground	109700
ohm Ph 1 to 2	0.31710
ohm Ph 2 to 3	0.31670
ohm Ph 3 to 1	0.31710
mH Ph 1 to 2	5.215
mH Ph 2 to 3	6.148
mH Ph 3 to 1	6.163
Average Inductance	5.842
% Res. Imbalance	0.08
% Ind. Imbalance	10.75

Remarks: The off line data indicates that the motor has some inductive imbalance of 10.75%. some motors can run as high as 17%. i see this as no issue for now.

The online test is indicating that there is a inductive imbalance of 298.5% this is a indication that the drive is going bad. I recommend changing the drive and retest.